

SBC 201 Chapter 6 Types of Construction — Group R-2 High-Rise Dimensional Requirements Matrix (2024)

1. Document metadata and use limitation

- **Project basis:** Riyadh, Saudi Arabia; Group R-2 residential high-rise; an occupied floor is stated to be more than 23 m above the relevant reference level.
- **Deliverable tier:** Project-use matrices in Sections 4–8 (design-check rows, not pasted inventory), plus a coverage summary and unresolved-source register. The full row inventory is not published.
- **Code/source basis:** SBC 201 (2024), Chapter 6, source file Reference\SBC 201 2024\source_reference\Chapter_06 – TYPES OF CONSTRUCTION.txt.
- **Extraction audit:** Skill extract. Project-use rows follow the chapter-extract row contract (noun-phrase checks, bold SI values, building-language triggers, named exceptions, check-specific actions). Internal inventory: **57** independently checkable numeric records (**56** Verified, **1** Verify source). Unresolved OCR is listed in the register and is not a design-release value.
- **Model:** Cursor Grok 4.6.
- **Prepared:** 2026-08-27.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped compliance statement, fire-resistance design, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Outbound-source rule:** No value in this matrix has been imported from Table 705.5, Section 703.2 / 703.3 / 703.6, 704, 711, 713, 718, Tables 722.7.1(1)–(2), Chapter 5 / 510, 2303.2 / 2304.11 / Table 2304.11, SBC 501 plenums, Chapter 8 / 14 / 15 / 26, commentary examples, bibliography years, or the existing chapter summary. Where Chapter 6 sends the user elsewhere, this matrix records the dependency without supplying the outbound value.

Scope and assumptions

1. Group R-2 and high-rise status are project statements, not independently verified classifications.
2. The exact Riyadh AHJ/permit pathway, project stage, fire-strategy status and SCD NOC status are unconfirmed; therefore this matrix does not conclude compliance.
3. Type of construction is unconfirmed. A Group R-2 high-rise is expected to be Type I or II unless the project elects mass timber (Type IV-A/B/C). Type III, Type V and Type IV-HT are not treated as the tower shaft.
4. Automatic sprinkler protection, mixed-use podium, storey count and fire separation distance are unconfirmed. Sprinkler branches that appear in this chapter are shown, not assumed.
5. Table 601 in the attached extract is concatenated. No hourly cell and no table note a–g is adopted from memory, commentary or the chapter summary.
6. Commentary Figure 601 roof-clearance examples, Table 601 Note b **6 m** roof-unprotected relief, and commentary hour grids (IA **3 h** / IB **2 h** / IIA **1 h** / IIB **0 h**) are not adopted. The **6 m** that is numbered code is 603.1 Item 1.3 Exception 1 only.

2. Legends

Applicability

Status	Meaning
Direct	Expected to govern the stated R-2 tower basis, subject to confirmed geometry and design data.
Conditional	Governs only when the stated feature, construction type, sprinkler branch or exception exists.
Not typical	Unrelated occupancy-only or low-rise construction-type rule; omitted from this deliverable unless the gap register already opened that use.
External verification	Chapter 6 points to another section/code/standard, or the project/AHJ basis must be confirmed before use.

Source confidence

Status	Meaning
Verified	Requirement and any stated numeric value were checked against unambiguous mandatory Chapter 6 source text.
Verify source	OCR, flattened table, page-split, or footnote attachment is unresolved. Not a design-release value.

3. Project decision and gap register

Decision / gap	Current project basis	Why it controls Chapter 6 application	Required project action
Type of construction	Unconfirmed; high-rise R-2 typically Type I or II, not verified	Locks Table 601 ratings, 602.2 noncombustible basis vs 602.4 mass timber, and which 603 combustibles apply	Freeze Type IA/IB/IIA/IIB or IV-A/B/C on the code data sheet before fireproofing, wall and floor assemblies
Table 601 hourly grid	Flattened in the extract; no cell adopted	Every primary-frame, bearing-wall, floor and roof rating in this chapter is charged to Table 601	Verify the published Table 601; do not reconstruct hours from IBC memory or commentary
Mass timber vs Type I/II	Unconfirmed	602.4 encapsulation, exposed-timber percentages and 23 m / 12 stories / 54 m core-enclosure rules apply only if Type IV-A/B/C is selected	State whether the tower is noncombustible or mass timber before detailing CLT, gypsum protection or stair/elevator shafts
Storey count / height	Occupied floor stated above 23 m; exact storeys unconfirmed	Type IV-A/B/C interior exit and elevator hoistway enclosures change at 12 stories or 54 m above grade plane	If mass timber is used, lock storey count and height above grade plane against that split
Podium / mixed types	Unconfirmed	602.1 allows multiple types only where the code specifically calls them out (Section 510) or a fire wall creates two buildings. 510 values are not imported	Do not mix Type V or III podium with a Type I shaft unless a 510 or fire-wall path is documented
Fire separation distance	Unconfirmed by wall	602.1 charges exterior walls to Table 705.5 in addition to Table 601; 705.5 values are not in this chapter	Dimension FSD on each elevation; take exterior-wall hours from the higher of the two tables once both are verified
Sprinkler system	Unconfirmed; NFPA 13 vs 13R not selected	603.1 Item 26 freezer/cooler wood walls require 903.3.1.1 throughout. Type IV concealed-space sprinkler options are in 718 / 903, not imported	Show the 903.3.1.1 branch only if a freezer/cooler enclosure uses combustible walls; do not assume 13R satisfies Item 26
NOC and fire strategy	SCD NOC and stamped fire-strategy status unconfirmed	Construction type, fireproofing and mass-timber encapsulation cannot be concluded from Chapter 6 text alone	Engage the qualified local/fire/structural consultants before design freeze

4. Construction classification and charging

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
601.1	Chapter construction-type scope	This chapter controls classification of buildings as to type of construction	All buildings	None stated	Direct	Assign a Type I–V classification on the code data sheet before running height/area or fire-resistance schedules	Verified
602.1	Construction type assignment	Classify buildings erected, altered or extended in height or area as one of the five types in 602.2 through 602.5. Building elements shall have a fire-resistance rating not less than Table 601. Exterior walls shall have a fire-resistance rating not less than Table 705.5. Where Table 601 requires a rating, comply with 703.2. Openings, ducts and air-transfer openings in Table 601 elements are not required to be protected unless other provisions of this code require it	New work, additions, and height or area extensions	Multiple types in one structure only where specifically allowed (Section 510) or where a fire wall creates separate buildings. Table 601 hours, Table 705.5 hours and 703.2 test criteria are not imported	Direct	Name the selected type on the drawings; take element hours from verified Table 601, exterior-wall hours from Table 705.5, and rated-assembly tests from 703.2	Verified
602.1.1	Higher-type features	A building or portion need not conform to a type of construction higher than the type that meets the occupancy minimum, even if some features actually conform to a higher type	Building classified at a stated type	Meeting a higher rating on some members does not reclassify the building unless all requirements of that higher type are met	Direct	Classify the tower by the type it fully meets; do not claim Type IA from a few over-rated members	Verified

5. Table 601 and element ratings

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
Table 601	Building-element fire-resistance	Minimum hourly fire-resistance ratings for building elements by construction type. The attached table is concatenated (TYPE VABABABABABCHT with run-on cells). No hourly cell is adopted	Primary structural frame, bearing walls, nonbearing walls, floor construction and roof construction	Notes a–g are referenced in the blob but are not recoverable as code text in this extract. Commentary hour grids and Note b 6 m roof relief are not adopted	Direct	Verify the published Table 601 before issuing fireproofing, wall ratings or roof ratings; do not reconstruct hours from memory	Verify source

6. Types I and II noncombustible basis

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
602.2	Types I and II materials	Types I and II construction are those in which the building elements specified in Table 601 are of noncombustible materials, except as permitted in Section 603 and elsewhere in this code	Tower assigned Type I or II	Combustible materials only where 603.1 through 603.1.3 (or another code section) expressly allow them. Table 601 hours remain a Verify-source hold	Direct	Specify noncombustible frame, floors, walls and roof unless a numbered 603 allowance is shown on the same drawing	Verified

7. Type IV mass timber

Apply this section only if the project elects Type IV-A, IV-B or IV-C. Type IV-HT is omitted as not typical for the high-rise shaft.

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
602.4	Type IV materials and rating basis	Building elements shall be mass timber or noncombustible and shall have fire-resistance ratings in accordance with Table 601. Mass timber ratings from noncombustible protection, the mass timber, or both, determined per 703.2. Minimum dimensions per this section and 2304.11. IV-A/B/C mass timber shall receive noncombustible protection applied directly, with assigned time per 703.6 and 722.7. CLT labeled to ANSI/APA PRG 320 per 2303.1.4	Type IV construction	Exterior and interior elements of Type IV-HT follow 602.4.4 (omitted here). Combustible concealed spaces only as 602.4.1 through 602.4.4 allow. Light-frame wood is not a Type IV-A/B/C option. 2304.11 sizes and 722.7 times are not imported	Conditional	If mass timber is selected, freeze IV-A, IV-B or IV-C and send member sizes to 2304.11; do not mix light-frame wood into the shaft	Verified
602.4	Mass timber exit and hoistway enclosures	In Type IV-A, IV-B and IV-C with an occupied floor more than 23 m above the lowest level of fire department access, up to and including 12 stories or 54 m above grade plane, mass timber interior exit and elevator hoistway enclosures shall be protected in accordance with 602.4.1.2. In buildings greater than 12 stories or 54 m above grade plane, those enclosures shall be constructed of noncombustible materials	Type IV-A/B/C high-rise	Other shafts above 12 stories or 54 m are not rewritten by this sentence. 602.4.1.2 protection times stay with the IV-A interior-protection rows	Conditional	If the tower is mass timber, lock stair and elevator enclosure material at the 12-storey / 54 m split and show 602.4.1.2 protection below that split	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
602.4.1.1	IV-A exterior encapsulation and WRB	Outside face of mass timber exterior walls: noncombustible protection with minimum assigned time 40 minutes (Table 722.7.1(1)). Exterior wall covering noncombustible except a WRB with peak heat release rate less than 150 kW/m² , total heat release less than 20 MJ/m² , effective heat of combustion less than 18 MJ/kg (ASTM E1354, thickness intended for use, horizontal, incident flux 50 kW/m²), flame spread index 25 or less and smoke-developed index 450 or less (ASTM E84 or UL 723)	Type IV-A mass timber exterior walls	722.7.1(1) assigned times are not imported beyond the 40-minute minimum stated here	Conditional	Put 40-minute exterior protection and the WRB E1354/E84 limits on the Type IV-A wall type; keep Table 722.7 values off this sheet	Verified
602.4.1.2–602.4.1.2.1	IV-A interior protection time	Interior faces of all mass timber elements, including inside faces of exterior mass timber walls and mass timber roofs, shall be protected with 703.3 materials. Noncombustible protection shall contribute not less than Table 722.7.1(1) times, and not less than 80 minutes . Table 722.7.1(2) contributions may be used for 722.7.1 compliance	Type IV-A mass timber interior faces	722.7.1(1)–(2) cell times are not imported. Commentary two-thirds / 120-minute examples are not adopted	Conditional	Specify interior noncombustible protection ≥ 80 minutes on every Type IV-A mass timber face; verify Table 722.7 for the assigned contribution	Verified
602.4.1.3	IV-A floor topping	Floor assembly shall contain a noncombustible material not less than 25 mm thick above the mass timber. Floor finishes per 804 may be applied on top. Underside protected per 602.4.1.2	Type IV-A mass timber floors	804 finish limits are not imported	Conditional	Show a ≥ 25 mm noncombustible topping on Type IV-A floor assemblies and 602.4.1.2 protection on the soffit	Verified
602.4.1.4	IV-A roof interior and covering	Interior surfaces of roof assemblies protected per 602.4.1.2. Roof coverings in accordance with Chapter 15 on the outside	Type IV-A mass timber roofs	Chapter 15 values are not imported	Conditional	Protect the Type IV-A roof soffit to 602.4.1.2 and specify the covering from Chapter 15, not from this chapter	Verified
602.4.1.5	IV-A concealed-space combustibles	Concealed spaces shall not contain combustibles other than electrical, mechanical, fire-protection or plumbing materials and equipment permitted in plenums per SBC 501 Section 602, and shall comply with 718. Combustible construction forming concealed spaces shall be protected per 602.4.1.2	Type IV-A concealed spaces	SBC 501 and 718 values are not imported	Conditional	Limit Type IV-A concealed-space contents to listed MEP/fire materials and encapsulate mass timber in those spaces per 602.4.1.2	Verified
602.4.1.6	IV-A shaft-face protection	Shafts permitted per 713 and 718. Both the shaft side and the room side of mass timber elements shall be protected per 602.4.1.2	Type IV-A shafts	713 and 718 values are not imported	Conditional	Encapsulate both faces of Type IV-A mass timber shaft walls to 602.4.1.2	Verified
602.4.2.1	IV-B exterior encapsulation and WRB	Outside face of mass timber exterior walls: noncombustible protection with minimum assigned time 40 minutes (Table 722.7.1(1)). WRB exception same as 602.4.1.1: peak heat release less than 150 kW/m² , total heat release less than 20 MJ/m² , effective heat of combustion less than 18 MJ/kg , E1354 horizontal at 50 kW/m² , flame spread 25 or less, smoke-developed 450 or less	Type IV-B mass timber exterior walls	The attached extract omits the 602.4.2.1 heading; running text is readable and is used. 722.7 cell times not imported	Conditional	Repeat the 40-minute exterior protection and WRB limits on Type IV-B wall types	Verified
602.4.2.2–602.4.2.2.1	IV-B interior protection time	Interior faces of all mass timber elements, including inside faces of exterior mass timber walls and roofs, shall be protected as required by this section with materials complying with 707.3. Noncombustible protection not less than Table 722.7.1(1) times, and not less than 80 minutes . Table 722.7.1(2) may be used for 722.7.1	Type IV-B mass timber interior faces	Exposed-area exceptions in 602.4.2.2.2–602.4.2.2.4. The extract cites 707.3 (not 703.3). 722.7 cells not imported	Conditional	Specify ≥ 80-minute interior protection on Type IV-B mass timber except where a numbered exposed-timber exception is proven	Verified
602.4.2.2.2–602.4.2.2.4	IV-B exposed mass timber limits	Unprotected mass timber ceilings, including attached beams, limited to 20 percent of the floor area in any dwelling unit or fire area. Unprotected walls, including attached columns, limited to 40 percent of that floor area. Where both walls and ceilings are unprotected, Equation 6-1 requires $(U_{tc} / U_{ac}) + (U_{tw} / U_{aw}) \leq 1$. Unprotected portions of walls and ceilings not less than 4.5 m from other unprotected wall or ceiling portions, measured horizontally along the ceiling or along the floor	Type IV-B dwelling unit or fire area with exposed mass timber	Exception 2: columns and beams that are not an integral portion of walls or ceilings may be unprotected without aggregate-area or separation limits. Commentary unit-area examples are not adopted	Conditional	Calculate exposed CLT per dwelling unit against 20 percent / 40 percent / Equation 6-1 and keep exposed patches ≥ 4.5 m apart on the unit plans	Verified
602.4.2.3	IV-B floor topping	Floor assembly shall contain a noncombustible material not less than 25 mm thick above the mass timber. Floor finishes per 804 permitted on top. Underside protected per 602.4.1.2	Type IV-B mass timber floors	804 values are not imported	Conditional	Show a ≥ 25 mm noncombustible topping on Type IV-B floors and 602.4.1.2 protection on the soffit	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
602.4.2.4	IV-B roof occupiable vs concealed	Interior roof surfaces protected per 602.4.2.2 except in nonoccupiable spaces, which shall be treated as a concealed space with no portion left unprotected. Roof coverings per Chapter 15 on the outside	Type IV-B mass timber roofs	Occupiable roof interiors may use the 602.4.2.2.2 exposed-area exceptions; nonoccupiable roofs may not. Chapter 15 values not imported	Conditional	Leave Type IV-B exposed timber off nonoccupiable roof voids; protect those surfaces as concealed space	Verified
602.4.2.5–602.4.2.6	IV-B concealed spaces and shafts	Concealed spaces: combustibles limited as 602.4.1.5; combustible construction forming those spaces protected per 602.4.1.2. Shafts per 713 and 718; both shaft side and room side of mass timber protected per 602.4.1.2	Type IV-B concealed spaces and shafts	SBC 501, 713 and 718 values are not imported	Conditional	Encapsulate Type IV-B concealed-space and shaft mass timber on both faces to 602.4.1.2	Verified
602.4.3.1	IV-C exterior encapsulation and WRB	Exterior side of combustible walls: noncombustible protection with minimum assigned time 40 minutes (Table 722.7.1(1)). WRB exception same numeric limits as 602.4.1.1 (150 kW/m², 20 MJ/m², 18 MJ/kg, 50 kW/m² flux, flame spread 25 , smoke-developed 450)	Type IV-C combustible exterior walls	722.7 cell times not imported	Conditional	Put 40-minute exterior protection and the WRB test limits on Type IV-C wall types	Verified
602.4.3.2–602.4.3.4	IV-C exposed interior, floors and roofs	Mass timber elements are permitted to be unprotected on the interior. Floor finishes per 804 may be applied on top of the floor construction. Roof coverings per Chapter 15 on the outside	Type IV-C mass timber interiors, floors and roofs	Other sections (occupancy separation, incidental uses) may still require protection. 804 and Chapter 15 values are not imported. No 25 mm topping is required by this section	Conditional	If Type IV-C is used, do not copy the IV-A/B topping or interior 80-minute encapsulation onto exposed interiors; still meet Table 601 by the timber itself	Verified
602.4.3.5	IV-C concealed-space protection	Concealed spaces: combustibles limited as for IV-A; combustible construction forming concealed spaces protected with noncombustible protection with minimum assigned time 40 minutes (Table 722.7.1(1))	Type IV-C concealed spaces	SBC 501 and 718 values are not imported. This 40-minute minimum is not the IV-A/B 80-minute interior face rule	Conditional	Encapsulate Type IV-C concealed-space mass timber to 40 minutes ; do not leave those voids exposed	Verified
602.4.3.6	IV-C shaft and enclosure protection	Shafts per 713 and 718. Shafts and elevator hoistway and interior exit stairway enclosures shall be protected with noncombustible protection with minimum assigned time 40 minutes (Table 722.7.1(1)) on both the inside and the outside of the shaft	Type IV-C shafts, hoistways and interior exit stair enclosures	713, 718 and 722.7 cell times are not imported	Conditional	Specify 40-minute noncombustible protection on both faces of Type IV-C shaft and exit-stair mass timber	Verified

8. Combustible materials in Types I and II

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
603.1	Combustible allowance list	Combustible materials are permitted in Type I or II construction only in the applications in 603.1 Items 1 through 27 and 603.1.1 through 603.1.3	Type I or II building	Items not listed are not a Type I/II combustible allowance	Direct	Tie every combustible product on Type I/II drawings to a numbered 603.1 item	Verified
603.1 Item 1.1	FRTW nonbearing partitions	Fire-retardant-treated wood permitted in nonbearing partitions where the required fire-resistance rating is 2 hours or less	Type I or II nonbearing partitions	Not permitted in shaft enclosures within Group I-2 occupancies and ambulatory care facilities (not the R-2 tower occupancy)	Direct	Limit FRTW partitions on the tower to nonbearing walls rated 2 hours or less; keep FRTW out of shafts	Verified
603.1 Item 1.2	FRTW nonbearing exterior walls	Fire-retardant-treated wood permitted in nonbearing exterior walls where fire-resistance-rated construction is not required	Type I or II nonbearing exterior walls with no required rating	If Table 601 or Table 705.5 requires a rating, this item does not apply	Direct	Use FRTW in Type I/II exterior walls only on nonbearing, non-rated walls	Verified
603.1 Item 1.3	FRTW roof construction	Fire-retardant-treated wood permitted in roof construction, including girders, trusses, framing and decking	Type I or II roofs	Exception 1: Type IA exceeding two stories above grade plane — FRTW is not permitted in the roof where the vertical distance from the upper floor to the roof is less than 6 m . Exception 2: Group I-2 Class A roof covering (not the R-2 occupancy)	Direct	On a Type IA high-rise, allow FRTW roof members only where upper-floor-to-roof clearance is 6 m or more; otherwise keep the roof noncombustible	Verified
603.1 Item 2	Insulation flame-spread index	Thermal and acoustical insulation other than foam plastics: flame spread index not more than 25	Insulation in Type I or II construction	Exception 1: between two layers of noncombustible materials with no intervening airspace, flame spread not more than 100 . Exception 2: between a finished floor and solid decking with no intervening airspace, flame spread not more than 200 . Foam plastics go to Chapter 26	Direct	Specify insulation FSI ≤ 25 unless a no-airspace sandwich or under-floor exception is detailed	Verified
603.1 Items 3, 15, 17	Plastics and foam	Foam plastics in accordance with Chapter 26. Light-transmitting plastics as permitted by Chapter 26. Exterior plastic veneer in accordance with 2605.2	Those products in Type I or II construction	Chapter 26 / 2605.2 values are not imported	External verification	Send foam, light-transmitting plastic and plastic veneer to Chapter 26; do not invent thicknesses here	Verified
603.1 Item 4	Combustible roof coverings	Roof coverings that have an A, B or C classification are permitted	Type I or II roof coverings	Classification is selected under Chapter 15; those tables are not imported	Direct	Allow a classified A/B/C covering on a noncombustible or FRTW deck; take the required class from Chapter 15	Verified
603.1 Items 5–8, 10	Interior finishes and millwork	Interior floor finish and floor covering per 804. Millwork such as doors, door frames, window sashes and frames. Interior wall and ceiling finishes per 801 and 803. Trim per 806. Finish flooring per 805	Those finish applications in Type I or II construction	Chapter 8 values are not imported	External verification	Keep doors, frames, finishes and trim on the finish schedule; take flame-spread limits from Chapter 8, not from this list	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
603.1 Item 9	Show-window wood	Show windows, nailing or furring strips and wooden bulkheads below show windows, including frames, aprons and show cases, where not installed greater than 4500 mm above grade	Type I or II show-window construction	None stated	Conditional	If podium retail uses wood show windows, keep that wood ≤ 4500 mm above grade	Verified
603.1 Item 11	Single-tenant low partitions	Partitions dividing portions of stores, offices or similar places occupied by one tenant only, that do not establish a corridor serving an occupant load of 30 or more, may be FRTW, 1-hour fire-resistance-rated construction, or wood panels or similar light construction up to 1.8 m in height	Single-tenant store/office subdivisions in Type I or II	Not permitted if the partition forms a corridor serving 30 or more occupants, or exceeds 1.8 m	Conditional	Limit amenity/office wood screens to 1.8 m and keep them off corridors serving 30 or more occupants	Verified
603.1 Item 13	Combustible exterior coverings	Combustible exterior wall coverings, balconies and similar projections and bay or oriel windows in accordance with Chapter 14 and 705.2.3.1	Those features on Type I or II walls	Chapter 14 and 705.2.3.1 values are not imported	External verification	Detail combustible cladding and balconies from Chapter 14 / 705.2.3.1; do not copy those heights or percentages here	Verified
603.1 Items 14, 16, 18, 20–25, 27	Blocking, firestopping and nailers	Blocking for handrails, millwork, cabinets and frames; mastics and caulking at exterior wall joints; nailing or furring strips per 803.15; aggregates/admixtures per 703.2.1.2; sprayed and intumescent fire-resistant materials per 703.2, 1705.15 and 1705.16; penetration and joint materials per 714 and 715; concealed-space materials per 718.5; plenum materials per SBC 501 Section 602; wood nailers for parapet flashing and roof cants	Those listed minor combustibles in Type I or II	Outbound section values are not imported. Item 19 heavy timber depends on Table 601 Note c, which is not recovered in this extract	Direct	Allow listed blocking, nailers, sealants and firestopping; do not treat them as a licence for combustible framing	Verified
603.1 Item 19	Heavy timber in Types I and II	Heavy timber as permitted by Note c to Table 601 and Sections 602.4.4.4 and 705.2.3.1	Heavy timber proposed in Type I or II	Table 601 Note c is not recoverable in this extract. 602.4.4.4 and 705.2.3.1 values are not imported	External verification	Do not specify heavy timber in Type I/II until published Table 601 Note c, 602.4.4.4 and 705.2.3.1 are verified	Verified
603.1 Item 26	Freezer and cooler walls	Wall construction of freezers and coolers of less than 100 m² in size, lined on both sides with noncombustible materials, and the building protected throughout with an automatic sprinkler system in accordance with 903.3.1.1	Freezer or cooler rooms in Type I or II	All three conditions apply together. 903.3.1.1 (NFPA 13) is not 13R. 903 values are not imported	Conditional	If a combustible-framed cooler is used, keep area less than 100 m² , line both faces with noncombustible materials, and confirm 903.3.1.1 throughout	Verified
603.1.1–603.1.3	Ducts, piping and electrical	Nonmetallic ducts permitted within SBC 501 limitations. Combustible piping permitted within SBC 501 and SBC 701 limitations. Electrical wiring methods with combustible insulation, tubing, raceways and related components permitted within the limitations of this code	MEP systems in Type I or II	SBC 501, SBC 701 and electrical-code values are not imported	External verification	Do not override SBC 501/701/401 combustible-MEP rules with construction type; do not import those limits here	Verified

9. Project-use controls

1. Use **Verified** rows for initial scoping after the row trigger is confirmed (construction type, mass timber, podium retail, freezer, and so on).
2. Treat every **Verify source** row as a hold. Table 601 hours and Table 601 Note c are not design-release values.
3. Do not import Table 705.5, 703.2, 722.7, 2304.11, Chapter 8 / 14 / 15 / 26, SBC 501 or 903.3.1.1 numeric criteria into issued drawings from this matrix.
4. Do not adopt commentary Table 601 hour grids, Note b **6 m** roof-unprotected relief, or Commentary Figure 601 **4.5 m** mezzanine examples.
5. Type III, Type V, Type IV-HT, Group I-2 FRTW roof Exception 2, and FRTW balconies on buildings **three stories or less** (603.1 Item 1.4) are omitted from lead tables as not typical for this tower shaft.
6. Record construction-type and mass-timber decisions in the project Golden Thread; this matrix is not evidence of SCD NOC or stamped compliance.

10. Coverage summary

Internal inventory of the attached Chapter 6 extract (numbered code, exceptions, tables, footnotes; commentary excluded). Row-level records are not published.

- **Inventory scope:** numbered code, exceptions, tables, footnotes (commentary excluded)
- **Total independently checkable numeric records:** 57
- **Verified:** 56
- **Verify source:** 1

Counts by top-level section

Top-level section	Records
601	1
602	44
603	12

Appended-table coverage

Appended table	Records	Verify source records
Table 601	1	1

Coverage cross-check against SBC 201 Chapter 6 Types of Construction (2024)_CS.md was topics-only: Type I–V menu; Table 601 vs Table 705.5; Type IV encapsulation and high-rise enclosure split; 603 combustibles in Types I and II. No CS.md value was copied into a matrix cell. Commentary figures and bibliography edition years were not inventoried.

Type III **2-hour** FRTW exterior walls (602.3), Type IV-HT numeric limits (602.4.4 through 602.4.4.4) and 603.1 Item 1.4 **three-storey** FRTW balconies are included in the inventory counts and omitted from project-use as not typical for the R-2 high-rise shaft.

11. Unresolved-source register

Hold points for the 1 **Verify source** inventory record. Item 19 heavy timber is charged in project-use as External verification because it depends on the same flattened Note c. No value in this register is a design-release figure.

Affected table / clause	Why unverified	Control note
Table 601 entire grid and notes a–g	Table HTML is concatenated (TYPE VABABABABABCHT plus run-on primary-frame cells). Hourly ratings and footnote text are not recoverable. Commentary IA 3 h / IB 2 h / IIA 1 h / IIB 0 h and Note b 6 m roof relief are not adopted	Verify the published Table 601 before issuing any construction-type hourly rating. Exterior walls still also vs Table 705.5
603.1 Item 19 / Table 601 Note c	Item 19 permits heavy timber as allowed by Note c; Note c is not present as readable table text	Do not substitute heavy timber for a 1-hour-or-less roof until published Note c is checked. 602.4.4.4 and 705.2.3.1 remain outbound
602.4.2.1 heading	Page split prints Exterior protection. without the subsection number; running text is complete and values are Verified	Cite as 602.4.2.1 by parallel numbering with 602.4.1.1 and 602.4.2.2; no numeric hold