

SBC 201 Chapter 8 Interior Finishes — Group R-2 High-Rise Dimensional Requirements Matrix (2024)

1. Document metadata and use limitation

- **Project basis:** Riyadh, Saudi Arabia; Group R-2 residential high-rise; an occupied floor is stated to be more than 23 m above the relevant reference level.
- **Deliverable tier:** Project-use matrices in Sections 4–12 (design-check rows, not pasted inventory), plus a coverage summary and unresolved-source register. The full row inventory is not published.
- **Code/source basis:** SBC 201 (2024), Chapter 8, source file Reference\SBC 201 2024\source_reference\Chapter_08 – INTERIOR FINISHES.txt.
- **Extraction audit:** Skill extract. Project-use rows follow the chapter-extract row contract (noun-phrase checks, bold SI values, building-language triggers, named exceptions, check-specific actions). Internal inventory: **120** independently checkable numeric records (**48** Verified, **72** Verify source). Flattened Table 803.13 non-R-2 cells are listed in the register and are not design-release values.
- **Model:** Cursor Grok 4.6.
- **Prepared:** 2026-08-27.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped compliance statement, fire-engineering report, interior-finish specification, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Outbound-source rule:** No value in this matrix has been imported from Chapter 7, Chapter 9, Chapter 16 Section 1612, Chapter 26 (including 2603.9 / 2603.10 / 2604.2 numeric trim and thermal-barrier limits), Section 718, Section 720, Section 410, Section 602.4, Section 2304.11, SBC 801 Sections 807.5.1–807.5.6, ASCE 24, commentary examples, Figure page-0824 10-percent area calculations, or an existing chapter summary. Where Chapter 8 sends the user elsewhere, this matrix records the dependency without supplying the outbound value.

Scope and assumptions

1. Group R-2 and high-rise status are project statements, not independently verified classifications.
2. The exact Riyadh AHJ/permit pathway, project stage, fire-strategy status and SCD NOC status are unconfirmed; therefore this matrix does not conclude compliance.
3. Automatic sprinkler protection is not selected. Table 803.13, 803.5.2, 803.15.2 Exception 1 and 804.4.2 branch on Section **903.3.1.1** or **903.3.1.2**. Both branches are shown; NFPA 13 versus 13R is not assumed.
4. Construction type is unconfirmed. High-rise R-2 is typically Type I or II, which turns on Section 805 combustible-floor rules, but Type I/II is not verified here.
5. Mixed-use podium, amenity assembly, dormitory sleeping-unit program and flood-hazard designation are unconfirmed. Group A finish rows, 806.2 Exception 1 (**75 percent**) and 806.6 pyroxilin are omitted until the gap register opens those uses.
6. Table 803.13 is flattened HTML. Only the R-2 six-letter run (R-2CCCBBC delimited by R-3) is adopted in project-use. Other occupancy class cells were inventoried as **Verify source** and are not published.
7. Foam plastic as finish or trim is charged to Chapter 26. Commentary millimetre, density and coverage figures for 2604.2 are not adopted.
8. Interior-finish listings, NFPA/ASTM/UL reports and SCD acceptance of decorative fabrics cannot be concluded from this chapter extract alone.

2. Legends

Applicability

Status	Meaning
Direct	Expected to govern the stated R-2 tower basis, subject to confirmed geometry and design data.
Conditional	Governs only when the stated feature, finish product, sprinkler branch, construction type or exception exists.
Not typical	Unrelated occupancy-only rule; omitted from this deliverable unless the gap register already opened that use.
External verification	Chapter 8 points to another section/code/standard, or the project/AHJ basis must be confirmed before use.

Source confidence

Status	Meaning
Verified	Requirement and any stated numeric value were checked against unambiguous mandatory Chapter 8 source text or an occupancy-delimited table run.
Verify source	OCR, flattened table, page-split, or footnote attachment is unresolved. Not a design-release value.

3. Project decision and gap register

Decision / gap	Current project basis	Why it controls Chapter 8 application	Required project action
Sprinkler standard	Unconfirmed; high-rise typically sprinklered, NFPA 13 vs 13R not locked	Table 803.13 note I, 803.5.2, 803.15.2 Exception 1 and 804.4.2 Exception all cite 903.3.1.1 or 903.3.1.2 . Sprinklered R-2 wall/ceiling classes are C/C/C ; nonsprinklered are B/B/C . Sprinklered R-2 egress floors may drop from Class II to the pill test / ASTM D2859	Freeze the building sprinkler standard on the code data sheet before issuing the finish schedule
Construction type	Unconfirmed; high-rise R-2 typically Type I or II	805 applies only to combustible materials on or embedded in Type I or II floors. 803.15.2.1 FRTW hangers are Type III and V only	Freeze type of construction before detailing sleeper floors, dropped ceilings and combustible insulating boards
Finish product mix	Unconfirmed: paint/wallpaper vs textile/vinyl vs HDPE/PP vs stretch vs foam vs wood veneer	Selects 803.2 thin exemption, 803.5–803.8 textile/vinyl tests, 803.9 room-corner-only plastics, 803.10 stretch Class A, 803.11–803.12 laminated/veneer mounting, or Chapter 26 foam	Issue a finish schedule by room type (unit, corridor, exit stair, lobby, amenity) naming the product class and test path
Floor covering type	Unconfirmed: carpet vs traditional wood/vinyl/linoleum/terrazzo	804 excepts traditional non-fibre finishes; carpet and textile floors in exits, corridors and spaces open to corridors take Class II (R-2) unless the sprinkler exception applies	Mark every egress floor finish as traditional (804.1 Exception) or tested covering (804.4)
Dormitory vs apartment	Unconfirmed apartment tower; dormitory not assumed	806.2 Exception 2 allows 50 percent decorative fabric in Group R-2 dormitory units when sprinklered per 903.3.1 . That exception is not applied to ordinary apartments	Confirm whether any floor is a dormitory; do not use the 50-percent dormitory limit on apartment units
Amenity assembly / podium mix	Unconfirmed	Would open Table 803.13 Group A rows, 806.2 Exception 1 (75 percent in sprinklered auditoriums) and 806.6 pyroxilin prohibition	If a cinema, banquet or assembly amenity is added, re-filter Chapter 8 for that occupancy; do not use those rows on dwelling floors
Foam plastic	Unconfirmed in interior finish, trim or lockers	802.7 / 803.4 ban foam as interior finish except Chapter 26 paths; 806.5 sends foam trim to 2604.2 with no millimetre values in this chapter	Identify every foam finish, trim and panel; send the package to Chapter 26. Do not copy commentary 2604.2 sizes into this matrix

Decision / gap	Current project basis	Why it controls Chapter 8 application	Required project action
Flood hazard	Unconfirmed	802.4 requires flood-damage-resistant finishes below the 1612 elevation	Civil/flood consultant to confirm 1612 designation before specifying below-datum interiors
Heavy timber / exposed structure	Unconfirmed	803.3 exempts exposed heavy timber from interior-finish testing except in interior exit stairways, ramps and exit passageways	Do not treat exposed CLT/heavy timber in exit enclosures as exempt
NOC and fire strategy	SCD NOC and stamped fire-strategy status unconfirmed	Finish listings, corridor Class II floors and decorative-fabric quantities cannot be concluded from Chapter 8 alone	Engage the fire/code consultant before freezing the interior-finish specification

4. Scope, application and foam plastics

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
801.1	Chapter interior-finish scope	This chapter governs materials used as interior finishes, trim and decorative materials	Interior finishes, trim and decorative materials	None stated	Direct	Treat Chapter 8 as the finish/trim/decorative fire-performance chapter, not the compartmentation or egress-width chapter	Verified
802.1	Wall and ceiling charging	Section 803 limits allowable fire performance and smoke development of interior wall and ceiling finish materials based on occupancy classification	Interior wall and ceiling finishes	Materials with different tests in 803.2 through 803.15	Direct	Send every wall and ceiling finish to Section 803 and Table 803.13 for this occupancy	Verified
802.2	Floor-finish charging	Section 804 limits allowable fire performance of interior floor finish materials based on occupancy classification	Interior floor finishes	Traditional non-fibre floor finishes excepted in 804.1	Direct	Send carpet and other regulated floor coverings to Section 804	Verified
802.3	Decorative and trim charging	Decorative materials and trim shall be restricted by combustibility, fire performance or flame-propagation criteria in accordance with Section 806	Decorative materials and trim	Movable walls, paneling, wall pads and crash pads are interior finish under 806.2, not decorative materials	Direct	Separate decorative fabrics from wall-finish products on the specification	Verified
802.4	Flood-resistant interior finishes	In flood hazard areas, interior finishes, trim and decorative materials below the elevation required by Section 1612 shall be flood-damage-resistant materials	Flood hazard areas; finishes below the 1612 elevation	Elevation values are in 1612 / ASCE 24, not this chapter	External verification	Confirm 1612 flood designation; do not import the elevation from this matrix	Verified
802.5	Combustible finish permitted	Combustible materials shall be permitted as finish for walls, ceilings, floors and other interior surfaces	Interior surfaces of buildings	Fire performance still limited by 803 / 804 / 806; construction-type combustibility limits remain in Chapter 6	Direct	Do not reject a combustible finish solely because the tower is noncombustible construction; still meet flame-spread and floor-flux limits	Verified
802.6	First-story show windows	Show windows in the exterior walls of the first story above grade plane shall be permitted to be of wood or of unprotected metal framing	Exterior-wall show windows on the first story above grade plane	Limited to that story; not a general interior-finish exemption for upper floors	Conditional	Use only for ground-level display windows; do not extend wood/unprotected metal show-window framing up the tower shaft	Verified
802.7	Foam plastic finish and trim ban	Foam plastics shall not be used as interior finish except as provided in Section 803.4 . Foam plastics shall not be used as interior trim except as provided in Section 806.5 or 2604.2 . Applies to exposed foam plastics and to foam plastics used with a textile or vinyl facing or cover	Foam plastic used as interior finish or trim	803.4 sends finish to 2603.9 ; 806.5 sends trim to 2604.2 . Do not import Chapter 26 thicknesses, densities or coverage limits	Conditional	Flag every foam finish or trim on the specification and route it through Chapter 26; do not treat vinyl-faced foam as ordinary wall covering	Verified
803.4	Foam plastic Chapter 26 path	Foam plastics shall not be used as interior finish except as provided in Section 2603.9 . Applies to exposed foam and to foam with a textile or vinyl facing or cover	Foam plastic proposed as interior finish	Special-approval values are in Chapter 26, not here	External verification	Require a Chapter 26 foam-plastic submittal; do not copy thermal-barrier millimetres from commentary	Verified

5. Wall and ceiling classification methods

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
803.1	Dual test-path classification	Interior wall and ceiling finish materials shall be classified for fire performance and smoke development in accordance with 803.1.1 or 803.1.2, except as shown in 803.2 through 803.15. Materials tested to 803.1.1 shall not be required to be tested to 803.1.2	Interior wall and ceiling finishes	Thin materials, heavy timber, foam, textiles, vinyl, HDPE/PP, stretch systems, laminates and site-applied veneers have their own sections	Direct	Name the test path (NFPA 286 or ASTM E84 / UL 723) on every finish submittal	Verified
803.1.1	NFPA 286 Class A equivalence	Interior wall and ceiling finish materials classified in accordance with NFPA 286 and complying with 803.1.1.1 shall be considered to also comply with the requirements of a Class A	Wall/ceiling finish using the room-corner path	Materials tested to 803.1.1 need not also take ASTM E84 / UL 723	Direct	Accept a passing NFPA 286 report as Class A for Table 803.13 locations that require Class A, B or C	Verified
803.1.1.1	NFPA 286 acceptance criteria	During the 40-kW exposure, flames shall not spread to the ceiling; flame shall not spread to the outer extremity of the sample on any wall or ceiling; flashover as defined in NFPA 286 shall not occur; peak heat release rate shall not exceed 800 kW ; total smoke released shall not exceed 1,000 m²	Interior finish qualified by NFPA 286	All five criteria must be met. Commentary burner durations are not adopted	Direct	Reject NFPA 286 reports that omit peak HRR or total smoke; do not invent 5-minute / 160 kW protocol figures from commentary	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
803.1.2	ASTM E84 / UL 723 classes	Class A: flame spread index 0–25 , smoke-developed index 0–450 . Class B: flame spread index 26–75 , smoke-developed index 0–450 . Class C: flame spread index 76–200 , smoke-developed index 0–450	Interior finish classified by ASTM E84 or UL 723	Exception: materials tested to 803.1.1 and as indicated in 803.1.3 through 803.13	Direct	Put the Class A/B/C letter on the finish schedule; a better class may substitute for a lesser required class	Verified
803.13	NFPA 286 where Class A required	Interior finish materials tested in accordance with NFPA 286 and meeting 803.1.1.1 shall be permitted where a Class A classification in accordance with ASTM E84 or UL 723 is required	Locations where Table 803.13 requires Class A	Does not waive mounting or product-specific tests in 803.5 through 803.12	Conditional	Use this substitution on nonsprinklered R-2 exits and corridors (Class B required) only when a Class A / NFPA 286 product is specified	Verified

6. Group R-2 wall and ceiling finish classes

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
Table 803.13	R-2 sprinklered finish classes	Sprinklered throughout per 903.3.1.1 or 903.3.1.2 (note l): interior exit stairways/ramps and exit passageways Class C ; corridors and exit-access stair/ramp enclosures Class C ; rooms and enclosed spaces Class C	Group R-2 building sprinklered throughout per note l	Note a Class C wainscot in the grade lobby; note k other code sections; NFPA 286 meeting 803.1.1.1 may be used where Class A is required. Note b (less than three stories) is not a high-rise path	Direct	If NFPA 13 or 13R is locked, specify minimum Class C wall/ceiling finish in exits, corridors and rooms; still apply textile/vinyl/foam product rules	Verified
Table 803.13	R-2 nonsprinklered finish classes	Without that sprinkler protection: interior exit stairways/ramps and exit passageways Class B ; corridors and enclosures for exit access stairways/ramps Class B ; rooms and enclosed spaces Class C	Group R-2 not sprinklered throughout per note l	Same notes as the sprinklered row. Do not assume a high-rise may be nonsprinklered; this is the Chapter 8 branch only	Conditional	Until the sprinkler standard is locked, hold exit and corridor finishes at Class B (or Class A / NFPA 286)	Verified
Table 803.13 note a	Grade-lobby Class C wainscot	Class C interior finish materials shall be permitted for wainscotting or paneling of not more than 93 m² of applied surface area in the grade lobby where applied directly to a noncombustible base or over furnishing strips applied to a noncombustible base and fireblocked as required by Section 803.15.1	Grade lobby wainscot/paneling using this note	Applies to the exit/lobby Class row, not as a general room-finish reduction	Conditional	If Class C wainscot is used in the tower lobby, limit applied area to 93 m² and show direct/noncombustible backing and 803.15.1 fireblocking	Verified
Table 803.13 note c	Room versus corridor enclosure	Requirements for rooms and enclosed spaces shall be based upon spaces enclosed by partitions. Where a fire-resistance rating is required for structural elements, the enclosing partitions shall extend from the floor to the ceiling. Partitions that do not comply shall be considered as not enclosing spaces and the rooms or spaces on both sides shall be considered one. The specific occupancy of the space governs, regardless of the group classification of the building	Rooms, lobbies and spaces open to corridors	Waiting or lounge areas not separated from a corridor take the corridor finish class	Direct	Treat open residential lounges and lift lobbies open to the corridor as corridor finish, not room Class C	Verified
Table 803.13 note k	Other-section finish materials	Finish materials as provided for in other sections of this code	Finish materials with a more specific charging section	Does not import those other sections' values	External verification	Where Chapter 8 points to another section (foam, textiles, floors), use that section's test path rather than Table 803.13 alone	Verified

7. Material-specific wall and ceiling tests

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
803.2	Thin-material test exemption	Materials having a thickness less than 0.9 mm applied directly to the surface of walls or ceilings shall not be required to be tested	Wallpaper and similar thin finishes applied directly to the wall or ceiling	Not a textile/vinyl covering path; not foam	Conditional	Exempt only documented < 0.9 mm direct-applied films; send carpet-like or vinyl wallcoverings to 803.5–803.8	Verified
803.3	Heavy-timber finish exemption	Exposed portions of building elements complying with heavy timber construction in Section 602.4 or 2304.11 shall not be subject to interior finish requirements except in interior exit stairways, interior exit ramps, and exit passageways	Exposed heavy-timber elements	Exit stairs, ramps and passageways still take Table 803.13. 602.4 / 2304.11 values are not imported	Conditional	If heavy timber is exposed in an exit enclosure, specify a tested interior finish or a complying timber species listing for that enclosure	Verified
803.5	Textile wall-covering tests	Textile wall coverings, including woven or nonwoven, napped, tufted, looped or similar surface and carpet and similar textile materials, shall be tested in the manner intended for use, using the product mounting system including adhesive, and shall comply with 803.1.1, 803.5.1 or 803.5.2	Textile materials used as interior wall finish	Three alternative paths; mounting and adhesive are part of the tested system	Conditional	Require the tested adhesive/mounting on the wallcovering specification; do not accept an ASTM E84 Class B textile wallcovering	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
803.5.1–803.5.1.1	NFPA 265 Method B criteria	Method B of NFPA 265, tested with the intended mounting and adhesive: during the 40-kW exposure flames shall not spread to the ceiling; flame shall not spread to the outer extremities of the 2400 mm by 3600 mm walls; flashover as defined in NFPA 265 shall not occur; total smoke released shall not exceed 1,000 m²	Textile or expanded vinyl wall coverings using the NFPA 265 path	NFPA 265 is a wall test; ceiling coverings cannot use 803.5.1 (see 803.6 / 803.8)	Conditional	Accept Method B reports only; check the 2400 × 3600 mm extremity and 1,000 m² smoke results. Do not use NFPA 265 for ceiling carpet	Verified
803.5.2	Class A textile or vinyl plus sprinklers	Textile wall and ceiling coverings and expanded vinyl wall and ceiling coverings shall have a Class A flame spread index in accordance with ASTM E84 or UL 723 and be protected by an automatic sprinkler system installed in accordance with Section 903.3.1.1 or 903.3.1.2 . Specimen preparation and mounting shall be in accordance with ASTM E2404	Textile or expanded vinyl wall or ceiling coverings using the Steiner-tunnel path	Both Class A and sprinklers are required; tunnel test alone is not sufficient	Conditional	If carpet or vinyl is used on corridor/unit walls or ceilings, require Class A with ASTM E2404 mounting and confirm 13 or 13R throughout	Verified
803.6 / 803.8	Textile or vinyl ceiling tests	Textile ceiling coverings and expanded vinyl ceiling coverings shall be tested in the manner intended for use, using the product mounting system including adhesive, and shall comply with 803.1.1 or 803.5.2	Textile or expanded vinyl used as ceiling finish	NFPA 265 / 803.5.1 is not an option for ceilings	Conditional	For ceiling carpet or vinyl, require NFPA 286 or Class A plus sprinklers; do not cite NFPA 265	Verified
803.7	Expanded vinyl wall tests	Expanded vinyl wall coverings shall be tested in the manner intended for use, using the product mounting system including adhesive, and shall comply with 803.1.1, 803.5.1 or 803.5.2	Expanded vinyl used as interior wall finish	Same three paths as textile walls	Conditional	Treat expanded vinyl wallcovering as a textile-equivalent product on the finish schedule	Verified
803.9	HDPE and polypropylene finish	HDPE or polypropylene used as interior finish shall comply with Section 803.1.1 (NFPA 286)	HDPE or PP used as interior finish	ASTM E84 / UL 723 Class A/B/C is not the charging test for these plastics	Conditional	Require an NFPA 286 (803.1.1.1) report for any HDPE/PP wall or ceiling lining; do not accept a tunnel-test letter	Verified
803.10	Site-fabricated stretch systems	Site-fabricated stretch systems containing all three components described in the Chapter 2 definition shall be tested in the manner intended for use and shall comply with 803.1.1 or with Class A in accordance with 803.1.2. If tested to ASTM E84 or UL 723, specimen preparation and mounting shall be in accordance with ASTM E2573	Stretch-fabric wall or ceiling systems (fabric/vinyl + frame + infill)	Class B or C tunnel results are not sufficient on this path	Conditional	If a stretch ceiling is specified in a lobby or amenity, require NFPA 286 or Class A with ASTM E2573 mounting	Verified
803.11	Factory-laminated wood-substrate products	Laminated products factory produced with a wood substrate shall comply with either: NFPA 286 using the product-mounting system including adhesive as described in Section 5.8 of NFPA 286 and meeting 803.1.1; or Class A, B or C flame spread and smoke-developed index based on Table 803.13, tested to ASTM E84 or UL 723 with specimen preparation and mounting in accordance with ASTM E2579	Factory-laminated wood-substrate wall/ceiling panels	Class letter still taken from Table 803.13 for this occupancy	Conditional	Require ASTM E2579 mounting on factory-laminated panels; match the Class letter to the sprinklered or nonsprinklered R-2 row	Verified
803.12	Site-applied facing or wood veneer	Facings or veneers intended to be applied on site over a wood substrate shall comply with either: 803.1.1.1 when tested to NFPA 286 using the product mounting system including adhesive as described in Section 5.9 of NFPA 286; or Class A, B or C based on Table 803.13, ASTM E84 or UL 723, specimen preparation and mounting in accordance with ASTM E2404	Site-applied facing or wood veneer over a wood substrate	Different mounting standard from factory laminates (E2404 vs E2579)	Conditional	If wood veneer is applied on site, require ASTM E2404 tunnel mounting or NFPA 286 Section 5.9; do not reuse a factory-laminate report	Verified

8. Finish attachment, furring and thin materials

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
803.14	Interior-finish high-temperature stability	Interior finish materials regulated by this chapter shall be applied or otherwise fastened so that such materials will not readily become detached where subjected to room temperatures of 93°C for not less than 30 minutes	Interior finish materials regulated by Chapter 8	No standard test method is named in this section	Direct	Specify mechanical fastening or listed adhesives that remain attached at the stated exposure; do not rely on thermoplastic-only adhesion in exits	Verified
803.15.1	Direct or shallow furring	Apply interior finish directly against the rated or noncombustible construction, or to furring strips not exceeding 44 mm applied directly against those surfaces	Finish on fire-resistance-rated or noncombustible walls, ceilings or structural elements	Deeper set-out or dropped ceilings: 803.15.2	Direct	Limit furring depth behind interior finish on shaft, stair and corridor-rated walls to 44 mm , or follow 803.15.2	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
803.15.1.1	Furred-cavity protection	If the interior finish is applied to furring strips, intervening spaces shall be filled with inorganic or noncombustible material; or filled with Class A material in accordance with 803.1.1 or 803.1.2; or fire-blocked at a maximum of 2.4 m in every direction in accordance with Section 718	Finish on furring strips under 803.15.1	Exception: Item 1, 2 or 3 is not required where the materials used to create the concealed space are noncombustible. Section 718 numeric limits are not imported	Direct	Fill, use Class A infill, or fireblock the furring cavity at 2.4 m each way; do not copy 718 areas from commentary	Verified
803.15.2	Set-out or dropped-ceiling Class A	Set-out walls or dropped ceilings deeper than 803.15.1 shall use Class A finish materials in accordance with 803.1.1 or 803.1.2	Set-out walls or dropped ceilings deeper than the 44 mm furring limit	Exception 1: interior finish protected on both sides by an automatic sprinkler system per 903.3.1.1 or 903.3.1.2 . Exception 2: attached to noncombustible backing or furring strips installed as 803.15.1.1. Exception 3: combustible void filled with a noncombustible material	Conditional	For a corridor or lobby bulkhead deeper than 44 mm , specify Class A finish or document a numbered exception (sprinklers both sides, noncombustible backing, or filled void)	Verified
803.15.2.1	Dropped-ceiling hangers	Hangers and assembly members of dropped ceilings below horizontal fire-resistance-rated floor or roof assemblies shall be of noncombustible materials. Each set-out wall and the horizontal fire-resistance-rated floor or roof assembly shall be of fire-resistance-rated construction as required elsewhere in this code	Dropped ceilings below horizontal fire-resistance-rated assemblies	Exception: in Type III and V construction, fire-retardant-treated wood shall be permitted for hangers and assembly members of dropped ceilings	Direct	Specify steel hangers for tower dropped ceilings; do not use FRTW hangers unless Type III or V is confirmed	Verified
803.15.3	Heavy-timber finish fireblocking	Wall and ceiling finishes of all classes permitted in this chapter that are installed directly against the wood decking or planking of heavy timber construction in Section 602.4.4.2 or 2304.11 , or to wood furring strips applied directly to that decking or planking, shall be fireblocked as specified in 803.15.1.1	Finish installed on heavy-timber decks or on furring applied to those decks	602.4 / 2304.11 values not imported	Conditional	If heavy timber is used, show 803.15.1.1 fireblocking at timber-to-finish cavities	Verified
803.15.4	Thin combustible finish attachment	An interior wall or ceiling finish material that is not more than 6.5 mm thick shall be applied directly onto the wall, ceiling or structural element without furring strips and shall not be suspended away from the building element to which it is applied	Combustible interior finish $\leq$ 6.5 mm thick	Exception 1: noncombustible interior finish materials. Exception 2: Class A materials tested furred out from noncombustible backing may be used with furring strips. Exception 3: Class A materials tested suspended away from noncombustible backing may be used suspended	Conditional	Direct-stick thin combustible panels; furr or suspend them only with a matching Class A tested assembly	Verified

9. Interior floor finish

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
804.1	Floor-finish charging and traditional exception	Interior floor finish and floor covering materials shall comply with 804.2 through 804.4.2	Interior floor finish and floor covering	Exception: traditional types such as wood, vinyl, linoleum or terrazzo, and resilient floor covering materials that are not comprised of fibres	Direct	Exempt documented wood, vinyl, linoleum, terrazzo and non-fibre resilient floors from 804; send carpet and textile floors through 804.2–804.4.2	Verified
804.2	Floor Class I and Class II flux	Interior floor finish and floor covering materials required by 804.4.2 to be Class I or II shall be classified in accordance with ASTM E648 or NFPA 253. Class I: 0.45 watts/cm² or greater. Class II: 0.22 watts/cm² or greater	Floors that 804.4.2 requires to be Class I or II	Classification is the critical radiant flux from those tests	Direct	Put Class I / II (or the critical radiant flux) on carpet submittals for egress floors	Verified
804.3	Floor testing and identification	Interior floor finish and floor covering materials shall be tested by an agency in accordance with ASTM E648 or NFPA 253 and identified by a hang tag or other suitable method so as to identify the manufacturer or supplier and style, and shall indicate the classification in accordance with 804.2. Carpet-type floor coverings shall be tested as proposed for use, including underlayment. Test reports shall be furnished to the building official upon request	Class I or II floor coverings	Carpet without the proposed underlayment is not the tested system	Direct	Require hang-tag / style identification and a report that includes the specified underlayment	Verified
804.4.1	Floor covering ignition test	In all occupancies, interior floor covering materials shall comply with ASTM D2859	Interior floor covering materials (all occupancies)	Traditional non-fibre finishes excepted by 804.1. 804.4.2 may still require Class I/II in egress	Direct	Require an ASTM D2859 (pill test) report for every regulated floor covering, including unit carpet if used	Verified
804.4.2	R-2 egress floor Class II	In all occupancies, interior floor finish and floor covering materials in enclosures for stairways and ramps, exit passageways, corridors and rooms or spaces not separated from corridors by partitions extending from the floor to the underside of the ceiling shall withstand a minimum critical radiant flux. The minimum shall be not less than Class II in Groups A, B, E, H, I-4, M, R-1, R-2 and S	Those egress and corridor-open locations in Group R-2	Class I applies to Groups I-1, I-2 and I-3, not this occupancy. Exception: where the building is equipped throughout with an automatic sprinkler system in accordance with 903.3.1.1 or 903.3.1.2 , Class II materials are permitted where Class I is required, and materials complying with DOC FF-1 (CPSC 16 CFR Part 1630) or ASTM D2859 are permitted where Class II is required	Direct	On nonsprinklered drawings, specify Class II carpet in stairs, exit passageways, corridors and spaces open to the corridor. If 13 or 13R is locked throughout, those same locations may use pill-test / ASTM D2859 coverings instead of Class II	Verified

10. Combustible materials in Types I and II floors

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
805.1	Type I/II combustible floor charging	Combustible materials installed on or embedded in floors of buildings of Type I or II construction shall comply with 805.1.1 through 805.1.3	Combustible floor sleepers, finish flooring or insulating boards in Type I or II	Exception: stages and platforms constructed in accordance with 410.2 and 410.3. Chapter 410 values are not imported	Direct	If the tower is Type I or II, run every raised or sleeper floor through 805.1.1–805.1.3	Verified
805.1.1	Combustible sleepers and fireblocking	Combustible sleepers, bucks and nailing blocks are permitted only if the void between the rated floor and the flooring is solidly filled with noncombustible materials or fireblocked per Section 718 , and those open spaces do not extend under or through permanent partitions or walls	Combustible sleepers, bucks or nailing blocks on Type I/II floors	Section 718 numeric limits are not imported. Do not adopt commentary 9.3 m²	Conditional	Fill or fireblock sleeper voids; stop the cavity at every partition. Size 718 fireblocks from Chapter 7, not this matrix	Verified
805.1.2	Wood finish flooring on sleepers	Wood finish flooring is permitted to be attached directly to the embedded or fireblocked wood sleepers and shall be permitted where cemented directly to the top surface of fire-resistance-rated floor assemblies or directly to a wood subfloor attached to sleepers as provided for in 805.1.1	Wood finish flooring in Type I or II	Sleepers must satisfy 805.1.1	Conditional	Direct-stick wood flooring to the rated slab, or to sleepers that are filled or fireblocked per 805.1.1	Verified
805.1.3	Combustible insulating boards	Combustible insulating boards not more than 12.5 mm thick and covered with finish flooring are permitted where attached directly to a noncombustible floor assembly or to wood subflooring attached to sleepers as provided for in 805.1.1	Combustible insulating boards under finish flooring in Type I or II	Thickness cap 12.5 mm ; must be covered with finish flooring	Conditional	Limit underfloor insulating board to 12.5 mm and cover it with the finish floor; attach to the slab or to 805.1.1 sleepers	Verified

11. Decorative materials and trim

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
806.1	General decorative controls	Furnishings or decorative materials of an explosive or highly flammable character shall not be used. Fire-retardant coatings in existing buildings shall be maintained so as to retain the effectiveness of the treatment under service conditions. Furnishings or other objects shall not be placed to obstruct exits, access thereto, egress therefrom or visibility thereof. The permissible amount of decorative vegetation and noncombustible decorative materials shall not be limited	All occupancies	806.2 limits combustible fabrics; occupancy-based extras are in SBC 801 via 806.3	Direct	Keep explosive/highly flammable décor out of the tower; keep furniture out of exit paths; do not limit noncombustible décor or decorative vegetation by the 10-percent rule	Verified
806.2	Combustible decorative fabric area	In other than Group I-3, curtains, draperies, fabric hangings and similar combustible decorative materials suspended from walls or ceilings shall comply with 806.4 and shall not exceed 10 percent of the specific wall or ceiling area to which such materials are attached. Fixed or movable walls and partitions, paneling, wall pads and crash pads applied structurally or for decoration, acoustical correction, surface insulation or other purposes shall be considered interior finish, shall comply with Section 803, and shall not be considered decorative materials or furnishings	Combustible decorative fabrics in R-2 (other than I-3)	Exception 4: the 10 percent limit shall not apply to curtains, draperies, fabric hangings and similar combustible decorative materials used as window coverings. Exception 1 (Group A auditorium 75 percent) and Exception 3 (Group B and M unlimited fabric partitions) are omitted unless mixed use is confirmed. Exception 2 (Group R-2 dormitories 50 percent , sprinklered per 903.3.1) is not applied to apartment units; see the gap register	Direct	Limit hanging combustible décor to 10 percent of the attached wall or ceiling, tested to 806.4. Treat wall pads, paneling and movable partitions as Section 803 finish. Window coverings are not counted in the 10 percent	Verified
806.3	Occupancy-based decorative extras	Occupancy-based requirements for combustible decorative materials, other than decorative vegetation, not complying with 806.4 shall comply with Sections 807.5.1 through 807.5.6 of SBC 801	Decorative materials that do not meet 806.4	SBC 801 values are not imported	External verification	If a fabric does not pass 806.4, do not invent an SBC 801 limit here; check SBC 801 807.5 with the fire consultant	Verified
806.4	Decorative fabric acceptance tests	Approved-agency test: NFPA 701 Test 1 or 2 as appropriate, or maximum heat release rate 100 kW to NFPA 289 using the 20-kW ignition source. Furnish reports to the building official upon request	Combustible decorative fabrics required to show improved fire performance	Commentary NFPA 701 fabric-density figures are not adopted	Direct	Require an NFPA 701 Test 1 or 2 report, or an NFPA 289 report with peak HRR ≤ 100 kW at the 20-kW source, for hanging décor	Verified
806.5	Foam plastic trim	Foam plastic used as trim in any occupancy shall comply with Section 2604.2	Foam plastic used as interior trim	2604.2 thicknesses, widths, densities and coverage percentages are not in this chapter and are not adopted from commentary	External verification	Send foam trim to Chapter 26; do not specify 12.5 mm / 200 mm / 10 percent / 320 kg/m³ from this matrix	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
806.7	Interior trim class and area	Material, other than foam plastic used as interior trim, shall have a minimum Class C flame spread and smoke-developed index when tested in accordance with ASTM E84 or UL 723 as described in 803.1.2. Combustible trim, excluding handrails and guardrails, shall not exceed 10 percent of the specific wall or ceiling area to which it is attached	Interior trim other than foam plastic	Handrails and guardrails excluded from the 10 percent . Foam trim is 806.5 / 2604.2	Direct	Specify minimum Class C millwork/trim and keep combustible trim (other than handrails and guards) within 10 percent of the attached wall or ceiling	Verified
806.8	Floor-wall base class	Interior floor-wall base that is 150 mm or less in height shall be tested in accordance with 804.2 and shall be not less than Class II. Where a Class I floor finish is required, the floor-wall base shall be Class I	Floor-wall base ≤ 150 mm high	Exception: interior trim materials that comply with 806.7. R-2 egress floors require Class II (804.4.2), so the matching base is Class II unless the sprinkler exception to 804.4.2 applies	Direct	Specify Class II (ASTM E648 / NFPA 253) cove base up to 150 mm in stairs, corridors and spaces open to corridors, or use 806.7 trim. Taller bases are not this section	Verified
806.9	Combustible lockers	Combustible lockers shall be considered interior finish and shall comply with Section 803	Combustible lockers	Exception: lockers constructed entirely of wood and noncombustible materials shall be permitted wherever interior finish materials are required to meet a Class C classification in accordance with 803.1.2	Conditional	If amenity or staff lockers are combustible, treat them as wall/ceiling finish under Table 803.13. All-wood/noncombustible lockers may be used where Class C is required	Verified

12. Insulation and acoustical ceiling systems

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	R-2 tower status	Design action	Source confidence
807.1	Thermal and acoustical insulation	Thermal and acoustical insulation shall comply with Section 720	Thermal or acoustical insulation	Section 720 values are not imported	External verification	Specify insulation to Section 720; do not copy concealed-insulation flame-spread limits from this chapter	Verified
808.1	Acoustical ceiling system charging	Metal suspension systems for acoustical tile and lay-in panel ceilings shall conform to generally accepted engineering practice, this chapter and other applicable code requirements	Metal-suspended acoustical tile or lay-in panel ceilings	None stated	Direct	Treat the grid, hangers and tiles as a Chapter 8 ceiling system, not as unregulated décor	Verified
808.1.1	Acoustical tile interior-finish class	Acoustical materials complying with the interior finish requirements of Section 803 shall be installed in accordance with the manufacturer's recommendations and applicable provisions for applying interior finish	Acoustical tiles and lay-in panels	Class letter from Table 803.13 for R-2	Direct	Put the Table 803.13 Class C (sprinklered) or room/corridor/exit class on the ceiling-tile specification	Verified
808.1.1.1	Suspended-ceiling installation standards	Suspended acoustical ceiling systems shall be installed in accordance with ASTM C635 and ASTM C636	Suspended acoustical ceilings	Fire-resistance-rated assemblies: also 808.1.1.2	Direct	Name ASTM C635 / C636 on the reflected-ceiling specification and shop drawings	Verified
808.1.1.2	Fire-resistance-rated ceiling installation	Acoustical ceiling systems that are part of fire-resistance-rated construction shall be installed in the same manner used in the assembly tested and shall comply with the provisions of Chapter 7	Acoustical ceilings that are part of a fire-resistance-rated assembly	Chapter 7 ratings and tested-assembly details are not imported	External verification	Match the listed floor/ceiling or roof/ceiling assembly; take fire-resistance details from Chapter 7, not from this matrix	Verified

13. Project-use controls

1. Use **Verified** rows for initial finish-schedule scoping after the row trigger is confirmed (product class, sprinkler branch, construction type, or location).
2. **Verify source** in this extract is the unpublished remainder of flattened Table 803.13 (non-R-2 occupancy cells). Do not adopt those cells as design-release values. The R-2 six-letter run used in Section 6 is **Verified**.
3. Do not import Chapter 26 foam-trim millimetres, Section 718 concealed-space areas, Section 720 insulation indices, Section 1612 flood elevations, Chapter 7 ratings, or SBC 801 807.5 decorative limits from this matrix.
4. Show both sprinkler branches until NFPA 13 or 13R is locked. Do not assume 13R is acceptable for a high-rise from this chapter.
5. Do not apply Group A auditorium **75 percent**, Group R-2 dormitory **50 percent**, Group B/M unlimited fabric partitions, or pyroxilin (Group A) rules to apartment floors unless the gap register is updated.
6. Record finish-class, floor-flux and decorative-fabric decisions in the project Golden Thread; this matrix is not evidence of SCD NOC or stamped compliance.

14. Coverage summary

Internal inventory of the attached Chapter 8 extract (numbered code, exceptions, tables, footnotes; commentary excluded). Row-level records are not published.

- **Inventory scope:** numbered code, exceptions, tables, footnotes (commentary excluded)
- **Total independently checkable numeric records:** 120
- **Verified:** 48
- **Verify source:** 72

Counts by top-level section

Top-level section	Records
801	0
802	1

Top-level section	Records
803	109
804	2
805	1
806	7
807	0
808	0

Section 803 includes Table 803.13 class cells (6 R-2 Verified; 72 other-occupancy cells Verify source) and six numeric footnotes. No Chapter 8 *_CS.md is present in this repo; coverage was not cross-checked against a CS.md.

15. Unresolved-source register

Affected table / clause	Why unverified	Control note
Table 803.13 (non-R-2 occupancy cells)	Flattened HTML concatenates occupancy labels and Class A/B/C letters; other occupancy rows were not adopted and were not reconstructed from memory	Project-use uses only the occupancy-delimited R-2 run R-2CCCBBC (sprinklered C/C/C , nonsprinklered B/B/C). Footnote running text for notes a and l is readable and was used. Note l is labeled 1 . in the extract
Commentary / figure numbers	Not code	NFPA 286 5 min / 160 kW / 10 min protocol, NFPA 701 700 g/m² , 2604.2 commentary 12.5 mm / 200 mm / 10 percent / 320 kg/m³ , 718 commentary 9.3 m² , gypsum 12.5 mm thermal barrier, and page-0824 10-percent area examples were excluded