

ICC A117.1 Chapter 11 Dwelling Units and Sleeping Units — Accessible Dimensional Requirements Matrix (2017)

1. Document metadata and use limitation

- **Project basis:** Mixed-use tall building containing Group R-1 (hotel) with Group R-2 residential sharing podium, parking and routes. An occupied floor is stated to be more than 23 m above the relevant reference level. This matrix filters ICC A117.1 Chapter 11 for **Accessible units** (Section 1102).
- **Unit type:** Accessible (1102). Type A, Type B and Type C interiors are omitted from this file.
- **Deliverable tier:** Project-use matrices in Sections 4–14 (design-check rows, not pasted inventory), plus project-use controls, a coverage summary and an unresolved-source register. The full row inventory is not published.
- **Code/source basis:** ICC A117.1 (2017), Chapter 11, source file Reference\2017 ICC A117_1 Accessible and Usable Buildings and Facilities\source_reference\Chapter_11 – DWELLING UNITS AND SLEEPING UNITS.txt. Companion numbers inlined from the attached 2017 Chapter 1–10 source_reference extracts where 1102 charges those sections.
- **Extraction audit:** Internal inventory: **241** independently checkable numeric records (**218** Verified, **23** Verify source). Unresolved OCR/flattened tables are listed in the register and are not design-release values.
- **Inspecting model:** Cursor Grok 4.6.
- **Prepared:** 2026-08-28.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped compliance statement, accessibility consultant report, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Scoping companion:** Counts, which units, and where Accessible units are required are **SBC 201 Chapter 11**. This file is technical geometry only.
- **Edition gap:** SBC 201 Chapter 35 lists **ICC A117.1—09**. Charging SBC 1102.1 has no year. This extract is **2017**. 2017 new-building clear floor space, turning space and door manoeuvre are larger than 2009. **Do not treat 2017 millimetres as the legal SBC minimum**. Do not back-fill 2009 values from memory.

Scope and assumptions

1. Group R-1 hotel Accessible guestrooms are the Direct typical. R-2 Accessible units, if provided, use the same 1102 technical set.
2. New construction is assumed. Existing-building dimensions are Conditional and are never mixed onto a Direct row with the 2017 new-building option set.
3. AHJ, SCD NOC, guestroom count and kitchenette provision are unconfirmed.
4. Type C (1105) is omitted. Communication features (1106) are a Conditional overlay, not a substitute for 1102 mobility geometry.
5. Children’s toilets (604.11), urinals (605), public toilet compartments (604.9–604.10), drinking fountains (602) and recreational facilities (Chapter 10) are omitted unless 1102 names them.
6. FIGURE captions are dependencies, not values. Flattened <table> blobs are not reconstructed as Verified cells.
7. ASME A17.1, BHMA A156, NFPA 72 and AAMA 513 are named companions only; unstated values are not imported.

2. Legends

Applicability

Status	Meaning
Direct	Expected to govern Accessible-unit interiors (and the unit accessible route) once geometry is confirmed.
Conditional	Governs only if the stated feature, existing-building branch, kitchenette, in-unit ramp/lift/elevator, or communication overlay exists.
Not typical	Unrelated unit-type-only rule; omitted unless the gap register already opened that use.
External verification	A figure is missing, a flattened table is unread, or AHJ/edition must be confirmed first.

Source confidence

Status	Meaning
Verified	Unambiguous mandatory source text or readable footnote after a table blob.
Verify source	OCR, flattened table, page-split, or footnote attachment is unresolved. Not a design-release value.

3. Project decision and gap register

Decision / gap	Current project basis	Why it controls Chapter 11 application	Required project action
A117.1 edition lock	Extracted edition is 2017 ; SBC 201 Chapter 35 lists A117.1—09 ; SBC 1102.1 has no year	2017 new CFS is 52 × 30 inches (1320 × 760 mm) ; turning is 67 inches (1700 mm) circular; 2009 used smaller CFS/turning	AHJ/code consultant to lock 2009 vs 2017 before freezing Accessible-guestroom typicals; do not treat this extract as the legal SBC minimum
New vs existing	New construction assumed	403.5, 304.3, 305.3, 404.2.3 footnotes and 608.2.1.2 split new/existing	Hold Direct rows on the new-building option set; use existing rows only on an alteration
Mixed R-1 / R-2	R-1 hotel plus R-2 apartments on one structure	Accessible-unit interiors follow 1102 for both occupancies; Type A/B files cover apartment typicals	Do not draw Type A adaptable baths or Type B 31 3/4 inches (805 mm) doors on Accessible guestrooms
Kitchen / kitchenette	Unconfirmed in hotel rooms	1102.12 charges Section 804 only where a kitchen is provided	Apply Section 8 only to Accessible units that include a kitchen or kitchenette
In-unit ramp / elevator / lift	Not typical in a hotel guestroom	1102.6–1102.8 charge 405 and 407–410 only if those elements exist inside the unit	Confirm duplex/maisonette or private elevator before using Section 12
Communication overlay	Unconfirmed	1106 is a separate unit type overlay, not a mobility substitute	Apply Section 14 only to units also scoped for communication features
AHJ / NOC	Unconfirmed	Stamped compliance, SCD and SBPS cannot be concluded from this extract	Engage the qualified local accessibility consultant before design freeze

4. Unit accessible route, turning and walking surfaces

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1102.2	Primary entrance location	Primary entrance on an accessible route from public and common areas; not to a bedroom unless it is the only entrance	Accessible units	None stated	Direct	Place the Accessible-guestroom entry on the corridor accessible route; do not enter through a bedroom	Verified
1102.3.1	Unit accessible-route extent	At least one accessible route shall connect all spaces and elements that are part of the unit and shall coincide with or be in the same area as the general circulation path	Accessible-unit interiors	Unfinished attics and unfinished basements	Direct	Connect entry, sleeping, living, required bath, kitchenette and balcony on one accessible route	Verified
1102.3.2 / 304.3.1.1	New circular turning space	All rooms served by the accessible route shall provide a circular turning space 67 inches (1700 mm) minimum diameter	Rooms on the Accessible-unit accessible route	Not required in toilets/baths that are not the 1102.11.2 room; not required in closets or pantries 48 inches (1220 mm) maximum depth; existing circular is 60 inches (1525 mm)	Direct	Hold a 1700 mm turning circle in the entry, sleeping room, required bath and living space	Verified
1102.3.2 / 304.3.2.1	New T-shaped turning option set	New T-turn is one of: 68 × 60 inches (1725 × 1525 mm) with arms/base 36 inches (915 mm) and 8-inch (205 mm) chamfers; or 64 × 60 inches (1625 × 1525 mm) with arms 38 inches (965 mm) and base 42 inches (1065 mm) ; or 64 × 60 inches (1625 × 1525 mm) with arms/base 40 inches (1015 mm)	Rooms on the Accessible-unit accessible route where a T-turn is used instead of a circle	Existing T-turn is a 60-inch (1525 mm) square with arms/base 36 inches (915 mm)	Direct	Pick one new T-option on the guestroom typical; do not mix the existing 1525 mm T on a new-build Direct plan	Verified
304.3.1.1.1	Turning-space knee/toe overlap	Circular-turn overlap under an obstruction 10 inches (255 mm) maximum, not exceeding the knee/toe clearance provided, and only in the shaded area of Figure 304.3.1.1	Turning space under a fixture or counter	Figure 304.3.1.1 defines the permitted overlap zone	Direct	Limit lavatory/vanity overlap into the 1700 mm circle to 255 mm	Verified
304.2	Turning-space floor	No change in level in the turning space; slope not steeper than 1:48 permitted	Turning spaces	None stated	Direct	Keep the turning circle on a 1:48 floor; do not drop a threshold through it	Verified
1102.3.3 / 403.3	Walking-surface slope	Accessible-route walking surfaces running slope not steeper than 1:20; cross slope not steeper than 1:48	Accessible-unit walking surfaces	Steeper walking surfaces become ramps (405)	Direct	Hold guestroom floors and balconies at 1:20 / 1:48; treat anything steeper as a ramp	Verified
1102.4 / 403.5.1	Interior accessible-route clear width	Interior accessible route clear width 36 inches (915 mm) minimum; exterior 48 inches (1220 mm) minimum	Accessible-unit accessible routes	New pinch: 32 inches (815 mm) for 24 inches (610 mm) max, separated by 52 × 36 inches (1320 × 915 mm) ; existing pinch uses 48 inches (1220 mm) separators; exterior seating 36 inches (915 mm) ; exterior ramp → 405.5	Direct	Hold interior corridor and unit circulation at 915 mm; document any local pinch	Verified
1102.4 / 403.5.2.1	New 180-degree turn widths	Around an object 52 inches (1320 mm) or wider, 90-degree new options apply. Around a narrower object, one of: approach/leave 36 inches (915 mm) with 60 inches (1525 mm) in the turn; or 42 inches (1065 mm) / 48 inches (1220 mm) / 42 inches (1065 mm) ; or 43 inches (1090 mm) throughout	180-degree turns on the Accessible-unit route	Existing 180° around object < 48 inches (1220 mm) is 42 / 48 / 42 inches (1065 / 1220 / 1065 mm) , waived if the turn is 60 inches (1525 mm)	Direct	Dimension guestroom 180° turns to one new option set; do not use the existing 42/48/42 set on a new Direct plan	Verified
1102.4 / 403.5.3.1	New 90-degree turn widths	One of: both legs 40 inches (1015 mm) held 28 inches (710 mm) from the inner corner; or 8-inch (205 mm) chamfers with both legs 36 inches (915 mm) ; or 42 inches (1065 mm) with the other 38 inches (965 mm) ; or 44 inches (1120 mm) with the other 36 inches (915 mm)	90-degree turns on the Accessible-unit route	Not required at doors complying with 404.2.3 or at elevators/lifts 407–410; existing 90° is 36 inches (915 mm) both legs	Direct	Pick one new 90° option at corridor/unit corners; chamfer or widen rather than using the existing 915 mm both-legs rule	Verified
1102.4 / 403.5.4.1	New passing space	Where clear width is less than 60 inches (1525 mm) , passing spaces at 200 feet (61 m) maximum: 60 × 60 inches (1525 × 1525 mm) or a T-turn per 304.3.2.1 with base/arms extending 52 inches (1320 mm) beyond the intersection	Long Accessible-unit or suite routes under 1525 mm wide	Existing T-arm extension is 48 inches (1220 mm)	Conditional	Add a 1525 mm passing bay on any Accessible suite corridor longer than 61 m that stays under 1525 mm	Verified
1102.4 / 303.2–303.4	Walking-surface change in level	Vertical 1/4 inch (6.4 mm) maximum; 1/4 inch (6.4 mm) to 1/2 inch (13 mm) beveled 1:2; above 1/2 inch (13 mm) by ramp 405 or curb ramp 406	Changes in level on the Accessible-unit route	None stated	Direct	Limit unit floor/balcony joints to 6.4 mm vertical or 13 mm at 1:2	Verified

5. Doors and doorways

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1102.5 / 404.2.2	Passage-door clear opening	Clear opening 32 inches (815 mm) minimum, measured between door face and stop at 90 degrees. Openings more than 24 inches (610 mm) deep without a door: 36 inches (915 mm) minimum. No projections below 34 inches (865 mm) AFF; projections 34–80 inches (865–2030 mm) AFF 4 inches (100 mm) maximum	Primary entrance and all user-passage doors in the Accessible unit	Closers/stops 78 inches (1980 mm) min AFF; alterations latch-stop 5/8 inch (16 mm) max. Hospital existing patient-room latch-side manoeuvre waived if the door is 44 inches (1120 mm) min width	Direct	Specify 815 mm clear (typically a 915 mm leaf); do not use Type B 31 3/4 inches (805 mm)	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1102.5 / Table 404.2.3.2	Swinging-door manoeuvre table	Swinging doors shall have manoeuvring clearances per Table 404.2.3.2 (full opening width plus latch- or hinge-side clearance)	Manual swinging user-passage doors	Flattened <table> blob: no cell adopted . Readable footnotes: add 6 inches (150 mm) if closer+latch (fn 1) or closer (fn 2); add 12 inches (305 mm) beyond latch if closer+latch (fn 3); hinge-side push is beyond hinge (fn 4); existing front-push perpendicular 48 inches (1220 mm) (fn 5). 1102.5 does not require 404.2.3 on the room side of non-required baths, at closet/pantry ≤ 48 inches (1220 mm) deep, or on balcony exteriors smaller than the manoeuvre; 404.2.5 turning between doors in a series is not required	External verification	Hold door manoeuvre off the published table after AHJ source check; apply the readable footnotes now	Verify source
1102.5 / Table 404.2.3.3	Sliding/folding-door manoeuvre table	Sliding and folding doors shall have manoeuvring clearances per Table 404.2.3.3	Sliding/folding user-passage doors	Flattened blob: no cell adopted . Fn 1: nonlatch parallel is beyond pocket or hinge. Recessed-door trigger (404.2.3.5): obstruction within 18 inches (455 mm) of latch projecting more than 8 inches (205 mm) requires forward-approach manoeuvre	External verification	Confirm sliding-door manoeuvre from a readable Table 404.2.3.3; apply the 455/205 mm recess trigger	Verify source
1102.5 / Table 404.2.3.4	Doorway-without-door manoeuvre	Doorways without doors less than 36 inches (915 mm) wide shall have manoeuvre per Table 404.2.3.4	Cased openings under 915 mm	Flattened blob: no cell adopted . Fn 1: existing front perpendicular 48 inches (1220 mm)	External verification	Prefer 915 mm cased openings or confirm table cells from a readable source	Verify source
1102.5 / 404.2.3.1	Manoeuvre floor slope	Floor within manoeuvring clearances slope not steeper than 1:48	Door manoeuvre zones	None stated	Direct	Keep latch-side pads at 1:48	Verified
1102.5 / 404.2.4	Door threshold height	Thresholds 1/2 inch (13 mm) maximum; raised thresholds comply with 302 and 303	Accessible-unit doorways	Existing/alterd threshold 3/4 inch (19 mm) max with 1:2 bevel on each side for height exceeding 1/4 inch (6.4 mm)	Direct	Specify 13 mm max thresholds at entry, bath and balcony doors	Verified
1102.5 / 404.2.5	Doors in series	Distance between hinged or pivoted doors in series 48 inches (1220 mm) minimum plus the width of any door swinging into the space, and a turning space between	Vestibules or bath/entry pairs	1102.5 Exceptions 3–5: turning space between doors in a series is not required in Accessible units; storm/screen doors and communicating doors between sleeping units are exempt from 404.2.5	Conditional	Size any in-unit vestibule to 1220 mm plus leaf swing; the 1102.5 series-turn exemption applies	Verified
1102.5 / 404.2.6	Door hardware force and height	Forward/push/pull hardware 15 pounds (66.7 N) maximum; rotational 28 inch-pounds (315 N-cm) maximum. Operable parts 34 inches (865 mm) minimum and 48 inches (1220 mm) maximum AFF; sliding-door hardware usable from both sides when open	Accessible-unit door hardware	Security-personnel-only doors exempt from listed 404.2/404.3 manoeuvre and hardware clauses	Direct	Schedule lever hardware 865–1220 mm AFF; keep operating force within 66.7 N / 315 N-cm	Verified
1102.5 / 404.2.7–404.2.8	Closer speed and opening force	Closer: 90° to 12° in 5 seconds minimum. Spring hinge: 70° to closed in 1.5 seconds minimum. Interior hinged and sliding/folding opening force 5.0 pounds (22.2 N) maximum (not fire/panic doors)	Doors with closers or interior swing/slide	Latch-retract force does not apply to panic, delayed-egress or fire-rated hardware	Direct	Set guestroom closers to 5 s; hold interior opening force at 22.2 N	Verified
1102.5 / 404.2.9	Push-side smooth surface	Smooth push-side surface within 10 inches (255 mm) of the floor, full width; joints within 1/16 inch (1.6 mm) of the same plane	Swinging Accessible-unit doors	Sliding doors; tapered tempered-glass bottom rail ≥ 60° from horizontal; doors not extending to within 255 mm of the floor; existing kick plates to 255 mm AFF and 1 inch (25 mm) from edges	Direct	Specify a 255 mm kick plate / smooth bottom rail on swinging guestroom doors	Verified
1102.5 / 404.2.10	Vision lite height	Bottom of at least one viewing panel 43 inches (1090 mm) maximum AFF	Doors, gates or sidelites with viewing panels	Vision lites with lowest part more than 66 inches (1675 mm) AFF	Conditional	If a guestroom entry has a vision panel, hold the bottom at 1090 mm max	Verified
1102.5 / 404.3.3	Automatic-door clear width	Automatic doorways 32 inches (815 mm) clear in power-on and power-off; break-out opening 32 inches (815 mm) minimum	Power-operated Accessible-unit doors	Full-power and low-energy devices also name BHMA A156.10 / A156.19 (values not imported)	Conditional	If a power door is used at the unit, keep 815 mm clear in both power states	Verified

6. Operable parts, reach and clear floor space

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1102.9 / 305.3.1	New clear floor space	New-building clear floor space 52 inches (1320 mm) minimum length × 30 inches (760 mm) minimum width	Operable parts, fixtures and elements that require a CFS	Existing CFS is 48 × 30 inches (1220 × 760 mm) ; Type B 1104.1.1 is not used here	Direct	Park a 1320 × 760 mm CFS at controls, fixtures and the bed	Verified
305.2	CFS floor	No change in level in the CFS; slope not steeper than 1:48 permitted	Clear floor spaces	None stated	Direct	Keep CFS pads at 1:48	Verified
305.7.1–305.7.2	Alcove CFS	Parallel alcove 60 inches (1525 mm) minimum wide where depth exceeds 15 inches (380 mm) . Forward alcove 36 inches (915 mm) minimum wide where depth exceeds 24 inches (610 mm)	CFS confined on three sides	None stated	Direct	Widen wardrobe/vanity alcoves to 1525 mm parallel or 915 mm forward	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1102.9 / 306.2–306.3	Knee and toe clearance	Toe: floor to 9 inches (230 mm) AFF, 25 inches (635 mm) max depth, 17 inches (430 mm) min where required, 30 inches (760 mm) min width. Knee: 9–27 inches (230–685 mm) AFF, 25 inches (635 mm) max at 9 in, 11 inches (280 mm) min at 9 in and 8 inches (205 mm) min at 27 in, reducing 1 inch (25 mm) per 6 inches (150 mm) height; 30 inches (760 mm) min width	Forward approach at lavatories, work surfaces and similar	Space beyond 6 inches (150 mm) past available knee clearance at 9 in is not toe clearance	Direct	Build removable or open vanities to the 230/685 mm knee-toe envelope	Verified
1102.9 / 308.2.1	Unobstructed forward reach	High forward reach 48 inches (1220 mm) maximum; low 15 inches (380 mm) minimum AFF	Forward reach to operable parts	None stated	Direct	Place switches, thermostats and outlets in the 380–1220 mm envelope	Verified
1102.9 / 308.2.2	Obstructed high forward reach	High forward 48 inches (1220 mm) max where reach depth is 20 inches (510 mm) max; 44 inches (1120 mm) max where depth is greater than 20 inches (510 mm) and not more than 25 inches (635 mm)	Forward reach over a counter or obstruction	CFS and 306 must extend under the element at least the reach depth	Direct	If a control sits over a 510–635 mm counter, drop the high reach to 1120 mm	Verified
1102.9 / 308.3.1	Unobstructed side reach	High side 48 inches (1220 mm) max; low 15 inches (380 mm) min, where the CFS edge is 10 inches (255 mm) max from the element	Parallel approach to operable parts	Existing unaltered elements 54 inches (1370 mm) max (Conditional)	Direct	Keep parallel-approach outlets at 380–1220 mm	Verified
1102.9 / 308.3.2	Obstructed high side reach	Obstruction 34 inches (865 mm) max high and 24 inches (610 mm) max deep. High side 48 inches (1220 mm) for reach depth 10 inches (255 mm) max; 46 inches (1170 mm) for reach depth 24 inches (610 mm) max	Side reach over a cabinet	None stated	Direct	Do not put Accessible-unit outlets over counters deeper than 610 mm or higher than 865 mm	Verified
1102.9 / 309.4	Operable-part force	One hand; no tight grasping, pinching or twisting of the wrist; 5.0 pounds (22.2 N) maximum	Lighting, panelboards, switches, receptacles, environmental, appliance, plumbing and security/intercom controls	Dedicated receptacles; one of two-plus kitchen counter receptacles; corner counter ≤ 9 square feet (0.835 m²) ; floor receptacles; HVAC diffusers; ceiling-fan controls; redundant non-light controls; appliance/plumbing reset; panelboards exempt from 309.4; emergency-personnel devices	Direct	Specify rocker/paddle devices at 22.2 N; apply the listed receptacle exceptions on the electrical drawings	Verified

7. Toilet and bathing facilities (grab bars in place)

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1102.11.2	Required Accessible bath set	At least one toilet/bathing facility complies with 603. At least one lavatory, one water closet and either a bathtub or shower comply with 604 through 610, in a single area so travel between fixtures does not go through other parts of the unit	Accessible units	Other baths in the unit follow 1102.11.1 blocking	Direct	Put WC, lav and tub or shower in one Accessible bathroom; do not split the set across a bedroom	Verified
1102.11.2 / 603.2.1–603.2.2	Bath turning space and door swing	Turning space inside the room, not inside a toilet compartment. Door shall not swing into any fixture CFS or clearance	The 1102.11.2 bathroom	Individual-use room with a 305.3 CFS beyond the door arc; private-office single-occupant reverse-swing (not typical in a guestroom)	Direct	Keep the 1700 mm turn in the Accessible bath and swing the door out or past a 1320 × 760 mm CFS	Verified
1102.11.2.2 / 603.3	Lavatory mirror height	Bottom of reflecting surface 40 inches (1015 mm) maximum AFF over the 606 lavatory (and over non-lavatory counters)	Mirrors above Accessible-unit lavatories	The 603.3 35-inch (890 mm) alternate mirror does not apply inside Accessible dwelling/sleeping units	Direct	Hold the Accessible-bath mirror at 1015 mm max; do not use the 890 mm elsewhere-in-room exception	Verified
603.4	Coat hook and shelf	Coat hooks in a 308 reach range. Shelves 40 inches (1015 mm) minimum and 48 inches (1220 mm) maximum AFF	Hooks/shelves in the Accessible bath	None stated	Conditional	If a robe hook or shelf is provided, place the shelf at 1015–1220 mm	Verified
Table 603.6	Towel dispenser / dryer reach	Operable parts on towel dispensers and hand dryers serving 606 lavatories shall comply with Table 603.6	Dispensers/dryers at the Accessible lavatory	Flattened blob: no cell adopted	External verification	Confirm dispenser reach from a readable Table 603.6 before specifying	Verify source
1102.11.2 / 604.2–604.4	Water-closet location, clearance, seat	Centerline 16 inches (405 mm) min to 18 inches (455 mm) max from the side wall. Clearance 60 inches (1525 mm) min wide and 56 inches (1420 mm) min deep. Seat 17 inches (430 mm) min to 19 inches (485 mm) max AFF, not sprung	Accessible-unit water closet	Adjustable-height WC with one setting in range; private-office height exemption (not typical)	Direct	Set WC at 405–455 mm from the side wall in a 1525 × 1420 mm clear zone; seat 430–485 mm	Verified
1102.11.2 / 604.5.1–604.5.2	Water-closet grab bars in place	Side wall: horizontal bar 42 inches (1065 mm) min, 12 inches (305 mm) max from rear wall, extending 54 inches (1370 mm) min from rear wall; vertical bar 18 inches (455 mm) min, bottom 39–41 inches (990–1040 mm) AFF, centerline 39–41 inches (990–1040 mm) from rear wall. Rear wall: 36 inches (915 mm) min, 6 inches (150 mm) max from side wall, extending 42 inches (1065 mm) min from side wall	Accessible-unit water closet	Rear bar 24 inches (610 mm) min centered where a recessed fixture prevents 915 mm; split/shifted rear bar if the AHJ requires a conflicting flush valve	Direct	Install both side (horizontal+vertical) and rear grab bars; this is not Type A/B blocking	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
604.6	Flush control	Hand-operated or automatic; hand-operated complies with 309; located on the open side of the water closet	Accessible-unit water closet	Ambulatory-compartment either-side rule is not the dwelling typical	Direct	Place the flush on the open side within the 308/309 envelope	Verified
604.7.1	Toilet-paper dispenser	Above grab bar: outlet 24–36 inches (610–915 mm) from rear wall. Below grab bar: 24–42 inches (610–1063 mm) from rear wall. Outlet 18–48 inches (455–1220 mm) AFF. Two-roll ≤ 5-inch (125 mm) diameter exception: 7–9 inches (180–230 mm) in front of the WC, outlet 15–48 inches (380–1220 mm) AFF	Paper dispensers at the Accessible WC	Delivery-controlling dispensers prohibited; 309.4 and 609.3 also apply	Direct	Locate the dispenser in the stated wall zone; do not use a controlled-delivery type	Verified
1102.11.2 / 606.2–606.6	Lavatory	Forward-approach 305.3 CFS with 306 knee/toe. Front of lavatory 34 inches (865 mm) max AFF to the higher of rim or counter. Faucets 309; metering 10 seconds min. Pipes insulated; no sharp undersides	Accessible-unit lavatory	Parallel CFS at kitchen sinks without cooktop/range and at wet bars; enhanced-reach faucet/soap 11 inches (280 mm) max depth; automatic faucet reach-depth 11 inches (280 mm)	Direct	Specify a 865 mm max open lavatory with insulated traps and a 1320 × 760 mm forward CFS	Verified
1102.11.2.1	Equivalent vanity	If non-Accessible units in the same facility have vanity countertop space, Accessible units get equivalent size and proximity to the lavatory	Vanities provided in other units	None stated	Conditional	Match Accessible-guestroom vanity length to the standard-room typical	Verified
1102.11.2 / 607.2–607.3	Bathtub clearance and seat	Clearance the length of the tub × 30 inches (760 mm) min depth; with a permanent head-end seat, extend 12 inches (305 mm) min beyond the head wall. Permanent or removable in-tub seat per 610	Accessible-unit bathtub (if tub is the bathing fixture)	Shower may be provided instead of a tub	Direct	If a tub is used, hold a 760 mm clear strip the full length and provide a 610 seat	Verified
607.4.1–607.4.2	Bathtub grab bars in place	Permanent-seat tub: two back-wall horizontals (one at 609.4, one 8–10 inches (205–255 mm) above the rim), 15 inches (380 mm) max from head wall to 12 inches (305 mm) max from control wall; control-end horizontal 24 inches (610 mm) min plus vertical 18 inches (455 mm) min. Removable-seat tub: back bars 24 inches (610 mm) min, 24 inches (610 mm) max from head wall; head-end horizontal 12 inches (305 mm) min	Accessible-unit bathtub	L-shaped continuous control-end bar permitted	Direct	Install the full 607.4 grab-bar set; do not substitute blocking	Verified
607.5–607.8	Bathtub controls, hand shower, enclosure, temperature	Controls between rim and grab bar and between the open side and tub centerline; 309.4. Hand shower hose 59 inches (1500 mm) min, nonpositive shutoff. No enclosure tracks on the rim. Water 120°F (49°C) maximum	Accessible-unit bathtub	Drain stoppers excepted from the control location	Direct	Specify a 1500 mm hand shower, rim-free enclosure and 49°C limit	Verified
1102.11.2 / 608.2.1	Transfer shower size and new clearance	Transfer shower 36 × 36 inches (915 × 915 mm) inside at center points; entry 36 inches (915 mm) min. New adjacent clearance 52 × 36 inches (1320 × 915 mm) ; length measured from the control wall or from 4 inches (100 mm) behind it. Seat on the wall opposite the control wall	Accessible-unit transfer shower	Existing clearance 48 × 36 inches (1220 × 915 mm) . Seat not required in private-office single-occupant showers with reinforcement	Direct	If a transfer shower is used, hold 915 × 915 mm with a 1320 × 915 mm clear	Verified
608.2.2	Standard roll-in shower	Inside 60 inches (1525 mm) min wide × 30 inches (760 mm) min deep; entry 60 inches (1525 mm) min. Adjacent clearance 60 × 30 inches (1525 × 760 mm) . Folding 610 seat on an end wall	Accessible-unit standard roll-in	606 lavatory permitted at the clearance end opposite the seat	Direct	Prefer a 1525 × 760 mm roll-in with a 1525 × 760 mm clear if the Accessible bath is a shower	Verified
608.2.3	Alternate roll-in shower	Inside 60 inches (1525 mm) min wide × 36 inches (915 mm) deep; entry 36 inches (915 mm) min at one end of the 1525 mm width. Seat wall 24 inches (610 mm) min to 36 inches (915 mm) max on the entry side	Accessible-unit alternate roll-in	Seat exception as 608.2.1.3	Conditional	Use only if the Accessible bath is planned as an alternate roll-in	Verified
608.3.1–608.3.3	Shower grab bars in place	Transfer: horizontal across control wall and back wall to 18 inches (455 mm) from the control wall; vertical 18 inches (455 mm) min, 3–6 inches (75–150 mm) above the horizontal, 4 inches (100 mm) max from the front edge. Roll-in and alternate: back/side bars to 6 inches (150 mm) from adjacent walls; roll-in back bar not required to exceed 48 inches (1220 mm) ; side bar not required to exceed 30 inches (760 mm) ; side-wall trigger within 72 inches (1830 mm) of the seat wall	Accessible-unit showers	Private-office reinforcement-only exception not typical	Direct	Install 608.3 bars in the chosen shower type; this is not blocking	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
608.4–608.8	Shower controls, hand shower, threshold, temperature	Controls/hand shower 38–48 inches (965–1220 mm) AFF. Transfer: on the control wall, 15 inches (380 mm) max from control-wall centerline toward the opening. Standard roll-in: on the back wall, 16–27 inches (405–685 mm) from the seat-wall. Hose 59 inches (1500 mm) min; holder 38–48 inches (965–1220 mm) AFF. Roll-in threshold 1/2 inch (13 mm) max; transfer threshold 1/2 inch (13 mm) beveled, rounded or vertical. Water 120°F (49°C) max	Accessible-unit showers	Existing transfer threshold 2 inches (51 mm) max only if a 13 mm threshold would disturb slab reinforcement. Fixed head 48 inches (1220 mm) max in lieu of hand shower is not permitted in Accessible or Type A units	Direct	Place controls in the 965–1220 mm band; specify a 1500 mm hand shower and 13 mm threshold	Verified
609.2–609.3	Grab-bar section and spacing	Circular OD 1 1/4–2 inches (32–51 mm) ; noncircular 2 inches (51 mm) max section, perimeter 4–4.8 inches (100–120 mm) . Wall clearance 1 1/2 inches (38 mm) ; 12 inches (305 mm) min above to projecting objects (1 1/2 inches (38 mm) min at shower controls/fittings)	All Accessible-unit grab bars	Recessed dispensers projecting 1/4 inch (6.4 mm) max permitted in the 305 mm zone	Direct	Specify 32–51 mm bars at 38 mm off the wall	Verified
609.4	Grab-bar mounting height	Horizontal grab-bar height above the floor	Grab bars charged by 604.5, 607.4 and 608.3	Adult 609.4 paragraph is missing/garbled in the Chapter 6 extract (children’s 609.4.2 text is present)	External verification	Confirm adult 609.4 height from a readable source before locking bar AFF	Verify source
609.8 / 610.4	Grab bar and seat strength	250 pounds (1112 N) vertical or horizontal at any point on the bar/seat, fastener or supporting structure	Grab bars and bath/shower seats	None stated	Direct	Note 1112 N on the interior typicals and blocking/backing spec	Verified
610.2–610.3	Bath and shower seat size	Seat height 17–19 inches (430–485 mm) AFF. Removable in-tub 15–16 inches (380–405 mm) deep; permanent tub seat 15 inches (380 mm) min deep to or beyond the outer rim. Shower seat to within 3 inches (75 mm) of the entry. Rectangular rear edge 2 1/2 inches (64 mm) max from seat wall, front edge 15–16 inches (380–405 mm) ; L-seat “L” front 14–15 inches (355–380 mm) , end 22–23 inches (560–585 mm) from the main seat wall	Seats in Accessible tubs/showers	None stated	Direct	Detail 430–485 mm seats to the 610 plan dimensions	Verified

8. Kitchens

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1102.12 / 804.2.1–804.2.3	Kitchen work-aisle clearance	Pass-through (two entries): 40 inches (1015 mm) min between opposing bases/counters/appliances/walls. U-shape: 60 inches (1525 mm) min. No cooktop/range: 40 inches (1015 mm) min	Kitchens in Accessible units	U-shape with an island may use the 804.2.1 1015 mm aisle	Conditional	If a kitchenette exists, hold 1015 mm (1525 mm if U-shaped)	Verified
1102.12 / 804.3 / 902.4	Accessible work surface	At least one work surface 30 inches minimum in length (804.3 publishes inches only) complying with 902: forward CFS + 306; top 28 inches (710 mm) min to 34 inches (865 mm) max AFF	Kitchens with a cooktop or conventional range	Not required where no cooktop/conventional range; locate per 804.5.5.2 or 804.5.5.3 beside the oven	Conditional	Provide a 30 in × 710–865 mm work surface with knee space beside the oven	Verified
1102.12 / 804.4 / 606	Kitchen sink	Sink complies with 606: forward 305.3 CFS, 306 knee/toe, 34 inches (865 mm) max to rim/counter, faucets 309, insulated pipes	Accessible-unit kitchen sink	Parallel CFS permitted where no cooktop/range and at wet bars; knee/toe at only one bowl of a multi-bowl sink	Conditional	Specify an 865 mm max open sink with a 1320 × 760 mm forward CFS	Verified
804.5.1–804.5.5	Appliance CFS and approach	CFS at each appliance. Dishwasher door shall not obstruct its CFS or an adjacent sink. Cooktop: parallel or forward; forward needs 306 and insulated underside; parallel CFS centered. Oven door shall not obstruct its CFS; side-hinged ovens get the 804.3 work surface on the latch side; bottom-hinged on one side. Controls shall not require reaching across burners	Kitchen appliances where provided	Appliance doors/latches exempt from 309.4; open bottom-hinged doors exempt from 309.3	Conditional	Park a CFS at each appliance; keep oven swing clear of the CFS	Verified
804.5.6	Refrigerator/freezer	At least 50 percent of freezer shelves including the freezer bottom 54 inches (1370 mm) max AFF at maximum shelf positions. Parallel CFS; CFS centerline offset 24 inches (610 mm) max from the appliance centerline	Combination refrigerator/freezer	None stated	Conditional	Specify a fridge with ≥ 50% of the freezer at or below 1370 mm and a centered-within-610 mm parallel CFS	Verified

9. Laundry equipment

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1102.10 / 611.2	Laundry clear floor space	Parallel-approach CFS at each machine. Top-load: CFS centered on the appliance. Front-load: CFS centerline offset 24 inches (610 mm) max from the door-opening centerline	Washers and dryers in the Accessible unit	None stated	Conditional	If in-unit laundry exists, center a 1320 × 760 mm parallel CFS (offset ≤ 610 mm at front-load)	Verified
611.3–611.4	Laundry operable parts and height	Operable parts, doors, lint screens and detergent compartments comply with 308 and 309. 308.3.2 obstruction height permitted 36 inches (915 mm) max. Top-load door 36 inches (915 mm) max AFF. Front-load opening bottom 15–36 inches (380–915 mm) AFF	In-unit laundry	None stated	Conditional	Specify front-load openings 380–915 mm AFF and controls in the reach range	Verified

10. Beds and wheelchair charging

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1102.15	Accessible bed quantity	In at least one sleeping area, minimum five percent , but not less than one bed, shall comply with 1102.15	Accessible-unit sleeping areas	None stated	Direct	Make at least one bed per Accessible guestroom the 1102.15 bed	Verified
1102.15.1 / 305.3.1	Bed clear floor space	CFS on both sides, positioned for parallel approach to the bed side	The 1102.15 bed	One CFS between two beds may serve both	Direct	Hold 1320 × 760 mm parallel CFS on both sides, or one CFS between a pair	Verified
1102.15.2	Open bed frame	At least one bed shall have an open bed frame	The 1102.15 bed	None stated	Direct	Specify an open-frame bed (no solid base blocking toe space)	Verified
1102.15.3	Mattress height	17 to 23 inches (430 to 585 mm) from the floor to the top of the uncompressed mattress	At least one bed	None stated	Direct	Schedule mattress height 430–585 mm AFF	Verified
1102.15.4 / 906.1–906.3	Wheelchair charging	The 1102.15.1 CFS also serves as a charging station: grounded duplex outlet, CFS at the station, height in a 308 reach range	Accessible-unit sleeping area	None stated	Direct	Put a duplex in the 380–1220 mm reach range at the bed CFS	Verified

11. Windows and storage

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1102.13 / 506.1–506.2	Operable window force	At least one operable window in an accessible room complies with 506. Locking/latching operable parts comply with 309. Opening/closing force 8.5 pounds (37.7 N) max for vertical or horizontal sliding; 5 pounds (22.2 N) max for all other types (AAMA 513 test method named, values not imported)	Operable windows in Accessible units	Kitchen and bathroom windows (1102.13 Ex. 1–2); employee-only windows; operable skylights. Natural-ventilation or emergency-escape windows, where required, shall be the complying window	Direct	Specify one complying window per Accessible guestroom (not the bath/kitchen window) within 37.7 N / 22.2 N	Verified
1102.14 / 905.2–905.4	Storage	Where storage is provided, at least one of each type: CFS, height in a 308 reach range, operable parts 309	Closets, shelves, rods other than kitchen cabinets	Kitchen cabinets exempt	Direct	Put at least one rod/shelf of each type in the 380–1220 mm reach range with a CFS	Verified

12. In-unit ramps, elevators and platform lifts

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1102.6 / 405.2–405.8	Ramp geometry	Running slope steeper than 1:20 and not steeper than 1:12. Cross slope not steeper than 1:48. Clear width 36 inches (915 mm) min. Rise 30 inches (760 mm) max per run. Landings 60 inches (1525 mm) min long; direction-change landing 60 × 60 inches (1525 × 1525 mm) . Handrails where rise > 6 inches (150 mm)	Ramps inside the Accessible unit	Existing steeper ramps per Table 405.2 (flattened: no cell adopted ; fn 1: slope steeper than 1:8 not permitted)	Conditional	If a unit ramp exists, hold 1:12, 915 mm width, 760 mm max rise and 1525 mm landings	Verified
1102.7 / Table 407.4.1	Destination-elevator car size	Elevators within the unit comply with 407, 408 or 409. Inside dimensions per Table 407.4.1	Elevators inside the Accessible unit	Flattened blob: no cell adopted . Readable footnotes: minus 7/8 inch (16 mm) door-width tolerance (fn 1); other cars with 36-inch (915 mm) door and 60-inch (1525 mm) diameter with door closed (fn 2). Existing-car exception: 16 square feet (1.5 m²) min with 36 × 54 inches (915 × 1370 mm) min	External verification	Confirm car size from a readable Table 407.4.1; apply the readable footnotes	Verify source
1102.7 / 408.4.1	LULA car size	Clear floor width 42 inches (1065 mm) min; area not less than 15.75 square feet (1.46 m²) ; CFS per 305.3	Limited-use/limited-application elevator in the unit	Existing: 15 square feet (1.4 m²) with 36 × 54 inches (915 × 1370 mm) ; or 51 × 51 inches (1295 × 1295 mm) with 36-inch (915 mm) door	Conditional	If a LULA is used, hold 1065 mm width and 1.46 m²	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1102.7 / 409.4.1.1	New private-residence elevator	New-building car 36 inches (915 mm) min width × 52 inches (1320 mm) min depth	Private residence elevator in the unit	Existing: 36 × 48 inches (915 × 1220 mm)	Conditional	If a private elevator is used in a new Accessible unit, hold 915 × 1320 mm	Verified
1102.8 / 410.5.1.1	New platform-lift size	New lifts with a single door or opposite-end doors: 36 inches (915 mm) min width × 52 inches (1320 mm) min depth. Adjacent-side doors (new): 42 × 60 inches (1065 × 1525 mm) . End-door clear 32 inches (815 mm) min (opposite ends) or 36 inches (915 mm) min (narrow end with a long-side door); side door 42 inches (1065 mm) min. Doors remain open 20 seconds min	Platform lifts inside the Accessible unit	Incline lifts with restraining arms: 36 × 48 inches (915 × 1220 mm) . Existing opposite-end: 36 × 48 inches (915 × 1220 mm) ; existing adjacent: 36 × 60 inches (915 × 1525 mm)	Conditional	If a lift is used, hold 915 × 1320 mm (new opposite-end) and 815 mm door clear	Verified

13. Other-bath grab-bar reinforcement

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1102.11.1 / 1104.11.1	Non-required-bath blocking	Fixtures in baths not required to comply with 1102.11.2 get reinforcement for future grab bars and seats per 604.5 (WC), 607.4 (tubs) and 608.3 / 608.2.1.3 / 608.2.2.3 / 608.2.3.2 (showers)	Other toilets/baths in the Accessible unit	Not required where Type B units are not provided in the structure. 1104.11.1 exceptions: powder room that is not the only WC/lav on the accessible level; vertical WC side-bar component; 24 in rear / 24 in side substitutes; swing-up bars; shower seat not required in compartments larger than 36 × 36 inches (915 × 915 mm)	Conditional	If the building also has Type B units, back the second bath for future 604.5 / 607.4 / 608 bars; skip if no Type B units exist	Verified

14. Communication-feature overlay

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Accessible status	Design action	Source confidence
1106.2–1106.4 / 702.1	Visible/audible notification	Unit smoke: audible per NFPA 72 (106.2.4). Building alarm wiring extended into the unit near the unit smoke system. Visible appliances, where provided, comply with 702 (NFPA 72 installation; dwelling visibles may instead use 1106.2–1106.4.4). Same appliances may serve both; not used for other purposes	Units also required to have communication features	NFPA 72 numeric spacing is not in the attached Chapter 7 extract	Conditional	If the unit is a comms unit, extend alarm wiring and provide 702/1106 visibles; do not treat this as a substitute for 1102 geometry	Verified
1106.5.1–1106.5.2	Doorbell and visitor ID	Hard-wired electric doorbell; public-side button; audible tone in the unit; deactivation where visible doorbell signals are in sleeping areas. Visual visitor identification without opening the door; peepholes 180-degree minimum range of view	Comms-unit primary entrance	None stated	Conditional	Specify a hard-wired doorbell and a 180° viewer or equivalent at the Accessible comms-unit entry	Verified
1106.6–1106.7	Remote entry voice/TTY	If visitor voice is provided away from the unit door: public interface supports voice and TTY; unit interface has a telephone jack supporting voice and TTY. Closed-circuit systems use the same interfaces	Remote entry communication	None stated	Conditional	If a lobby video-phone exists, provide a TTY-capable jack in the comms unit	Verified

15. Project-use controls

- Use **Verified** rows as design-release geometry for Accessible-unit typicals.
- Do not use **Verify source** or **External verification** rows (flattened Tables 404.2.3.2 / 404.2.3.3 / 404.2.3.4 / 407.4.1 / 405.2 / 603.6, and 609.4 height) until a readable source is confirmed.
- Do not mix 2017 new **67 inches (1700 mm)** turning or **52 inches (1320 mm)** CFS with existing **60 inches (1525 mm) / 48 inches (1220 mm)** on the same Direct typical.
- Do not apply Type A removable-cabinet baths or Type B **31 3/4 inches (805 mm)** doors to Accessible units.
- Scoping (how many Accessible units, which storeys, communication-feature counts) remains SBC 201 Chapter 11.

16. Coverage summary

- Inventory scope: numbered Chapter 11 code (1101–1102, 1106 overlay, 1102.11.1 → 1104.11.1), exceptions, charged companion paragraphs/footnotes from Chapters 3–9. INSIGHTS headings, FIGURE captions and commentary excluded. Type C (1105), public compartments (604.9–604.10), children’s (604.11), urinals (605), drinking fountains (602) and Chapter 10 omitted.
- Total independently checkable numeric records: **241**
- Verified: **218**
- Verify source: **23** (flattened table cells and 609.4 height)

Top-level section	Numeric records
1102 local + 1106 overlay	18
303–309 building blocks	52
403–404 routes/doors (paragraphs + footnotes; tables held)	48

Top-level section	Numeric records
405 / 407–410 ramps and vertical (paragraphs + footnotes)	28
506 / 603–611 / 804 / 902 / 905–906	95

17. Unresolved-source register

Affected table / clause	Why unverified	Control note
Table 404.2.3.2	Concatenated <table> blob; skill forbids reconstructing swinging-door manoeuvre cells	Do not adopt front-pull/push or hinge/latch cells as design-release; footnotes 1–5 after the blob remain Verified
Table 404.2.3.3	Flattened sliding/folding manoeuvre blob	Confirm from a readable table; fn 1 (beyond pocket/hinge) is Verified
Table 404.2.3.4	Flattened doorway-without-door blob	Confirm from a readable table; existing front 48 inches (1220 mm) footnote is Verified
Table 405.2	Flattened existing-ramp slope/rise blob	New ramps use paragraph 1:12; do not adopt reconstructed existing-ramp cells; fn 1 (no steeper than 1:8) is Verified
Table 407.4.1	Flattened elevator-car option blob	Do not adopt reconstructed car cells; fn 1 7/8 inch (16 mm) and fn 2 36 / 60 inch (915 / 1525 mm) remain Verified
Table 603.6	Flattened towel-dispenser/dryer reach-depth blob	Confirm dispenser/dryer reach from a readable table
609.4	Adult horizontal grab-bar height paragraph missing/garbled in the Chapter 6 extract	Confirm adult AFF from a readable 609.4; do not back-fill from memory or CS.md
Figure 304.3.1.1 shaded overlap	Overlap zone is figure-defined beyond the 10-inch (255 mm) cap	Treat the shaded limit as a figure dependency
702 / NFPA 72	Chapter 7 names NFPA 72 without appliance spacing millimetres	Visible-appliance layout remains an NFPA 72 companion
ASME A17.1 / BHMA A156 / AAMA 513	Named only	Do not import unstated car-sill, power-door or window-test values