

ICC A117.1 Chapter 11 Dwelling Units and Sleeping Units — Type A Dimensional Requirements Matrix (2017)

1. Document metadata and use limitation

- **Project basis:** Mixed-use tall building containing Group R-1 (hotel) with Group R-2 residential sharing podium, parking and routes. An occupied floor is stated to be more than 23 m above the relevant reference level. This matrix filters ICC A117.1 Chapter 11 for **Type A units** (Section 1103).
- **Unit type:** Type A (1103). Accessible (1102) and Type B (1104) interiors are omitted from this file. Type C (1105) is omitted.
- **Deliverable tier:** Project-use matrices in Sections 4–13 (design-check rows, not pasted inventory), plus project-use controls, a coverage summary and an unresolved-source register.
- **Code/source basis:** ICC A117.1 (2017), Chapter 11, source file Reference\2017 ICC A117_1 Accessible and Usable Buildings and Facilities\source_reference\Chapter_11 – DWELLING UNITS AND SLEEPING UNITS.txt. Companion numbers inlined from the attached 2017 Chapter 1–10 source_reference extracts where 1103 charges those sections.
- **Extraction audit:** Internal inventory: **236** independently checkable numeric records (**214** Verified, **22** Verify source). Unresolved OCR/flattened tables are listed in the register and are not design-release values.
- **Inspecting model:** Cursor Grok 4.6.
- **Prepared:** 2026-08-28.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped compliance statement, accessibility consultant report, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Scoping companion:** Counts and which units must be Type A are **SBC 201 Chapter 11**. This file is technical geometry only.
- **Edition gap:** SBC 201 Chapter 35 lists **ICC A117.1—09**. Charging SBC 1102.1 has no year. This extract is **2017**. 2017 new-building CFS, turning and door manoeuvre are larger than 2009. **Do not treat 2017 millimetres as the legal SBC minimum.**

Scope and assumptions

1. Type A is Direct for the R-2 apartment typicals. Transient R-1 hotel rooms are not the Type A path; the gap register records that. Do not hide this matrix.
2. New construction is assumed. Existing-building dimensions are Conditional.
3. Type A uses **full 404 doors** and **304 turning** like Accessible units. Baths and kitchens are **adaptable** (removable cabinetry, grab-bar **blocking**, not grab bars in place).
4. Type A water-closet seat is **15–19 inches (380–485 mm)**, not the Accessible 17–19 in range.
5. FIGURE captions are dependencies. Flattened <table> blobs are not reconstructed as Verified cells.

2. Legends

Applicability

Status	Meaning
Direct	Expected to govern Type A unit interiors once geometry is confirmed (R-2 typical).
Conditional	Governs only if the stated feature, existing-building branch, in-unit ramp/lift/elevator, or communication overlay exists; or if Type A is applied to R-1.
Not typical	Unrelated unit-type-only rule; omitted unless the gap register already opened that use.
External verification	A figure is missing, a flattened table is unread, or AHJ/edition must be confirmed first.

Source confidence

Status	Meaning
Verified	Unambiguous mandatory source text or readable footnote after a table blob.
Verify source	OCR, flattened table, page-split, or footnote attachment is unresolved. Not a design-release value.

3. Project decision and gap register

Decision / gap	Current project basis	Why it controls Chapter 11 application	Required project action
A117.1 edition lock	Extracted edition is 2017 ; SBC 201 Chapter 35 lists A117.1—09	2017 new CFS 52 × 30 inches (1320 × 760 mm) and turning 67 inches (1700 mm) exceed 2009	AHJ to lock 2009 vs 2017; do not treat this extract as the legal SBC minimum
Occupancy path	Mixed R-1 hotel + R-2 apartments	Type A is the R-2 adaptable typical, not the transient R-1 Accessible-guestroom path	Apply this matrix to R-2 Type A apartments; do not relabel hotel Accessible rooms as Type A
New vs existing	New construction assumed	403.5 / 304.3 / 305.3 / 404.2.3 / 608.2.1.2 split new/existing	Hold Direct rows on the new-building option set
Grab bars	Type A is blocking, not bars in place	1103.11.1 charges 604.5 / 607.4 / 608.3 reinforcement; vertical WC side-bar component is not required	Draw removable bases and blocking; do not install Accessible-unit grab bars as the Type A typical
Kitchenette vs full kitchen	Unconfirmed	1103.12 work surface is not required without a cooktop/conventional range	Confirm whether Type A units have a range before locking the 30 in work surface
AHJ / NOC	Unconfirmed	Stamped compliance cannot be concluded from this extract	Engage the qualified local accessibility consultant before design freeze

4. Unit accessible route, turning and walking surfaces

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type A status	Design action	Source confidence
1103.2	Primary entrance location	Primary entrance on an accessible route from public and common areas; not to a bedroom unless it is the only entrance	Type A units	None stated	Direct	Place the Type A entry on the corridor accessible route	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type A status	Design action	Source confidence
1103.3.1	Unit accessible-route extent	At least one accessible route shall connect all spaces and elements that are part of the unit and shall coincide with or be in the same area as the general circulation path	Type A interiors	Unfinished attics and unfinished basements	Direct	Connect entry, bedrooms, living, required bath and kitchen on one accessible route	Verified
1103.3.2 / 304.3.1.1	New circular turning space	All rooms served by the accessible route shall provide a circular turning space 67 inches (1700 mm) minimum diameter	Rooms on the Type A accessible route	Not required in toilets/baths that are not the 1103.11.2 room; not required in closets or pantries 48 inches (1220 mm) maximum depth; existing circular is 60 inches (1525 mm)	Direct	Hold a 1700 mm turning circle in habitable rooms and the required bath	Verified
1103.3.2 / 304.3.2.1	New T-shaped turning option set	New T-turn is one of: 68 × 60 inches (1725 × 1525 mm) with arms/base 36 inches (915 mm) and 8-inch (205 mm) chamfers; or 64 × 60 inches (1625 × 1525 mm) with arms 38 inches (965 mm) and base 42 inches (1065 mm) ; or 64 × 60 inches (1625 × 1525 mm) with arms/base 40 inches (1015 mm)	Rooms where a T-turn is used instead of a circle	Existing T-turn is a 60-inch (1525 mm) square with arms/base 36 inches (915 mm)	Direct	Pick one new T-option; do not mix the existing 1525 mm T on a new Direct plan	Verified
304.3.1.1.1	Turning-space knee/toe overlap	Circular-turn overlap 10 inches (255 mm) maximum, not exceeding the knee/toe provided, only in Figure 304.3.1.1	Turning under a fixture or counter	Figure-defined shaded zone	Direct	Limit vanity overlap into the 1700 mm circle to 255 mm	Verified
1103.3.3 / 403.3	Walking-surface slope	Running slope not steeper than 1:20; cross slope not steeper than 1:48	Type A walking surfaces	Steeper surfaces become ramps (405)	Direct	Hold unit floors at 1:20 / 1:48	Verified
1103.4 / 403.5.1	Interior accessible-route clear width	Interior 36 inches (915 mm) minimum; exterior 48 inches (1220 mm) minimum	Type A accessible routes	New pinch: 32 inches (815 mm) for 24 inches (610 mm) max, separated by 52 × 36 inches (1320 × 915 mm) ; existing pinch uses 48 inches (1220 mm) separators; exterior seating 36 inches (915 mm) ; exterior ramp → 405.5	Direct	Hold interior circulation at 915 mm; document any local pinch	Verified
1103.4 / 403.5.2.1	New 180-degree turn widths	Around an object ≥ 52 inches (1320 mm) , new 90° options apply. Narrower object: 36 / 60 / 36 inches (915 / 1525 / 915 mm) ; or 42 / 48 / 42 inches (1065 / 1220 / 1065 mm) ; or 43 inches (1090 mm) throughout	180-degree turns	Existing 180° around object < 48 inches (1220 mm) is 42 / 48 / 42 inches (1065 / 1220 / 1065 mm) , waived if the turn is 60 inches (1525 mm)	Direct	Dimension 180° turns to one new option set	Verified
1103.4 / 403.5.3.1	New 90-degree turn widths	Both legs 40 inches (1015 mm) held 28 inches (710 mm) from the inner corner; or 8-inch (205 mm) chamfers with both legs 36 inches (915 mm) ; or 42 / 38 inches (1065 / 965 mm) ; or 44 / 36 inches (1120 / 915 mm)	90-degree turns	Not required at 404.2.3 doors or 407–410 lifts; existing 90° is 36 inches (915 mm) both legs	Direct	Pick one new 90° option at unit corners	Verified
1103.4 / 403.5.4.1	New passing space	Width < 60 inches (1525 mm) ; passing at 200 feet (61 m) max; 60 × 60 inches (1525 × 1525 mm) or T-turn per 304.3.2.1 with arms/base 52 inches (1320 mm) beyond the intersection	Long Type A routes under 1525 mm	Existing T-arm extension 48 inches (1220 mm)	Conditional	Add a 1525 mm passing bay on any Type A corridor longer than 61 m under 1525 mm	Verified
1103.4 / 303.2–303.4	Change in level	Vertical 1/4 inch (6.4 mm) max; 1/4–1/2 inch (6.4–13 mm) beveled 1:2; above 1/2 inch (13 mm) by ramp 405 or curb ramp 406	Type A walking surfaces	None stated	Direct	Limit floor/balcony joints to 6.4 mm vertical or 13 mm at 1:2	Verified

5. Doors and doorways

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type A status	Design action	Source confidence
1103.5 / 404.2.2	Passage-door clear opening	32 inches (815 mm) minimum clear, door face to stop at 90°. Openings more than 24 inches (610 mm) deep without a door: 36 inches (915 mm) . No projections below 34 inches (865 mm) AFF; 34–80 inches (865–2030 mm) AFF projections 4 inches (100 mm) max	Primary entrance and all user-passage doors	Closers/stops 78 inches (1980 mm) min AFF; alterations latch-stop 5/8 inch (16 mm)	Direct	Specify 815 mm clear; do not use Type B 31 3/4 inches (805 mm)	Verified
1103.5 Exception 1	Exterior sliding threshold	Exterior sliding-door threshold 3/4 inch (19 mm) maximum, beveled not greater than 1:2	Type A exterior sliding doors	General 404.2.4 remains 1/2 inch (13 mm) at other doors	Direct	Allow 19 mm at 1:2 only on exterior sliders	Verified
1103.5 / Table 404.2.3.2	Swinging-door manoeuvre table	Manoeuvre per Table 404.2.3.2	Manual swinging user-passage doors	Flattened blob: no cell adopted . Readable footnotes: +6 inches (150 mm) closer+latch (fn 1) or closer (fn 2); +12 inches (305 mm) beyond latch if closer+latch (fn 3); hinge-side push beyond hinge (fn 4); existing front-push 48 inches (1220 mm) (fn 5). 1103.5 does not require 404.2.3 on the room side of non-required baths, at closet/pantry ≤ 48 inches (1220 mm) deep, or on undersized balcony exteriors; 404.2.5 series turning is not required	External verification	Hold manoeuvre off a readable table; apply footnotes now	Verify source

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type A status	Design action	Source confidence
1103.5 / Table 404.2.3.3–404.2.3.4	Sliding and cased-opening manoeuvre	Tables 404.2.3.3 and 404.2.3.4	Sliding/folding doors and cased openings < 36 inches (915 mm)	Flattened blobs: no cell adopted . Recess trigger 404.2.3.5: obstruction within 18 inches (455 mm) of latch projecting > 8 inches (205 mm)	External verification	Confirm from readable tables; apply the 455/205 mm recess trigger	Verify source
1103.5 / 404.2.4	Door threshold (other than Ex. 1)	Thresholds 1/2 inch (13 mm) maximum	Type A doorways other than exterior sliders	Existing/altered 3/4 inch (19 mm) with 1:2 bevel above 1/4 inch (6.4 mm)	Direct	Specify 13 mm max at swing doors	Verified
1103.5 / 404.2.6	Door hardware force and height	Push/pull 15 pounds (66.7 N) max; rotational 28 inch-pounds (315 N-cm) max. Hardware 34–48 inches (865–1220 mm) AFF	Type A door hardware	Security-personnel-only doors	Direct	Schedule levers 865–1220 mm AFF	Verified
1103.5 / 404.2.7–404.2.8	Closer speed and opening force	Closer 90° to 12° in 5 seconds min. Spring hinge 70° to closed in 1.5 seconds min. Interior hinged/sliding/folding 5.0 pounds (22.2 N) max	Doors with closers or interior swing/slide	Fire/panic opening-force path is AHJ-scoped	Direct	Set closers to 5 s; hold interior opening force at 22.2 N	Verified
1103.5 / 404.2.9–404.2.10	Push-side smooth surface and vision lite	Smooth push side within 10 inches (255 mm) of the floor. Vision-panel bottom 43 inches (1090 mm) max AFF	Swinging doors; doors with viewing panels	Sliding doors; vision lites with lowest part > 66 inches (1675 mm) AFF	Direct	Specify a 255 mm kick plate; hold vision panels at 1090 mm max	Verified
1103.5 / 404.3.3	Automatic-door clear width	32 inches (815 mm) clear in power-on and power-off	Power-operated Type A doors	BHMA A156 values not imported	Conditional	Keep 815 mm clear in both power states	Verified

6. Operable parts, reach and clear floor space

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type A status	Design action	Source confidence
1103.9 / 305.3.1	New clear floor space	52 × 30 inches (1320 × 760 mm) minimum	Operable parts, fixtures and kitchen CFS (1103.12.2 → 305)	Existing 48 × 30 inches (1220 × 760 mm)	Direct	Park 1320 × 760 mm CFS at controls, fixtures and appliances	Verified
305.7.1–305.7.2	Alcove CFS	Parallel alcove 60 inches (1525 mm) min wide where depth > 15 inches (380 mm) . Forward alcove 36 inches (915 mm) min wide where depth > 24 inches (610 mm)	CFS confined on three sides	None stated	Direct	Widen wardrobe/kitchen alcoves accordingly	Verified
1103.9 / 306.2–306.3	Knee and toe clearance	Toe to 9 inches (230 mm) AFF, 25 inches (635 mm) max / 17 inches (430 mm) min depth, 30 inches (760 mm) width. Knee 9–27 inches (230–685 mm) AFF, 11 inches (280 mm) min at 9 in and 8 inches (205 mm) min at 27 in	Forward approach at lavatory, work surface and sink	Removable cabinetry permitted under Type A lavatory, work surface and sink if removable without replacing the fixture, floor finish continues, and surrounding walls are finished	Direct	Build removable bases to the 306 envelope so the CFS works after removal	Verified
1103.9 / 308.2–308.3	Reach ranges	Unobstructed high 48 inches (1220 mm) / low 15 inches (380 mm) . Obstructed forward: 48 inches (1220 mm) at ≤ 20 inches (510 mm) depth, 44 inches (1120 mm) at 20–25 inches (510–635 mm) . Obstructed side: obstruction 34 inches (865 mm) max high × 24 inches (610 mm) max deep; high side 48 inches (1220 mm) at 10 inches (255 mm) depth, 46 inches (1170 mm) at 24 inches (610 mm)	Lighting, panelboards, switches, receptacles, environmental, appliance, plumbing and security/intercom controls	Existing unaltered side reach 54 inches (1370 mm)	Direct	Place Type A controls in the 380–1220 mm envelope, including plumbing/appliance controls	Verified
1103.9 / 309.4	Operable-part force	One hand; no tight grasp/pinch/wrist twist; 5.0 pounds (22.2 N) maximum	Type A operable parts listed in 1103.9	309.1 exceptions (dedicated receptacles, one of two-plus kitchen counter receptacles, corner ≤ 9 square feet (0.835 m²) , floor receptacles, HVAC, ceiling fans, redundant non-light controls, resets, panelboards vs 309.4)	Direct	Specify 22.2 N rocker devices; apply kitchen receptacle exceptions	Verified

7. Toilet and bathing facilities (adaptable)

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type A status	Design action	Source confidence
1103.11 / 1103.11.2	Required Type A bath set	At least one toilet/bathing facility complies with 1103.11.2. At least one lavatory, one water closet and either a bathtub or shower in a single area so travel between fixtures does not go through other parts of the unit. All baths comply with 1103.11.1 blocking	Type A units	None stated	Direct	Put WC, lav and tub or shower in one adaptable bathroom	Verified
1103.11.1	Grab-bar and seat blocking	Reinforcement for future 604.5 WC bars, 607.4 tub bars, and 608.3 / 608.2.1.3 / 608.2.2.3 / 608.2.3.2 shower bars and seats	All Type A baths	Non-required fixtures may use 1104.11.1 blocking. Not required in a lav+WC-only room that is not the only lav/WC on the accessible level. Vertical WC side-bar component of 604.5 is not required. Lavatory-overlap exception: rear-wall blocking for a 24-inch (610 mm) min bar centered on the WC	Direct	Back WC/tub/shower walls for future bars; omit the vertical side-bar blocking	Verified
1103.11.2.1	Bath door swing	Door shall not swing into any fixture CFS or clearance	The 1103.11.2 bathroom	CFS provided in the room beyond the door-swing arc	Direct	Swing the door out or past a 1320 × 760 mm CFS	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type A status	Design action	Source confidence
1103.11.2.2 / 606.3	Lavatory with removable cabinetry	Lavatory complies with 606: forward 305.3 CFS, 306 knee/toe, front 34 inches (865 mm) max AFF, faucets 309, insulated pipes	Type A required lavatory	Cabinetry permitted if removable without replacing the lavatory, floor finish continues under, and surrounding walls are finished	Direct	Draw a removable-base 865 mm lavatory; show the 306 envelope after removal	Verified
1103.11.2.3	Mirror height	Bottom of reflecting surface 40 inches (1015 mm) maximum AFF	Mirrors above the 1103.11.2.2 lavatory	None stated	Direct	Hold the Type A bath mirror at 1015 mm max	Verified
1103.11.2.4.1–1103.11.2.4.5	Water-closet location, clearance, seat	Centerline 16 inches (405 mm) min to 18 inches (455 mm) max from the sidewall. Clearance 60 inches (1525 mm) min wide × 56 inches (1420 mm) min deep. Seat 15 inches (380 mm) min to 19 inches (485 mm) max AFF	Type A required water closet	Overlap of WC, grab bars, dispensers, hooks, shelves, accessible routes, other fixture CFS and the turning space is permitted. Lavatory 24 inches (610 mm) max deep on the rear wall, 18 inches (455 mm) min from WC centerline to lavatory side edge, if WC clearance depth is 66 inches (1675 mm) min	Direct	Set WC at 405–455 mm in a 1525 × 1420 mm zone; seat 380–485 mm (not Accessible 430–485 mm)	Verified
1103.11.2.4.6	Flush control	Hand-operated or automatic; hand-operated 309; on the open side of the water closet	Type A required WC	None stated	Direct	Place the flush on the open side in the 308/309 envelope	Verified
1103.11.2.5.1 / 607.2	Bathtub clearance with removable cabinetry	Tub complies with 607: clearance the length of the tub × 30 inches (760 mm) min depth; + 12 inches (305 mm) beyond a permanent head-end seat. Seat per 610. Controls, 59-inch (1500 mm) hand shower, 120°F (49°C) water	Type A required bathtub	Countertops/cabinetry at one end of the clearance if removable, floor finish continues, and surrounding walls are finished. Grab bars are blocking (1103.11.1), not 607.4 bars in place	Direct	Hold a 760 mm tub clear; show removable end cabinetry; back for 607.4 bars	Verified
1103.11.2.5.2 / 608.2	Shower with removable cabinetry	Shower complies with 608 (transfer 36 × 36 inches (915 × 915 mm) with new 52 × 36 inches (1320 × 915 mm) clear; standard roll-in 60 × 30 inches (1525 × 760 mm) with 60 × 30 inches (1525 × 760 mm) clear; alternate roll-in 60 × 36 inches (1525 × 915 mm)). Hand shower required (608.5 Accessible/Type A). Threshold 1/2 inch (13 mm)	Type A required shower	At 608.2.2 standard roll-in, lavatory/counter/cabinetry permitted at one end of the clearance if removable, floor finish continues, and walls are finished. Grab bars/seats are blocking	Direct	Prefer a 1525 × 760 mm roll-in; show removable end cabinetry; back for 608.3 bars and 610 seat	Verified
604.5.1–604.5.2	Future WC grab-bar geometry (blocking)	Side horizontal 42 inches (1065 mm) min, 12 inches (305 mm) max from rear wall, extending 54 inches (1370 mm) min; vertical 18 inches (455 mm) min at 39–41 inches (990–1040 mm) AFF and from rear wall — vertical component not required to be blocked (1103.11.1 Ex. 3). Rear 36 inches (915 mm) min, 6 inches (150 mm) max from side wall, extending 42 inches (1065 mm) min	Type A WC blocking	Rear 24 inches (610 mm) min centered where lavatory overlap exception applies	Direct	Block for the 1065 mm side horizontal and 915 mm rear bar; skip vertical side-bar blocking	Verified
609.2–609.3 / 609.8	Grab-bar product (when installed)	Circular OD 1 1/4–2 inches (32–51 mm) ; wall clearance 1 1/2 inches (38 mm) ; 250 pounds (1112 N)	Future bars	Adult 609.4 height unverified in the Chapter 6 extract	External verification	Size blocking for 32–51 mm bars at 38 mm off the wall and 1112 N; confirm 609.4 AFF later	Verify source

8. Kitchens

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type A status	Design action	Source confidence
1103.12.1.1–1103.12.1.2	Kitchen work-aisle clearance	40 inches (1015 mm) min between opposing bases/counters/appliances/walls. U-shape (three contiguous sides): 60 inches (1525 mm) min	Type A kitchens	U-shape with an island may use the 1015 mm aisle	Direct	Hold 1015 mm (1525 mm if U-shaped)	Verified
1103.12.3–1103.12.3.2	Work surface	At least one section 30 inches (760 mm) min length. Forward CFS + 306 knee/toe. Height 34 inches (865 mm) max AFF	Type A kitchens with a cooktop or conventional range	Not required without cooktop/conventional range. Removable cabinetry permitted (remove without replacing the work surface; floor and walls finished). Adjustable/relocatable 29–36 inches (735–915 mm) AFF without cutting the counter	Direct	Provide a 760 mm × 865 mm max work surface with removable base and 306 clearance	Verified
1103.12.4.1–1103.12.4.4	Sink	Forward CFS + 306. Front 34 inches (865 mm) max AFF to the higher of rim or counter. Faucets 309. Pipes insulated	Type A kitchen sink	Knee/toe at only one bowl of a multi-bowl sink; removable cabinetry permitted; parallel centered CFS permitted where no cooktop/range and at wet bars. Adjustable 29–36 inches (735–915 mm) if rough-in allows 29 inches (735 mm) connections	Direct	Specify an 865 mm max sink with removable base (or parallel CFS if no range)	Verified
1103.12.5.1–1103.12.5.5	Appliance CFS and approach	CFS parallel or forward at each appliance. Dishwasher door shall not obstruct its CFS or an adjacent sink. Cooktop forward needs 306 and insulated underside; parallel CFS centered. Oven door shall not obstruct its CFS; side-hinged ovens get a countertop on the latch side; bottom-hinged on one side. Controls shall not require reaching across burners. Appliance controls comply with 1103.9	Kitchen appliances where provided	Appliance doors/latches exempt from 309.4; open bottom-hinged doors exempt from 309.3	Direct	Park a 1320 × 760 mm CFS at each appliance; keep oven swing clear	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type A status	Design action	Source confidence
1103.12.5.6	Refrigerator/freezer	At least 50 percent of freezer shelves including the freezer bottom 54 inches (1370 mm) max AFF at maximum shelf positions. Parallel CFS; centerline offset 24 inches (610 mm) max from the appliance centerline	Combination refrigerator/freezer	None stated	Direct	Specify ≥ 50% of the freezer at or below 1370 mm with CFS offset ≤ 610 mm	Verified

9. Laundry equipment

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type A status	Design action	Source confidence
1103.10 / 611.2–611.4	Laundry CFS, reach, height	Parallel CFS; top-load centered; front-load offset 24 inches (610 mm) max. Operable parts 308/309; 308.3.2 obstruction 36 inches (915 mm) max. Top-load door 36 inches (915 mm) max AFF; front-load opening 15–36 inches (380–915 mm) AFF	Washers and dryers in the Type A unit	None stated	Conditional	If in-unit laundry exists, provide a 1320 × 760 mm CFS and 380–915 mm openings	Verified

10. Windows and storage

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type A status	Design action	Source confidence
1103.13.1–1103.13.2	Operable windows	Natural-ventilation windows: 309.2 CFS and 309.3 reach. Emergency-escape windows: 309.2 CFS. (Type A does not charge 506.2 opening-force newtons)	Operable windows in Type A units	Kitchen and bathroom windows	Direct	Provide a 1320 × 760 mm CFS at the ventilation/escape window and keep locks in the 308 envelope	Verified
1103.14 / 905.2–905.4	Storage	At least one of each type: CFS, 308 reach, 309 operable parts	Storage other than kitchen cabinets	Kitchen cabinets exempt	Direct	Put one rod/shelf of each type in the 380–1220 mm range with a CFS	Verified

11. In-unit ramps, elevators and platform lifts

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type A status	Design action	Source confidence
1103.6 / 405.2–405.8	Ramp geometry	Slope steeper than 1:20 and not steeper than 1:12. Cross slope 1:48. Width 36 inches (915 mm) min. Rise 30 inches (760 mm) max per run. Landings 60 inches (1525 mm) min; direction-change 60 × 60 inches (1525 × 1525 mm) . Handrails where rise > 6 inches (150 mm)	Ramps inside the Type A unit	Table 405.2 flattened: no cell adopted	Conditional	If a unit ramp exists, hold 1:12, 915 mm and 1525 mm landings	Verified
1103.7 / Table 407.4.1	Destination-elevator car size	Elevators within the unit comply with 407, 408 or 409	Elevators inside the Type A unit	Flattened Table 407.4.1: no cell adopted . Fn 1 7/8 inch (16 mm) ; fn 2 36-inch (915 mm) door with 60-inch (1525 mm) turning diameter	External verification	Confirm car size from a readable table	Verify source
1103.7 / 408.4.1 / 409.4.1.1	LULA and new private elevator	LULA: width 42 inches (1065 mm) min, area 15.75 square feet (1.46 m²) . New private-residence elevator: 36 × 52 inches (915 × 1320 mm)	LULA or private elevator in the unit	Existing LULA and 409.4.1.2 36 × 48 inches (915 × 1220 mm)	Conditional	If provided, hold the new-building car size	Verified
1103.8 / 410.5.1.1	New platform-lift size	Opposite-end new: 36 × 52 inches (915 × 1320 mm) . Adjacent-side new: 42 × 60 inches (1065 × 1525 mm) . End door 32 inches (815 mm) min; side door 42 inches (1065 mm) min; open 20 seconds min	Platform lifts inside the Type A unit	Incline 36 × 48 inches (915 × 1220 mm) ; existing opposite-end 36 × 48 inches (915 × 1220 mm)	Conditional	If a lift is used, hold 915 × 1320 mm new opposite-end	Verified

12. Communication-feature overlay

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type A status	Design action	Source confidence
1106.2–1106.4 / 702.1	Visible/audible notification	Unit smoke audible per NFPA 72. Building alarm wiring extended into the unit. Visibles, where provided, comply with 702 (dwelling visibles may use 1106.2–1106.4.4). Same appliances may serve both; not used for other purposes	Type A units also scoped for communication features	NFPA 72 spacing not in Chapter 7 extract	Conditional	Extend alarm wiring and provide 702/1106 visibles; this does not replace 1103 geometry	Verified
1106.5.1–1106.5.2	Doorbell and visitor ID	Hard-wired doorbell; public-side button; audible in the unit; sleeping-area visible-signal deactivation. Visual ID without opening the door; peepholes 180-degree min	Comms-unit primary entrance	None stated	Conditional	Specify a hard-wired doorbell and 180° viewer	Verified
1106.6–1106.7	Remote entry voice/TTY	Public interface supports voice and TTY; unit interface has a telephone jack supporting voice and TTY	Remote visitor communication	None stated	Conditional	If a lobby video-phone exists, provide a TTY-capable jack	Verified

13. Project-use controls

- Use **Verified** rows as design-release geometry for Type A apartment typicals.
- Do not use **Verify source** rows (flattened door/elevator/ramp/dispenser tables; 609.4 height) until a readable source is confirmed.
- Do not mix new **67 inches (1700 mm)** turning or **52 inches (1320 mm)** CFS with existing values on the same Direct typical.
- Do not install Accessible-unit grab bars in place as the Type A typical; draw removable bases and blocking.
- Do not apply this matrix to transient R-1 Accessible guestrooms.

14. Coverage summary

- Inventory scope: numbered Chapter 11 code (1103, 1106 overlay, charged 1104.11.1 exceptions), exceptions, charged companion paragraphs/footnotes from Chapters 3–9. INSIGHTS, figures and commentary excluded. Type C omitted. Public compartments, children’s toilets, urinals, drinking fountains and Chapter 10 omitted.
- Total independently checkable numeric records: **236**
- Verified: **214**
- Verify source: **22**

Top-level section	Numeric records
1103 local + 1106 overlay	42
303–309 building blocks	52
403–404 routes/doors (paragraphs + footnotes; tables held)	46
405 / 407–410 ramps and vertical	26
506 / 606–611 / 905	70

15. Unresolved-source register

Affected table / clause	Why unverified	Control note
Table 404.2.3.2	Flattened swinging-door manoeuvre blob	Do not adopt reconstructed cells; footnotes 1–5 remain Verified
Table 404.2.3.3	Flattened sliding/folding blob	Confirm from a readable table
Table 404.2.3.4	Flattened doorway-without-door blob	Confirm from a readable table
Table 405.2	Flattened existing-ramp blob	New ramps use paragraph 1:12
Table 407.4.1	Flattened elevator-car blob	Footnotes 1–2 remain Verified
Table 603.6	Flattened dispenser/dryer blob (only if a dispenser is specified)	Confirm from a readable table
609.4	Adult grab-bar height paragraph missing/garbled	Confirm AFF from a readable 609.4; do not back-fill
Figure 304.3.1.1	Shaded overlap zone	Treat as a figure dependency
702 / NFPA 72	No millimetre spacing in Chapter 7	Visible layout remains NFPA 72
ASME A17.1 / BHMA A156	Named only	Do not import unstated values