

ICC A117.1 Chapter 11 Dwelling Units and Sleeping Units — Type B Dimensional Requirements Matrix (2017)

1. Document metadata and use limitation

- **Project basis:** Mixed-use tall building containing Group R-1 (hotel) with Group R-2 residential sharing podium, parking and routes. An occupied floor is stated to be more than 23 m above the relevant reference level. This matrix filters ICC A117.1 Chapter 11 for **Type B units** (Section 1104).
- **Unit type:** Type B (1104). Accessible (1102) and Type A (1103) interiors are omitted from this file. Type C (1105) is omitted.
- **Deliverable tier:** Project-use matrices in Sections 4–13 (design-check rows, not pasted inventory), plus project-use controls, a coverage summary and an unresolved-source register.
- **Code/source basis:** ICC A117.1 (2017), Chapter 11, source file Reference\2017 ICC A117_1 Accessible and Usable Buildings and Facilities\source_reference\Chapter_11 – DWELLING UNITS AND SLEEPING UNITS.txt. Companion numbers inlined from the attached 2017 Chapter 1–10 source_reference extracts where 1104 charges those sections.
- **Extraction audit:** Internal inventory: **198** independently checkable numeric records (**186** Verified, **12** Verify source). Unresolved OCR/flattened tables are listed in the register and are not design-release values.
- **Inspecting model:** Cursor Grok 4.6.
- **Prepared:** 2026-08-28.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped compliance statement, accessibility consultant report, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Scoping companion:** Counts and which units must be Type B are **SBC 201 Chapter 11**. R-1 Type B applies only where units are intended to be occupied as a residence. This file does not import SBC quotas.
- **Edition gap:** SBC 201 Chapter 35 lists **ICC A117.1—09**. Charging SBC 1102.1 has no year. This extract is **2017**. Type B interiors already use reduced CFS and existing-style route exceptions; do not “upgrade” them to Accessible/Type A 2017 turning or 404 manoeuvring. **Do not treat 2017 millimetres as the legal SBC minimum.**

Scope and assumptions

1. Type B is Direct for R-2 apartments. R-1 hotel Type B is Conditional unless units are occupied as a residence.
2. New construction is assumed for building-wide elements. Type B **interior** route exceptions in 1104.4.1 already print existing-style 180°/90°/passing numbers; those printed 1104 exceptions are Direct for Type B interiors.
3. **Do not** draw Type B interiors with Accessible/Type A 404 latch-side manoeuvre or 304 room-wide turning.
4. Type B CFS is **48 × 30 inches (1220 × 760 mm)** (1104.1.1), not 2017 new 52 in.
5. Interior user-passage clear opening is **31 3/4 inches (805 mm)**. Primary entrance still charges 404, with Type B front-approach **48 inches (1220 mm)** exceptions.
6. FIGURE captions are dependencies. Flattened <table> blobs are not reconstructed as Verified cells.

2. Legends

Applicability

Status	Meaning
Direct	Expected to govern Type B unit interiors once geometry is confirmed (R-2 typical).
Conditional	Governs only if the stated feature, R-1 residential occupancy, existing-building branch, in-unit ramp/lift/elevator, or communication overlay exists.
Not typical	Unrelated unit-type-only rule; omitted unless the gap register already opened that use.
External verification	A figure is missing, a flattened table is unread, or AHJ/edition must be confirmed first.

Source confidence

Status	Meaning
Verified	Unambiguous mandatory source text or readable footnote after a table blob.
Verify source	OCR, flattened table, page-split, or footnote attachment is unresolved. Not a design-release value.

3. Project decision and gap register

Decision / gap	Current project basis	Why it controls Chapter 11 application	Required project action
A117.1 edition lock	Extracted edition is 2017 ; SBC 201 Chapter 35 lists A117.1—09	Type B CFS and door width are in 1104; do not import Accessible 2017 52 in CFS or 67 in turning into Type B interiors	AHJ to lock 2009 vs 2017 for common/public routes; keep Type B interiors on 1104
R-1 vs R-2	Mixed hotel + apartments	R-2 Type B is Direct. R-1 Type B only if units are occupied as a residence (SBC scoping — quotas not imported)	Freeze hotel operating model before applying this matrix to guestrooms
New vs existing	New construction assumed	1104.4.1 already prints existing-style pinch/180°/90°/passing as Type B exceptions; those are Direct for Type B interiors. Primary-door Table 404.2.3.2 new vs existing still splits	Do not mix Accessible new 403.5.3.1 90° options into Type B unit corridors
Manoeuvre inside the unit	Type B interiors are reduced	Interior user-passage doors are 1104.5.2 (31 3/4 inches (805 mm)), not full 404 manoeuvre	Do not draw 404 latch-side pads at bedroom/bath doors
Grab bars	Blocking only	1104.11.1 reinforcement; bars not in place	Draw blocking; do not install Accessible-unit grab bars as the Type B typical
Option A vs Option B baths	Unconfirmed	Either all baths Option A, or one bath Option B	Pick one strategy per typical and dimension it
AHJ / NOC	Unconfirmed	Stamped compliance cannot be concluded from this extract	Engage the qualified local accessibility consultant before design freeze

4. Unit accessible route and walking surfaces

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type B status	Design action	Source confidence
1104.2	Primary entrance location	Primary entrance on an accessible route from public and common areas; not to a bedroom unless it is the only entrance	Type B units	None stated	Direct	Place the Type B entry on the corridor accessible route	Verified
1104.3.1	Unit accessible-route extent	At least one accessible route shall connect all spaces and elements that are part of the unit and shall coincide with or be in the same area as the general circulation path	Type B interiors	Unfinished attics/basements. One allowed miss: a raised or sunken portion of a living/dining/sleeping room, or a mezzanine without plumbing fixtures or enclosed habitable space	Direct	Connect entry, bedrooms, living, kitchen and accessible-level baths; document any single raised/sunken/mezzanine miss	Verified
1104.3.2 / 1104.4	Route components and slope	Walking surfaces with slope not steeper than 1:20, plus doors, ramps, elevators and platform lifts	Type B accessible routes	Steeper walking surfaces become ramps (405)	Direct	Hold unit floors at 1:20; treat steeper runs as ramps	Verified
1104.4.1 / 403.5.1	Interior clear width with Type B pinch	Clear width complies with 403.5, except Type B may reduce to 32 inches (815 mm) min for 24 inches (610 mm) max length if reduced segments are separated by 48 inches (1220 mm) min length × 36 inches (915 mm) min width	Type B interior accessible routes	This printed exception uses the existing-style 48-inch (1220 mm) separator, not the new-building 52-inch (1320 mm) separator	Direct	Hold Type B corridors at 915 mm; if a pinch is used, separate with 1220 × 915 mm	Verified
1104.4.1 Exceptions 2–3	Type B 180-degree turn	Around an object < 48 inches (1220 mm) wide: 42 inches (1065 mm) approaching, 48 inches (1220 mm) during, 42 inches (1065 mm) leaving; or approach/leave 36 inches (915 mm) if the turn is 60 inches (1525 mm) min	180-degree turns on the Type B route	These are the Type B printed exceptions (existing-style), Direct for Type B interiors	Direct	Dimension Type B 180° turns to 42/48/42 or 36/60/36; do not require Accessible new 43 in or 52 in object rules inside the unit	Verified
1104.4.1 Exception 4	Type B 90-degree turn	Clear widths approaching and leaving a 90-degree turn 36 inches (915 mm) minimum	90-degree turns on the Type B route	Do not apply Accessible new 403.5.3.1 40/38/44 in option set inside Type B units	Direct	Hold Type B 90° turns at 915 mm both legs	Verified
1104.4.1 Exception 5	Type B passing space	Where width < 60 inches (1525 mm) , passing at 200 feet (61 m) max: 60 × 60 inches (1525 × 1525 mm) or a T-turn per 304.3.2.2 with base/arms 48 inches (1220 mm) min beyond the intersection	Long Type B routes under 1525 mm	304.3.2.2 is the existing T-turn (60-inch (1525 mm) square, arms/base 36 inches (915 mm))	Conditional	Add a 1525 mm passing bay on any Type B corridor longer than 61 m under 1525 mm	Verified
1104.4.2 / 303.2–303.4	Change in level	Vertical 1/4 inch (6.4 mm) max; 1/4–1/2 inch (6.4–13 mm) beveled 1:2; above 1/2 inch (13 mm) by ramp 405 or curb ramp 406	Type B walking surfaces	Exterior impervious deck/patio/balcony may be 4 inches (100 mm) max below the adjacent interior floor	Direct	Limit interior joints to 13 mm at 1:2; balcony drop ≤ 100 mm if impervious	Verified

5. Doors and doorways

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type B status	Design action	Source confidence
1104.5.1 / 404.2.2	Primary-entrance clear opening	Primary entrance complies with 404: clear opening 32 inches (815 mm) min, door face to stop at 90°	Type B primary entrance door	Interior user-passage doors use 1104.5.2, not this row	Direct	Specify 815 mm clear at the unit entry only	Verified
1104.5.1 Exceptions 2–4	Type B primary-door front manoeuvre	Front-approach push on swinging doors, front approach on sliding/folding doors, and front approach at doorways without doors: perpendicular dimension 48 inches (1220 mm) minimum	Type B primary entrance	Storm/screen doors exempt from 404.2.5. Remainder of 404 manoeuvre at the primary door still charges Table 404.2.3.2 (flattened: no other cell adopted). Readable 404.2.3.2 footnotes 1–4 still apply at the primary door	Direct	Hold 1220 mm perpendicular on the push/front side of the Type B entry; do not import reconstructed table cells for other approaches	Verify source
1104.5.2.1	Interior user-passage clear opening	Doorways intended for user passage: clear opening 31 3/4 inches (805 mm) minimum, measured door face to stop at 90°	Interior Type B user-passage doors	Shower door assemblies exempt. This is not 404 manoeuvre and not 32 in (815 mm)	Direct	Specify 805 mm clear at bedrooms, baths and kitchens; do not draw 404 latch-side pads	Verified
1104.5.2.1.1	Double-leaf inactive hardware	If operable parts on an inactive leaf are > 48 inches (1220 mm) or < 15 inches (380 mm) AFF, the active leaf shall provide the 1104.5.2.1 clearance	Type B double-leaf user-passage doors	None stated	Conditional	Keep inactive-leaf hardware in 380–1220 mm or size the active leaf to 805 mm clear	Verified
1104.5.2.2 / 303	Interior thresholds	Thresholds comply with 303: 1/4 inch (6.4 mm) vertical; 1/2 inch (13 mm) at 1:2	Type B user-passage doorways	Exterior sliding doors 3/4 inch (19 mm) max, beveled not steeper than 1:2	Direct	Specify 13 mm max interior thresholds; 19 mm at 1:2 on exterior sliders	Verified
1104.5.2.3 / 404.3.3	Automatic user-passage doors	Automatic doors comply with 404.3: 32 inches (815 mm) clear in power-on and power-off	Power-operated interior Type B doors	BHMA A156 values not imported	Conditional	If an automatic interior door is used, keep 815 mm clear in both power states	Verified
1104.5.1 / 404.2.6	Primary-door hardware	Push/pull 15 pounds (66.7 N) max; rotational 28 inch-pounds (315 N-cm) max; hardware 34–48 inches (865–1220 mm) AFF	Type B primary entrance	Interior 1104.5.2 doors are not charged with full 404 hardware	Direct	Schedule entry levers 865–1220 mm AFF	Verified

6. Clear floor space and operable parts

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type B status	Design action	Source confidence
1104.1.1	Type B clear floor space	Clear floor spaces 48 inches (1220 mm) min length × 30 inches (760 mm) min width	Type B fixtures, appliances, laundry and controls that require a CFS	Do not use 2017 new 305.3.1 52 inches (1320 mm) inside Type B units	Direct	Park 1220 × 760 mm CFS at Type B fixtures and appliances	Verified
1104.1.2	Mailbox side reach	Mailboxes serving Type B units may use unobstructed side reach 54 inches (1370 mm) maximum AFF	Mailboxes serving Type B units	This is a Type B permission, not a 308.3.1 existing-element rule	Conditional	If unit mailboxes are provided, 1370 mm side reach is permitted	Verified
1104.9 / 309.3 / 308	Control height	Lighting, switches, receptacles, environmental controls, panelboards and security/intercom controls: height in a 308 reach range, with CFS per 1104.1.1. Unobstructed high 48 inches (1220 mm) / low 15 inches (380 mm)	Type B lighting, receptacles, environmental, panelboards, security/intercom	Plumbing fixture and appliance controls are not charged (Ex. 7–8). Dedicated receptacles; one of two-plus kitchen counter receptacles; corner counter ≤ 9 square feet (0.835 m²) ; floor receptacles; HVAC diffusers; ceiling-fan controls; appliance resets; redundant non-light controls. Kitchen/bath controls may sit over cabinets 36 inches (915 mm) max high × 25 1/2 inches (650 mm) max deep	Direct	Place switches and receptacles at 380–1220 mm; allow the 915 × 650 mm over-cabinet exception in kitchens/baths; do not force 309 on plumbing/appliance controls	Verified
1104.11.2.2 / 306	Knee and toe at fixtures	Fixture CFS may include 306 knee/toe: toe to 9 inches (230 mm) AFF, 25 inches (635 mm) max / 17 inches (430 mm) min; knee 9–27 inches (230–685 mm) AFF	Forward-approach Type B fixtures	Option A lavatory typical is parallel approach (no 306 required unless the 606 forward option is used)	Conditional	Apply 306 only where a forward Type B approach is used	Verified

7. Toilet and bathing facilities (blocking; Option A or B)

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type B status	Design action	Source confidence
1104.11	Bath applicability	Toilet and bathing fixtures comply with 1104.11	Fixtures on accessible levels of the Type B unit	Fixtures on levels not required to be accessible	Direct	Apply this section to the accessible-level bath(s)	Verified
1104.11.3	Option A or Option B	Either all toilet/bathing areas comply with Option A (1104.11.3.1), or one toilet/bathing area complies with Option B (1104.11.3.2)	Type B accessible-level baths	Pick one strategy; do not mix unlabelled	Direct	Freeze Option A (every bath) or Option B (one room) on the typical	Verified
1104.11.1	Grab-bar and seat blocking	Reinforcement for future 604.5 WC bars, 607.4 tub bars, and 608.3 / 608.2.1.3 / 608.2.2.3 / 608.2.3.2 shower bars and seats, where walls permit those installations	Water closets, tubs and showers on accessible levels	Powder room that is not the only lav/WC on the accessible level. Vertical WC side-bar component of 604.5 not required. Rear 24 inches (610 mm) min centered if 604.5.2 will not fit. Side 24 inches (610 mm) min, 12 inches (305 mm) max from rear wall, if a 42-inch (1065 mm) side bar will not fit. Swing-up bars per 1104.11.1.1 permitted in lieu. Shower seat blocking not required in compartments larger than 36 × 36 inches (915 × 915 mm)	Direct	Back WC/tub/shower walls for future bars; omit vertical side-bar blocking	Verified
1104.11.1.1	Swing-up grab-bar blocking	18 inches (455 mm) min from WC centerline to any side wall or obstruction (on the side opposite a side approach). Bar centered 15 3/4 inches (400 mm) from WC centerline, 28 inches (710 mm) min length from the wall, down position 33–36 inches (840–915 mm) AFF. Force per 609.8 250 pounds (1112 N)	Where swing-up blocking is used instead of a 42 in side bar	If the WC has a wall to the rear and one side, centerline 16–18 inches (405–455 mm) from the sidewall	Conditional	If swing-up blocking is used, hold 455 mm to the obstruction and 840–915 mm down height	Verified
1104.11.2.1	Bath door swing	Door shall not swing into any fixture CFS or clearance	Option A or B bathrooms	CFS beyond the door arc, excluding knee/toe under elements	Direct	Swing the door out or past a 1220 × 760 mm CFS	Verified
1104.11.3.1.1	Option A lavatory	Parallel-approach CFS centered on the lavatory	Option A lavatories	Not more than one lavatory per combined toilet/bathing area. Powder-room lav+WC exemption. Forward 606.3/606.4 lavatory with 1104.1.1 CFS and removable cabinetry permitted	Direct	Center a 1220 × 760 mm parallel CFS on the Option A lavatory	Verified
1104.11.3.1.2.1–1104.11.3.1.2.2.4	Option A water closet	Centerline 16–18 inches (405–455 mm) from one side of the required clearance. Clearance 48 inches (1220 mm) min wide × 56 inches (1420 mm) min deep; 66 inches (1675 mm) min deep where a forward approach is provided. Vanity/obstruction 24 inches (610 mm) max deep may overlap if remaining WC width is 33 inches (840 mm) min	Option A water closets	Clearance complying with Type A 1103.11.2.4.2–1103.11.2.4.4 (60 × 56 inches (1525 × 1420 mm) , 24 in lavatory overlap at 66 in depth) is permitted	Direct	Set WC at 405–455 mm in a 1220 × 1420 mm zone (1675 mm if forward approach)	Verified
1104.11.3.1.3.1	Option A parallel bathtub	Clearance 60 inches (1525 mm) min length × 30 inches (760 mm) min width in front. 606 lavatory permitted in the clearance. 1104.11.3.1 lavatory at one end permitted if a 48 × 30 inches (1220 × 760 mm) clearance remains in front of the tub	Option A parallel-approach tub	None stated	Direct	Hold 1525 × 760 mm in front of a parallel Option A tub	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type B status	Design action	Source confidence
1104.11.3.1.3.2	Option A forward bathtub	Clearance 60 inches (1525 mm) min length × 48 inches (1220 mm) min width in front. A water closet and lavatory permitted in the clearance at one end	Option A forward-approach tub	None stated	Direct	Hold 1525 × 1220 mm in front of a forward Option A tub	Verified
1104.11.3.1.3.3	Option A/B shower (only bathing fixture)	If the shower is the only bathing facility: 36 × 36 inches (915 × 915 mm) min. Clearance 48 inches (1220 mm) min perpendicular from the control wall × 30 inches (760 mm) min from the shower face	Transfer shower as the only bath	30 × 44 inches (760 × 1120 mm) permitted. Removable shower door assembly permitted	Direct	If a shower-only Type B bath, hold 915 × 915 mm with a 1220 × 760 mm clear	Verified
1104.11.3.2.1.1	Option B lavatory height	Front of the lavatory 34 inches (865 mm) max AFF to the higher of rim or counter, plus Option A lavatory CFS	Option B lavatory	Option B fixtures must be in a single toilet/bathing area	Direct	Specify an 865 mm max lavatory with a centered parallel CFS	Verified
1104.11.3.2.3.1	Option B bathtub	Clearance 48 inches (1220 mm) min perpendicular from the control end × 30 inches (760 mm) min width in front	Option B bathtub	Shower may be used instead (1104.11.3.1.3.3)	Direct	Hold 1220 × 760 mm in front of the Option B tub, measured from the control end	Verified

8. Kitchens

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type B status	Design action	Source confidence
1104.12.1.1–1104.12.1.2	Kitchen work-aisle clearance	40 inches (1015 mm) min between opposing bases/counters/appliances/walls. U-shape: 60 inches (1525 mm) min	Type B kitchens	U-shape with an island may use the 1015 mm aisle	Direct	Hold 1015 mm (1525 mm if U-shaped)	Verified
1104.12.2.1	Sink CFS	Parallel-approach CFS centered on the sink bowl, sized per 1104.1.1 (48 × 30 inches (1220 × 760 mm))	Type B kitchen sink	Forward sink per 1103.12.4.1 permitted	Direct	Center a 1220 × 760 mm parallel CFS on the sink; do not require Type A knee space unless the forward option is used	Verified
1104.12.2.2–1104.12.2.4	Appliance CFS	Parallel or forward CFS at dishwasher, cooktop and oven. Dishwasher/oven doors shall not obstruct their CFS. Cooktop forward needs 306 and insulated underside; parallel CFS centered	Kitchen appliances where provided	None stated	Direct	Park a 1220 × 760 mm CFS at each appliance; keep door swings clear	Verified
1104.12.2.5.2–1104.12.2.5.3	Refrigerator CFS offset	Forward approach: CFS centerline offset 15 inches (380 mm) max from the appliance centerline. Parallel approach: offset 24 inches (610 mm) max	Refrigerator/freezer	None stated	Direct	Align the 1220 × 760 mm CFS within 380 mm (forward) or 610 mm (parallel) of the fridge centerline	Verified
1104.12.2.6	Trash-compactor CFS	Parallel or forward CFS	Trash compactor where provided	None stated	Conditional	If a compactor is provided, park a 1220 × 760 mm CFS	Verified

9. Laundry equipment

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type B status	Design action	Source confidence
1104.10.1	Laundry clear floor space	CFS at each washer and dryer (1104.1.1 48 × 30 inches (1220 × 760 mm)). Parallel approach at top-load. Forward or parallel at front-load	In-unit laundry	611 height/operable-part millimetres are not charged by 1104.10	Conditional	If in-unit laundry exists, provide a 1220 × 760 mm CFS (parallel at top-load)	Verified

10. In-unit ramps, elevators and platform lifts

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type B status	Design action	Source confidence
1104.6 / 405.2–405.8	Ramp geometry	Slope steeper than 1:20 and not steeper than 1:12. Cross slope 1:48. Width 36 inches (915 mm) min. Rise 30 inches (760 mm) max per run. Landings 60 inches (1525 mm) min; direction-change 60 × 60 inches (1525 × 1525 mm) . Handrails where rise > 6 inches (150 mm)	Ramps inside the Type B unit	Table 405.2 flattened: no cell adopted	Conditional	If a unit ramp exists, hold 1:12, 915 mm and 1525 mm landings	Verified
1104.7 Exception	Private-residence elevator car	Private residence elevators: clear floor 48 inches (1220 mm) min length × 36 inches (760 mm) min width	Private residence elevator serving the Type B unit	Full 407/408/409 otherwise. Table 407.4.1 flattened: no destination-car cell adopted . Note: the printed width millimetre is (760 mm) beside 36 inches	Direct	If a private elevator is used, hold 1220 × 760 mm clear inside the car	Verified
1104.8 Exception	Platform-lift size	Lifts with a single door or opposite-end doors: 36 inches (915 mm) min width × 48 inches (1220 mm) min length	Platform lifts inside the Type B unit	Full 410 otherwise (new opposite-end 36 × 52 inches (915 × 1320 mm))	Conditional	If a Type B lift exception is used, hold 915 × 1220 mm	Verified

11. Communication-feature overlay

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Type B status	Design action	Source confidence
1106.2–1106.4 / 702.1	Visible/audible notification	Unit smoke audible per NFPA 72. Building alarm wiring extended into the unit. Visibles, where provided, comply with 702 (dwelling visibles may use 1106.2–1106.4.4)	Type B units also scoped for communication features	NFPA 72 spacing not in Chapter 7 extract	Conditional	Extend alarm wiring and provide 702/1106 visibles; this does not replace 1104 geometry	Verified
1106.5.1–1106.5.2	Doorbell and visitor ID	Hard-wired doorbell; public-side button; audible in the unit; sleeping-area visible-signal deactivation. Visual ID without opening the door; peepholes 180-degree min	Comms-unit primary entrance	None stated	Conditional	Specify a hard-wired doorbell and 180° viewer	Verified
1106.6–1106.7	Remote entry voice/TTY	Public interface supports voice and TTY; unit interface has a telephone jack supporting voice and TTY	Remote visitor communication	None stated	Conditional	If a lobby video-phone exists, provide a TTY-capable jack	Verified

12. Project-use controls

- Use **Verified** rows as design-release geometry for Type B apartment typicals.
- Do not use **Verify source** rows (flattened Table 404.2.3.2 cells beyond the printed 1104.5.1 48 in exceptions; Tables 405.2 and 407.4.1) until a readable source is confirmed.
- Do not draw Accessible/Type A 404 latch-side manoeuvre, 32 in interior doors, 52 in CFS, or 67 in room-wide turning inside Type B units.
- Grab bars are **blocking**, not in place.
- R-1 hotel application remains Conditional until residential occupancy is confirmed.

13. Coverage summary

- Inventory scope: numbered Chapter 11 code (1104, 1106 overlay), exceptions, charged companion paragraphs/footnotes from Chapters 3–6 and 9. INSIGHTS, figures and commentary excluded. Type C omitted. Accessible/Type A-only 804 kitchens, 611 height, 1102.15 beds and full 404 interior manoeuvre omitted as not charged.
- Total independently checkable numeric records: **198**
- Verified: **186**
- Verify source: **12**

Top-level section	Numeric records
1104 local + 1106 overlay	78
303 / 306 / 308 / 309.3	22
403.5 / 404 primary (paragraphs + footnotes; tables held)	38
405 / 407–410 ramps and vertical	24
604.5 / 606–609 blocking geometry	36

14. Unresolved-source register

Affected table / clause	Why unverified	Control note
Table 404.2.3.2 (primary door, non-front approaches)	Flattened swinging-door blob	1104.5.1 Exceptions 2–4 lock front perpendicular at 48 inches (1220 mm) ; do not adopt other reconstructed cells
Table 405.2	Flattened existing-ramp blob	New ramps use paragraph 1:12
Table 407.4.1	Flattened destination-elevator blob	Type B private-residence exception 48 × 36 inches (1220 × 760 mm) is Verified from 1104.7
609.4	Adult grab-bar height paragraph missing/garbled	Blocking length/location from 604.5 / 1104.11.1 is Verified; confirm AFF from a readable 609.4 when bars are installed
702 / NFPA 72	No millimetre spacing in Chapter 7	Visible layout remains NFPA 72
ASME A17.1 / BHMA A156	Named only	Do not import unstated values
1104.7 Exception SI	Source prints 36 inches (760 mm) for private-elevator width	Keep the published pair; do not “correct” to 915 mm