

SBC 201 Chapter 11 Accessibility — Group B Office and Amenities Dimensional Requirements Matrix (2024)

1. Document metadata and use limitation

- **Project basis:** Mixed-use tall building containing Group B (office and amenities) with Group R-1 hotel and Group R-2 residential sharing podium, parking and routes. An occupied floor is stated to be more than 23 m above the relevant reference level. This matrix filters Chapter 11 for the **Group B office and amenity** portion.
- **Deliverable tier:** Project-use matrices in Sections 1–16 (design-check rows, not pasted inventory), plus a coverage summary and unresolved-source register. The full row inventory is not published.
- **Code/source basis:** SBC 201 (2024), Chapter 11, source file Reference\SBC 201 2024\source_reference\Chapter_11 – ACCESSIBILITY.txt.
- **Extraction audit:** Internal inventory: **276** independently checkable numeric records (**192** Verified, **84** Verify source). Unresolved OCR is listed in the register and is not a design-release value.
- **Model:** Cursor Grok 4.6.
- **Prepared:** 2026-08-28.
- **Status:** Source-only architectural advisory matrix for design coordination. It is not a stamped compliance statement, accessibility consultant report, SCD NOC, SBPS approval, legal opinion, or permission to construct.
- **Outbound-source rule:** No value in this matrix has been imported from ICC A117.1, Chapter 10, Chapter 9, Section 403, Chapter 30, SBC 701, SBC 901, HUD/FHAG, ADA, commentary examples, or the chapter summary. Where Chapter 11 sends the user elsewhere, this matrix records the dependency without supplying the outbound value.

Scope and assumptions

1. Group B and high-rise / mixed-use status are project statements, not independently verified classifications.
2. “Amenities” are a project statement. Dining, assembly, recreation, locker rooms, food-service and family toilets are treated as **Conditional** unless the amenity exists on drawings.
3. The mixed-use podium with Group R-1 and Group R-2 is a project statement. Shared routes, parking, EV and recreation must be assigned to an occupancy before a row is used as Direct.
4. The exact AHJ/permit pathway, project stage and SCD NOC status are unconfirmed; therefore this matrix does not conclude compliance.
5. Group B has **no** dwelling/sleeping-unit mix under Section 1108. Accessible / Type A / Type B unit quotas live in the companion R-1 and R-2 Chapter 11 matrices.
6. Automatic sprinkler protection is not selected in this chapter extract. Chapter 11 does not branch office scoping on NFPA 13 versus 13R.
7. Occupant load, parking counts/types, EV provision, amenity program and tenant count are unconfirmed.
8. Chapter 11 is **scoping**. Technical millimetre geometry for accessible routes, doors, toilets, counters and work surfaces is ICC A117.1. Charging **1102.1** names ICC A117.1 with **no edition year**. Neither commentary year is adopted as a charging substitution.
9. All eight appended tables are concatenated OCR. No reconstructed cell is adopted as a design-release value. Affected project-use rows are **Verify source**.
10. Do not apply R-2 **2 percent** parking, the 1107.2 R-2 EV exemption, or R-1 Accessible-guestroom quotas to Group B office parking or office EV.

2. Legends

Applicability

Status	Meaning
Direct	Expected to govern the stated Group B office/amenity basis, subject to confirmed geometry and design data.
Conditional	Governs only when the stated feature, use, occupant load or mixed-use/podium condition exists.
Not typical	Unrelated occupancy-only rule; omitted from this deliverable unless the gap register already opened that use.
External verification	Chapter 11 points to another section/code/standard, or the project/AHJ basis must be confirmed before use.

Source confidence

Status	Meaning
Verified	Requirement and any stated numeric value were checked against unambiguous mandatory Chapter 11 source text.
Verify source	OCR, flattened table, page-split, or footnote attachment is unresolved. Not a design-release value.

3. Project decision and gap register

Decision / gap	Current project basis	Why it controls Chapter 11 application	Required project action
ICC A117.1 edition	Charging 1102.1 has no year; General Comments name 2009; commentary discusses 2017	Controls turning spaces, clear floor space, door manoeuvring, toilet and counter geometry	AHJ/code consultant to lock the referenced edition; do not silently switch editions
Office occupant load	Unconfirmed	Table 1105.1.1 lists Group B ; mixed-use footnote uses the most restrictive listed load among A/B/M/R-1	Freeze occupant loads by occupancy before power-door design
Amenity program	Unconfirmed gym, F&B, assembly, locker rooms, retail	Opens 1109 dining/assembly, 1110.2.1 family toilets, 1110.13 food service, 1111.3 recreation	Freeze amenity schedule by room and occupancy served
Mixed-use Type B on the same structure	R-2 Type B units stated on the same building	1104.1 vehicular-way exception does not apply to buildings containing or serving Type B units	Provide a pedestrian accessible route from every applicable arrival point
Parking facility split	Unconfirmed shared garage	Group B uses Table 1106.2 via 1106.2, not 1106.3 residential items; calculate each parking facility separately	Produce a parking schedule by facility and occupancy served (office, hotel, residential)
EV charging	Unconfirmed	1107.2 exception is R-2, R-3, R-4 only — office/public EV is not exempt	If office or public chargers exist, apply 1107.2.1 / 1107.2.2
Recreation serving which occupancy	Unconfirmed shared pool/gym	Office/hotel recreation uses 1111.3 (all facilities accessible). R-2 Type A/B uses 1111.2.2 (25% / ≥ 1)	Map every recreational facility to the occupancies it serves

Decision / gap	Current project basis	Why it controls Chapter 11 application	Required project action
Health-care tenants	Unconfirmed	1104.4 Exception 1 does not apply to stories containing offices of health care providers (Group B or I)	If clinics are in the podium, do not use the 279 m² story-skip in any event
Occupied roof / amenities	Unconfirmed	1104.4 requires an accessible route to each accessible story, mezzanine and occupied roof; elevator high-rise does not use the 279 m² skip	Show an accessible route to office floors, amenity floors and any occupied roof
NOC / accessibility consultant	Unconfirmed	Technical A117.1 geometry, assisted-evacuation and SCD acceptance cannot be concluded from Chapter 11 scoping alone	Engage the qualified local accessibility/fire consultants before design freeze

4. Scoping versus technical standard

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
1101.1	Chapter scope	This chapter controls design and construction of facilities for accessibility	All facilities in scope	None stated	Direct	Treat Chapter 11 as the scoping document for office floors, amenities and the site elements that serve them	Verified
1102.1	ICC A117.1	Accessible in accordance with this code and ICC A117.1 (no year)	All required accessible facilities	None stated	External verification	Lock the A117.1 edition with the AHJ; do not import millimetre geometry here	Verified
1110.1	Other features	Accessible building features and facilities shall be provided in accordance with 1110.2 through 1110.16	Features listed in 1110	Accessible / Type A / Type B units comply with ICC A117.1 Chapter 10 (units are not this occupancy)	Direct	Apply 1110 to office toilets, kitchens, counters, storage and operable parts	Verified

5. General applicability and employee work areas

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
1103.1	Default accessibility	Sites, buildings, structures, facilities, elements and spaces, temporary or permanent, shall be accessible	All construction	Only to the extent permitted by 1103.2 / 1104–1112	Direct	Assume accessible unless a numbered exception is proven	Verified
1103.2.2	Employee work areas	Approach, enter and exit plus 907.5.2.3.1, 1009 and 1104.3.1 only	Employee work areas	Portions < 28 m² and ≥ 175 mm essential level change exempt from all requirements (not courtroom stations)	Direct	Require an accessible route to each workstation; do not fully fit-out cubicle interiors. Keep visible alarm and accessible MOE outbound	Verified
1104.3.1	Work-area circulation	Common-use circulation paths within employee work areas shall be accessible routes	Employee work areas	Ex. 1: paths in work areas < 100 m² defined by permanent partitions/furnishings. Ex. 2: equipment-integral paths. Ex. 3: fully weather-exposed exterior work areas	Direct	Keep an accessible route through open office floors; small defined workstations may skip the path through the station	Verified
1103.2.9	Equipment spaces	Spaces frequented only by service personnel for maintenance, repair or occasional monitoring of equipment are not required to comply with this chapter	Service-only equipment spaces	None stated	Direct	Do not force an accessible route into elevator pits, penthouses or typical MEP rooms	Verified
1103.2.7	Limited-access spaces	Spaces accessed only by ladders, catwalks, crawl spaces, freight elevators or very narrow passageways are not required to comply with this chapter	Those access-only spaces	None stated	Direct	Exempt catwalks and crawl spaces; do not use this for ordinary office floors	Verified
1103.2.14	Walk-in coolers	Walk-in cooler and freezer equipment accessed only from employee work areas is not required to comply with this chapter	BOH coolers	Public-facing coolers still need operable parts / display on the public side	Conditional	Exempt amenity-kitchen walk-ins; keep F&B display coolers in the operable-parts package	Verified

6. Accessible routes and stories

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
1104.1	Site arrival route	At least one accessible route from transit, accessible parking, accessible loading, streets/sidewalks to the accessible entrance	Site arrival points	Vehicular-way-only exception does not apply to buildings containing or serving Type B units (R-2 on this mixed-use structure)	Direct	Provide a pedestrian accessible route from every applicable arrival point	Verified
1104.2	On-site connections	At least one accessible route connecting accessible buildings, facilities, elements and spaces on the same site	Multiple accessible elements on one site	Vehicular-way-only; recreation only as 1111	Direct	Connect podium, parking, office lobby and amenities to the same accessible network	Verified
1104.3	Connected spaces	At least one accessible route to each required accessible portion, to accessible entrances connecting accessible walkways, and to the public way	Building required to be accessible	1104.4 story skips; assembly levels without wheelchair spaces; courtroom workstations; 1111 recreation	Direct	Trace the accessible route from public way through lobby, lifts, office floors and amenity floors	Verified
1104.4	Multistory / occupied roof	At least one accessible route shall connect each accessible story, mezzanine and occupied roofs	Multilevel buildings	Exception 1 (≤ 279 m² aggregate) shall not apply to health-care-provider offices (Group B or I), government buildings, or this elevator high-rise. Exception 4: two-story building with occupant load five or fewer, no public use	Direct	Do not use the 279 m² story-skip; serve every office and amenity level including occupied roof	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
1104.5	Route coincidence	Accessible routes shall coincide with or be in the same area as general circulation; interior circulation requires an interior accessible route; a single accessible route shall not pass through kitchens, storage, restrooms, closets or similar	Accessible routes	Garage-to-Type B interior exception is residential, not this occupancy	Direct	Keep common accessible routes in public/office circulation, not through service rooms	Verified
1104.6	Security barriers	Security barriers shall not obstruct a required accessible route or accessible means of egress	Bollards, checkpoints	Adjacent route permitted around devices that cannot comply (metal detectors), with visual contact of personal items	Conditional	If a lobby security line exists, provide an adjacent accessible path that keeps bags in view	Verified

7. Entrances

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
1105.1	Public entrances	At least 60 percent of all public entrances shall be accessible, in addition to 1105.1.2–1105.1.8	Public entrances	Areas not required to be accessible; loading/service entrances that are not the only tenant entrance	Direct	Count public doors (not egress-only doors) and make ≥ 60% accessible	Verified
1105.1.1 / Table 1105.1.1	Power-operated public entrance	One full-power or low-energy power-operated door at each required accessible public entrance when occupancy and building occupant load exceed the table; vestibule: one leaf in and one leaf out	Table lists Groups A-1–A-4 and B, M, R-1 . Mixed-use uses the most restrictive listed load	Flattened OCR occupant-load cells are not adopted	Direct	Power-operate accessible office public entrances once the published Group B load is confirmed; mixed-use may use the most restrictive listed load	Verify source
1105.1.2	Parking-garage entrance	Direct pedestrian access from parking structures to building/facility entrances shall be accessible	Direct garage-to-building pedestrian access	None stated	Direct	Provide an accessible pedestrian door from the parking structure into the office lobby	Verified
1105.1.3	Tunnel / walkway entrance	At least one accessible entrance from each pedestrian tunnel or elevated walkway	Direct pedestrian access from those links	None stated	Conditional	If a podium link bridge exists, make at least one door from it accessible	Verified
1105.1.4	Restricted entrance	At least one restricted entrance shall be accessible	Restricted (security-controlled) entrances	Ordinary key-card staff doors are not this section	Conditional	If a tenant-secure office entry exists as a restricted entrance, make at least one of that type accessible	Verified
1105.1.6	Sole service entrance	If a service entrance is the only entrance to a building or tenant space, that entrance shall be accessible	Service entrance as the only entry	Loading docks that are not the only entry are excepted from 1105.1	Conditional	Do not leave a BOH-only tenant with an inaccessible sole door	Verified
1105.1.7	Tenant entrance	At least one accessible entrance to each tenant in a facility	Multi-tenant facility	Self-service storage not required to be accessible	Direct	Give each office tenant an accessible entrance in addition to the 60% building count	Verified

8. Parking, vans and passenger loading

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
1106.2 / Table 1106.2	Office accessible parking	Where parking is provided, accessible spaces shall comply with Table 1106.2 , calculated separately for each parking facility	Parking serving Group B	1106.3 residential items do not apply to Group B. Table is flattened OCR	Direct	Size office accessible stalls from the published Table 1106.2 after source check; do not use the R-2 2 percent rule	Verify source
1106.6	Van spaces	For every six or fraction of six accessible parking spaces, at least one shall be van-accessible	Accessible parking provided	2100 mm van-height reduction is Group U private garages serving R-2 and R-3 only — not Group B	Direct	Provide 1-in-6 vans; do not use the residential garage height exception for office stalls	Verified
1106.7 Ex. 1	Van-space level	In multilevel parking structures, van-accessible parking spaces are permitted on one level	Multilevel parking	Accessible spaces still dispersed; van-height millimetres are A117.1 (not imported)	Direct	Concentrate van stalls on the level that can provide the A117.1 van clearance	Verified
1106.9.1	Continuous loading zone	One accessible passenger loading zone in every continuous 30 m maximum	Passenger loading zones provided	None stated	Conditional	If a kerbside drop-off exists, space accessible zones at ≤ 30 m	Verified
1106.9.3	Valet loading zone	A passenger loading zone shall be provided at valet parking services	Valet parking	Valet does not delete accessible parking	Conditional	If valet is offered for the office/amenities, provide an accessible drop-off; still provide 1106 parking	Verified
1112.1 Item 1	Stall identification	Accessible parking required by 1106.2 shall be identified by the ISA	1106.2 accessible spaces	Identification not required where total parking provided is four or less	Direct	Sign every required office accessible stall unless the entire facility has four or fewer spaces	Verified

9. Electrical vehicle charging

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
1107.2 Exception	R-2 EV exemption (not Group B)	EV charging stations provided to serve Groups R-2, R-3 and R-4 are not required to comply with 1107.2	EV serving those occupancies	Group B is not listed	Direct	Do not apply the residential EV exemption to office or public chargers	Verified
1107.2.1	Accessible EV count	Not less than 5 percent of vehicle spaces served by EV systems, but not fewer than one of each type , shall be accessible	EV systems not covered by the R-2/R-3/R-4 serving exception	None stated beyond 1107.2	Conditional	If office or podium/public chargers exist, reserve 5% (≥ 1 of each charger type)	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
1107.2.2	Accessible EV stall size	3300 mm minimum vehicle-space width with adjoining access aisle 1500 mm minimum	Accessible EV spaces required by 1107.2.1	None stated	Conditional	Do not substitute a narrower A117.1 van option; this section specifies 3300 + 1500	Verified

10. Common toilets, kitchens, drinking fountains, storage and lifts

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
1110.2	Toilet/bathing rooms	Each toilet room and bathing room shall be accessible; at least one of each type of fixture/element/control/dispenser accessible	Toilet/bathing rooms	Ex. 1: private-office single-occupant rooms may use A117.1 adaptable exceptions. Ex. 3: clustered single-user rooms ≥ 50% (≥ 1 of each use). Do not locate the only toilets on a non-accessible floor	Direct	Make office-floor, lobby and amenity toilets accessible; a private en-suite in an individual office may use the adaptable exception	Verified
1110.2.1	Family/assisted-use toilet	Required in assembly and mercantile where aggregate male+female water closets ≥ 6 ; travel ≤ 150 m and ≤ one story from separate-sex rooms	Assembly/mercantile fixture count	Mixed occupancy: count only A/M water closets. Family bathing room required where separate-sex bathing rooms are provided in recreational facilities	Conditional	If amenity F&B/assembly/retail hits six WCs, add a family room on an accessible route	Verified
1110.2.4	Compartments	≥ 5% of compartments wheelchair-accessible; if compartments+urinals ≥ 6 , ≥ 5% ambulatory-accessible in addition	Multi-compartment toilets	None stated for office toilets	Direct	Size typical office toilets with a wheelchair stall; add ambulatory stall when compartments+urinals ≥ 6	Verified
1110.2.5	Lavatories	≥ 5% (≥ 1) accessible; extra accessible lavatory if the only one is inside the accessible stall; ≥ 6 lavatories → one enhanced-reach	Lavatories provided	Enhanced reach per A117.1 (not imported)	Direct	Do not hide the only accessible lavatory inside the accessible stall	Verified
1110.3	Sinks	≥ 5% (≥ 1) of sinks in accessible spaces shall be accessible	Sinks provided	Mop or service sinks not required to be accessible	Conditional	Make pantry/tea-point sinks accessible; exempt janitor sinks	Verified
1110.4	Kitchens and kitchenettes	Kitchens and kitchenettes in accessible spaces or rooms shall be accessible	Common kitchens / kitchenettes	Employee-work-area commercial kitchens follow 1103.2.2 / 1104.3.1; break-room kitchenettes are not employee work areas	Direct	Detail office pantries, amenity kitchens and staff break kitchenettes as accessible	Verified
1110.5.1	Drinking fountains	No fewer than two : one wheelchair, one standing (or dual-spout substitute)	Drinking fountains provided on a floor/site/secured area	Children’s standing spout 760 mm minimum	Conditional	If fountains are provided, install hi-lo; do not import SBC 701 fixture counts	Verified
1110.10	Built-in storage	≥ 5% (≥ 1) of each type of fixed/built-in storage in required accessible spaces shall be accessible	Cabinets, lockers, closets, drawers	Employee-workstation storage follows 1103.2.2	Direct	Make ≥ 5% of each locker/coat-hook/shelf type accessible in common office and amenity spaces	Verified
1110.8	Elevators	Passenger elevators on an accessible route shall be accessible and comply with Chapter 30	Passenger elevators on an accessible route	Freight/construction elevators not this section	External verification	All passenger cars on the accessible route are accessible; stretcher/FSAE sizes live in Chapter 30 / 403, not here	Verified
1110.9 Item 3	Platform lift to small non-public space	Platform lifts permitted on a required accessible route to spaces not open to the public with occupant load not more than five	New construction	ASME A18.1 (not imported)	Conditional	A lift may serve a small non-public mezzanine (e.g. projection); it does not replace building elevators	Verified

11. Work surfaces, service facilities and lockers

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
1110.12	Tables and work surfaces	≥ 5% (≥ 1) of seating and standing spaces at fixed/built-in tables, counters or work surfaces in accessible spaces shall be accessible	Fixed/built-in tables or counters	Check-writing surfaces at non-accessible check-out aisles; individual workstations follow 1103.2.2	Direct	Provide wheelchair spaces at ≥ 5% of meeting-room, lounge and amenity built-in tables; disperse them (1110.12.1)	Verified
1110.13.2	Sales and service counters	At least one of each type of sales or service counter/window shall be accessible; disperse if the counters are dispersed	Reception, F&B, retail counters	Not a check-out-aisle table	Direct	Lower at least one reception desk and one of each amenity/retail service counter type	Verified
1110.13.1 / Table 1110.13.1	Check-out aisles	Accessible check-out aisles per Table 1110.13.1 for each function; disperse if aisles are dispersed	Check-out aisles provided	Public-use area < 465 m² : not more than one accessible aisle required. Table is flattened OCR	Conditional	If amenity retail uses check-out lanes, apply the published table after source check	Verify source
1110.13.3	Food-service lines	Food service lines shall be accessible; ≥ 50% (≥ 1) of each type of self-service shelf accessible	Food-service lines provided	None stated	Conditional	If a cafeteria or buffet line exists, put the line and ≥ 50% of each shelf type on the accessible route	Verified
1110.13.4	Queue lines	Queue and waiting lines serving accessible counters or check-out aisles shall be accessible	Queues at those counters	None stated	Conditional	Keep reception and F&B queues on an accessible route; do not create a separate “accessible” line	Verified
1110.14	Locker / fitting rooms	≥ 5% (≥ 1) of each type of use in each cluster shall be accessible	Dressing, fitting or locker rooms provided	None stated	Conditional	If gym/spa lockers exist, make ≥ 5% of each cluster accessible	Verified
1110.15	Operable parts	Controls, operating mechanisms and hardware intended for occupant operation in accessible spaces, along accessible routes or as parts of accessible elements shall be accessible	Those controls	Service-only parts; pool-barrier gates per 1010.2.3; A117.1 operable-part exceptions	Direct	Keep light switches, outlets, thermostats and amenity controls on the accessible package	Verified

12. Recreational facilities

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
1111.3	Recreation other than R-2/R-3/R-4	Recreational facilities not falling within 1111.2 shall be accessible	Office, hotel and other occupancies outside 1111.2	Shared facilities that also serve R-2 Type A/B still cannot drop below 1111.3 where they serve Group B	Direct	Make every office-serving gym, pool, court and spa accessible — do not use the R-2 25% rule	Verified
1111.4.14	Pool water entry	Swimming pools, wading pools, cold baths, hot tubs and spas shall be accessible and on an accessible route	Those water features provided	Ex. 1 catch-pool/slide terminus. Ex. 2 clustered spas 5% (≥ 1 of each type). Ex. 3 water-entry waiver is only for 1111.2.2 / 1111.2.3 — not 1111.3	Conditional	Provide an accessible route to and into office/amenity pools/spas; do not use the Type A/B water-entry waiver	Verified
1111.4.10	Exercise machines	At least one of each type of exercise machine and equipment shall be on an accessible route	Exercise machines provided	Operable-part heights are A117.1 (not imported)	Conditional	Put at least one of each gym machine type on the accessible route	Verified
1111.4.2	Player seating	At least one wheelchair space in team/player seating serving areas of sport activity	Team/player seating provided	Bowling-lane exception	Conditional	If a court has player benches, provide one wheelchair space	Verified
1111.4.4	Court sides	At least one accessible route shall directly connect both sides of the court	Court sports	None stated	Conditional	If tennis/padel/basketball courts exist, connect both sides without leaving the court area	Verified
1110.7	Saunas and steam rooms	Where provided, saunas and steam rooms shall be accessible	Those rooms provided	Clustered: ≥ 5% (≥ 1) of each type in each cluster	Conditional	If spa saunas exist, make them accessible (or 5% of each clustered type)	Verified

13. Amenity assembly and dining

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
Table 1109.2.2.1	Wheelchair spaces	Flattened OCR table; no reconstructed seating-capacity cell is adopted	Assembly with fixed seating	Companion seat per 1109.2.3 (one per wheelchair space); 5% designated aisle seats	Conditional	If an auditorium, cinema or lecture room has fixed seats, apply the published table after source check	Verify source
1109.2.5	Designated aisle seats	≥ 5% (≥ 1) of aisle seats, closest to accessible routes	Aisle seats provided	Not required in team/player seating	Conditional	Mark aisle seats nearest the accessible route in amenity auditoria	Verified
1109.2.9	Dining floor areas	All interior and exterior dining and drinking floor areas shall be accessible and on an accessible route	Dining and drinking areas	Mezzanine < 25% of combined dining area with the same services (Ex. 2); 1104.4 Ex. 1 story skip (not this high-rise)	Conditional	Put restaurant, café and terrace dining on an accessible route	Verified
1109.2.9.1	Dining surfaces	≥ 5% (≥ 1) of dining surfaces for seating and standing spaces accessible, distributed, on an accessible level	Dining surfaces provided	Same mezzanine branch as 1109.2.9	Conditional	Provide wheelchair dining in office cafés and amenity restaurants	Verified
Table 1109.2.7.1	ALS receivers	Flattened OCR table; asterisks unresolved; no reconstructed receiver-count cell is adopted	Assembly where audible communication is integral	Not required (except courtrooms) where there is no audio amplification; induction-loop HAC exception	Conditional	If an amenity hall has a PA, provide receivers after published-source check of the table	Verify source

14. Signage

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
1112.1 Items 4–7	Partial-access identification	Identify accessible toilets, entrances, check-out aisles and dressing/locker rooms where not all are accessible	Mixed accessible/non-accessible sets	None stated	Direct	Sign the accessible lobby entrance if any public entrance remains inaccessible	Verified
1112.1 Items 8–9	Accessible MOE signs	Accessible areas of refuge and exterior areas for assisted rescue in accordance with Section 1009.9	Those elements provided	Values not in Chapter 11	External verification	Coordinate ISA with the Chapter 10 accessible-egress package	Verified
1112.3	Directional signs	Directional ISA signage at inaccessible entrances, toilets, elevators not on an accessible route, family-toilet locations, exits not providing approved accessible MOE (1009.10), and split hi-lo fountains	Those conditions	Visual characters per A117.1 (not imported)	Direct	Place directional copy at every inaccessible public entrance	Verified
1112.4 Item 1	ALS availability sign	Assembly areas required to comply with 1109.2.7 shall notify patrons of assistive listening systems, with the hearing-loss symbol	Assembly with ALS	Signs at each ticket window may substitute for signs in each assembly room	Conditional	If an amenity hall has a PA, post ALS availability at the door or ticket point	Verified

15. High-rise and outbound controls

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
1009 (named)	Accessible means of egress	Chapter 11 repeatedly sends accessible egress to Section 1009	Accessible floors and occupied roofs	No 1009 values imported	External verification	Use the Chapter 10 matrix for AMOE; do not copy those numbers here	Verified
1110.8 / Ch. 30 / 403	Elevators	Passenger elevators on the accessible route: accessible + Chapter 30. Commentary also names stretcher, 1009.2.1 and 36 m FSAE — commentary numbers are not adopted	Elevators / high-rise	Charging 1110.8 does not itself state 36 m or four-storey triggers	External verification	Coordinate stretcher, FSAE and occupant-evacuation elevators from Chapter 30 / 403, not from Chapter 11 commentary	Verified

Cite	Component / check	Exact source requirement / value	Trigger / condition	Exceptions / branch	Group B status	Design action	Source confidence
SBC 901 §306	Existing buildings	Named in General Comments only	Existing buildings	Not quantified in this chapter's code paragraphs	External verification	Alterations are outside this new-construction extract	Verified

16. Project-use controls

1. Use **Verified** rows for initial scoping after the row trigger and branch are confirmed.
2. Treat every **Verify source** row (all reconstructed appended tables) as a design hold point; no affected value is to be placed in issued-for-approval drawings without a published-source check.
3. Do not apply R-1 Accessible-guestroom quotas, R-2 Type A/B apartment mix, the R-2 **2 percent** parking rule, or the 1107.2 R-2 EV exemption to Group B office parking or office EV.
4. Do not apply the 1111.2.2 **25%** recreation rule to office-serving facilities; those use 1111.3.
5. Do not import ICC A117.1 millimetres, Chapter 10 AMOE dimensions, or commentary examples.
6. Record AHJ, occupant-load, parking, amenity-program and recreation-ownership decisions in the project Golden Thread; this matrix is not evidence of SCD NOC or stamped compliance.

17. Coverage summary

Internal inventory of the attached Chapter 11 extract (numbered code, exceptions, tables, footnotes; commentary excluded). Row-level records are not published.

- **Inventory scope:** numbered code, exceptions, tables, footnotes (commentary excluded)
- **Total independently checkable numeric records:** 276
- **Verified:** 192
- **Verify source:** 84
- **Numeric records in Sections 1101 and 1102:** 0

Counts by top-level section

Top-level section	Records
1101	0
1102	0
1103	3
1104	12
1105	9
1106	12
1107	4
1108	51
1109	16
1110	62
1111	22
1112	1

Appended-table coverage

Appended table	Records	Verify source records
Table 1105.1.1	2	2
Table 1106.2	11	11
Table 1108.6.1.1	33	33
Table 1109.2.2.1	7	7
Table 1109.2.7.1	12	12
Table 1109.3	2	2
Table 1110.13.1	4	4
TABLE 111.4.9.1 (OCR title)	13	13

Coverage cross-check against SBC 201 Chapter 11 Accessibility (2024)_CS.md was topics-only: scoping vs ICC A117.1; 1103.2 exceptions; routes and stories; entrances and power doors; parking/vans; EV charging; employee work areas; assembly seating and toilets. No CS.md value was copied into a matrix cell.

18. Unresolved-source register

Hold points for the 84 **Verify source** inventory records. Counts are record counts, not distinct numeric values. No value in this register is a design-release figure.

Affected table / clause	Why unverified	Control note
Table 1105.1.1	2 flattened occupancy/load cells	Verify published table; Group B is listed. Mixed-use footnote uses the most restrictive listed occupant load
Table 1106.2	11 flattened stall-count rows	Group B parking uses this table via 1106.2; verify published table before stall counts
Table 1108.6.1.1	33 flattened Accessible-unit cells (without / with roll-in / total)	Not applied to Group B office; verify published table only if a hotel/congregate use is added on this occupancy
Table 1109.2.2.1	7 flattened wheelchair-space rows	Verify published table before amenity/assembly seating
Table 1109.2.7.1	12 flattened receiver/HAC cells; asterisks unresolved	Verify published table before ALS receiver counts
Table 1109.3	2 flattened self-storage rows	Not typical for this office; verify published table only if self-storage is added
Table 1110.13.1	4 flattened check-out-aisle rows	Verify published table if amenity retail check-out aisles exist
TABLE 111.4.9.1 (OCR title as printed)	13 flattened boat-slip rows	Title OCR; not typical for this office; verify published Table 1111.4.9.1 if a marina is added