

Garage roof leak investigation

Customer Jordan & Casey Morgan (Fictitious Demo Homeowners)
Service address 1847 Cedar Hollow Way, Indianapolis, IN 46220
HouseIQ property ID HIQ-DEMO-001
Event ID E2017-01

Proposed Scope

Investigated a ceiling stain over the attached garage. Water entry traced to deteriorated step flashing where garage roof meets the two-story wall.

- Moisture meter elevated around garage ceiling stain.
- Shingles generally serviceable but showing age.
- Removed localized shingles, replaced step flashing, and installed ice/water membrane patch.
- Interior ceiling left open to dry; no structural rot found.

Quoted project amount	\$645.00
Quote status	FOR REVIEW
Valid through	2017-03-20

Recordkeeping note: Retain this document with related estimates, invoices, warranties, inspection reports, and manuals. HouseIQ demo event linkage: E2017-01

Entirely fictitious property, vendors, people, equipment, documents, and transactions created for HouseIQ software demonstration and testing.