

Enhanced LSTM framework for water-cooled chiller COP forecasting

Chao-Wei Yu ¹, June-Wei Chen ¹, Yen-Lin Chen ^{1,*}

¹ Dept. Computer Science and Information Engineering, National Taipei University of Technology, Taipei Taiwan.

* ylchen@mail.ntut.edu.tw

Abstract—The water-cooled chiller is one of the indispensable equipment in each building. Due to long-term use or improper operation, it is easy to cause components of the equipment to be wore out, generating additional energy consumption, and even causing malfunction. In this study, we used technology of IoT (Internet of Things) to upload the operating parameters and data in each period of every water-cooled chiller to the cloud, and presented the visualized result. Managers were able to understand the current status of each water-cooled chiller much easier with the visualized results, and at the same time we conducted predictive analysis on the collected water-cooled chiller data. If we can predict the COP (Coefficient Of Performance) value trend accurately, managers can effectively arrange personnel to carry out the maintenance work of each water-cooled chiller to reduce unnecessary energy and cost losses.

Keywords—Water-cooled, IoT, COP, Forecast, Enthalpy

I. INTRODUCTION

The Coefficient of Performance of a water-cooled chiller represents its ability of refrigeration and operating condition. Through the performance, it can be decided whether the water-cooled chiller needs to maintain or clean. COP of every water-cooled chiller is in a certain range according to the locating environment or types of compressor, however, the function of the chiller decrease due to long-term use, equipment worn out, improper operation and maintenance or other factors. In Breuker's[1] research about how machinery breakdown affect the refrigerating ability and function of an air conditioner, when the leakage of the refrigerant reach 14%, the ability of refrigeration decrease 8% while COP decrease 4.6%, and when the fouling of the condenser reaches 28%, the ability of refrigeration decrease 4.8% while COP decrease 4.4%. Once the function decline severely, lots of energy can be wasted, life of the water-cooled chiller become shorter, and malfunction occurs more which means the need of maintenance gets higher as well. Therefore, we installed sensor accordingly to every water-cooled chiller and uploaded the results to the cloud through IoT, then we predicted the COP value trend of every chiller by analyzing the information which is collected by Seq2Seq with thermodynamics and theories of different scholars. Manager can arrange the maintain schedule efficiently with our prediction. Attention mechanism is added in our COP prediction, using the temperature of overheated gaseous refrigerant from the compressor discharge(T_{hg}), saturated evaporate pressure(P_{ev}) and saturated condensate pressure(P_{cd}) to calculated the Enthalpy value. The Enthalpy value, discharge temperature of condenser and evaporator can be used as a reference parameter for training model, which helped to increase the accuracy of the prediction.

II. RESEARCH METHOD

In this chapter we are introducing the structure of our experiment system and research method, they are mainly separated into two parts, model training and water-cooled chiller cloud platform. Model training can be divided into three section which are data cleaning model, COP calculation, and Seq2Seq LSTM model in this research. As for cloud platform, we are going to explain how we visualized the collected data and present the COP value trend prediction on cloud platform through the trained model.

1) Model Training

a) Data Cleaning: As Fig. 1 shows, we installed sensors in water-cooled chillers and uploaded these data to cloud server. the original data, including the information of operating and closing status, uploaded from the chillers. The power consumptions are 0 in the last two data on the table, therefore they should be filtered out since they are not in operation status. In addition, some data were lost which shows "Null" on the table and because every data has high relevance, we determined to discard the data to assure the completeness rather than padding the data by square numbers.




Fig. 1 Sensor locations in water-cooled chiller

b) feature data result: In our research we found out feature data which affected COP for training perdition model, the data are three-point temperature of refrigerant circulation (Enthalpy value $h1$, $h2$, $h3$), evaporator discharge temperature(T_{ev}), and condenser discharge temperature(T_{cd}). The way of calculating COP is based on the formula (1) that Industrial Technology Research Institute[2] proposed. The enthalpy value $h1$ 、 $h2$ 、 $h3$ were obtained respectively by finding out the corresponding points in the Mollier diagram[3] with compressor discharge pressure(T_{hg}), saturated evaporate pressure(P_{ev}) and saturated condensate pressure(P_{cd}), shows as Fig. 2.

$$\text{COP} = \frac{(\int_{t_1}^{t_2} h_1 dt - \int_{t_1}^{t_2} h_3 dt)}{(\int_{t_1}^{t_2} h_2 dt - \int_{t_1}^{t_2} h_1 dt)} \quad (1)$$




Fig. 2 Corresponding points of enthalpy value in Mollier diagram

c) Model structure: We used Seq2Seq(Sequence to Sequence) network framework for model training. The Encoder and Decoder concept in the framework could assure the unity of different length data inputted from water-cooled chillers and added different attention mechanism individually, they have better prediction result compare to regular LSTM model. The description of Encoder and Decoder concept from the LSTM model improved by our research are as below:

i) Encoder with soft attention: Fig. 3 is the first part of the model, which we inputted our feature data as Encoder module. In the module, Enthalpy value of evaporator discharge represents as h_1 , Enthalpy value of compressor discharge represents as h_2 , Enthalpy value of condenser discharge represents as h_3 , cold water charge temperature represents as T_{evwi} , and cooling water charge and discharge temperature represents as T_{cdwi} . As the input sequence data S_t , we added Soft attention mechanism that gave different weights value at according to the enthalpy value, cold water charge and discharge temperature in each time sequence data. Multiplying the input number sequences S_t and weights value a_t , x_t was obtained to be the input data for LSTM model, and the hidden status when outputting will be decided by the hidden layer states inputted in the last moment, as formula (2) to (6).




Fig. 3 Encoder structure in this research

$$s_t = [h1_t; h2_t; h3_t; T_{evwi_t}; T_{cdwi_t}] \quad (2)$$

$$e_t^k = v_e^T \tanh(W_e \cdot [h_{t-1}, s_{t-1}] + U_e s_t^k) \quad (3)$$

$$a_t^k = \frac{\exp(e_t^k)}{\sum_{i=1}^n \exp(e_t^i)} \quad (4)$$

$$x_t = (a_t^1 \cdot s_t^1 + a_t^2 \cdot s_t^2 + \dots + a_t^n \cdot s_t^n)^T \quad (5)$$

$$h_t = \text{LSTM}(h_{t-1}, x_t) \quad (6)$$

ii) Decoder with hard attention: Fig. 4 is the second part of the prediction model, the input data in this part is the status of each hidden layer states h_1, h_2, \dots, h_t that Encoder output. The Hard attention which was imported in this stage was focused on the data in past few days, the prediction point was different in every focusing time. The date which was important comparatively at that moment were labeled as 1 while the other data were labeled as 0. As for the linear layer, ReLU(rectified Linear Units) was used to prevent the problem of gradient disappearance, as formula (7) to (10) show. Each moment has different context vector, and finally this sequence C_t was input to LSTM model for prediction.




Fig. 4 Decoder structure in this research

$$l_t^k = v_d^T \text{ReLU}(W_d \cdot [h_{t-1}, s_{t-1}] + U_d h_t) \quad (7)$$

$$\beta_t^i = \frac{\exp(l_t^i)}{\sum_{j=1}^T \exp(l_t^j)} \quad (8)$$

$$c_t = \sum_{i=1}^T \beta_t^i h_i \quad (9)$$

$$y_t = \text{LSTM}(y_{t-1}, w^T[y_{t-1}; c_{t-1}] + b) \quad (10)$$

III. EXPERIMENTAL DATA

In this research we used the data of five water-cooled chillers during January to May, 2020 and filtered out the incomplete data. We separated the training data into three parts for deep learning as below:

- 1) Training set: Data used for training model
- 2) Validation set: Used for verify the correctness of the model to prevent overfitting
- 3) Testing set: Data for testing finished training model and calculated the quality of the model

Training and Validation sets contain the data of the whole year of 2019, and testing set contains the data during March and

April, 2020. Table 1 and 2 are the detail information of model training and testing

TABLE 1 EXPERIMENT TRAINING DATA

Data Set	Number of Data	Number of Columns	Time per Unit
Water-cooled chiller (one per year)	63204	9	2 min

TABLE 2 EXPERIMENT TESTING DATA

Data Set	Number of Data	Number of Columns	Time per Unit
Water-cooled chiller (two per two months)	5500	9	2 min

a) Model COP trend prediction: In this research we took advantage of the processed featured information to predict future COP trend. Different observe length of data can be inputted to prediction model for long-term prediction, and the prediction result of error rate was presented per unit, the value difference between prediction value and actual value were calculated by MAE. We predicted the water-cooled chiller COP by selecting the optimum model from 5000 epoch, by comparing different water-cooled chiller and model, the experiment result could be conspicuous.

- i) Different water-cooled chiller: Our observation length is one week as a circulation, we observed the information in first three days and predicted the possible COP trend for the next three days. Sample maps and statistics tables for five testing set during March and April are show as below, Fig. 5 is the COP curve sampling for the first testing set during March, and Fig. 6 is the COP curve sampling for the first testing set during April.
- ii) Different model: In this research we inputted the same water-cooled chiller data to models trained by different neural network. Table show as below are the result data, table 3 presents the MAE differences of testing sets using the first water-cooled chiller.




Fig. 5 COP curve sampling for the first testing set during March




Fig. 6 COP curve sampling for the first testing set during April

TABLE 3 MAE DIFFERENCES OF TESTING SETS USING THE FIRST WATER-COOLED CHILLER

Metric	Models	Testi ng set 1	Testi ng set 2	Testi ng set 3	Avera ge
MAE (Enthalpy [kg/J])	Ours	0.087	0.121	0.119	0.109
	V-LSTM [4]	0.138	0.129	0.130	0.132
	RNN	0.112	0.146	0.129	0.129
	ResRNN	0.109	0.133	0.122	0.121
	LSTM	0.107	0.145	0.151	0.134
	GRU	0.106	0.148	0.116	0.123

IV. CONCLUSION

We took water-cooled chillers in office buildings as our research experiment samples and proposed an improved LSTM prediction model which could effectively apply in the COP prediction for water-cooled chillers. The average COP differences could be lowered to 0.0311(kg/J) while the highest differences was 0.166(kg/J), this result shows that it is possible to predict the COP trend. Setup of the cloud platform allowed managers to control water-cooled chiller in different areas more easily through visualized data, they could notice mechanical failures at the first moment and arranged maintenance processes effectively. This application can not only be used in the control of water-cooled chillers but widely applied in other field in the future.

V. ACKNOWLEDGMENT

This manuscript was edited by Chun-Ting, Chen. This project is financially sponsored by the Ministry of Science and Technology. MOST-109-2628-E-027-004-MY3, MOST- 109-2622-E-027 -034 and MOST- 109-2622-E-027 -013 CC2.

VI. REFERENCES

- [1] Breuker, Mark, Todd Rossi, and Jim Braun. "Smart maintenance for rooftop units." ASHRAE journal 42.11 (2000): 41-47.
- [2] Lin Zhenyuan, Liu Zhongzhe, Luo Jinhong, "Measuring Device and Method for Refrigeration and Air Conditioning Main Unit Efficiency Value", Patent of the Republic of China, Industrial Technology Research Institute, 2010
- [3] SHELTON, Mark R.; GROSSMANN, Ignacio E. A shortcut procedure for refrigeration systems. Computers & chemical engineering, 1985, 9.6: 615-619.
- [4] Deng-Zeng Chen, "Prediction of COP attenuation for water-cooled chillers base on LSTM" NTUT, ROC, 2019.