

ACTCON
Adam

adam@actcon.com.au

18 March 2026

Lead Air Monitoring Results: Test Project - Do Not Delete - 26 February 2026

Introduction

Following discussions with ACTCON, Lancaster and Dickenson Consulting (L & D) were contracted to undertake air monitoring during lead abatement works at Test Project - Do Not Delete (herein referred to as 'the Site').

Lead abatement works were undertaken by Aztech Services. Kyle Lancaster from L&D visited the Site on 26 February 2026.

Table 1 below outlines the samples that formed part of the inspection. The certificate of analysis for the samples is presented in Appendix A of this report.

Table 1: Lead Air Monitoring Results

Sample ref.	Sample location	Start time	Finish time	Flowrate (L/min)	Lead Conc. (mg/m ³)
LDJ06023-LP1	SW of abatement zone	10:45	16:45	2.0	0.0556
LDJ06023-LP2	East of abatement zone	09:37	15:37	2.0	<0.0014
LDJ06023-LP3	Sample 3	06:13	17:13	2.0	<0.0008
LDJ06023-LP4	Sample 4	06:14	17:14	2.0	<0.0008
LDJ06023-LP5	Sample 5	04:14	17:14	2.0	<0.0006
LDJ06023-LP6	Sample 6	05:14	17:15	2.0	<0.0007

Discussion & Conclusions

Analysis of LDJ06023-LP1 found the sample exceeded the exposure limit for airborne lead of 0.05 mg/m³.

Work should immediately cease until a review is conducted of the controls used for these lead abatement works and improvements to control measures have been implemented. Work may only recommence once improvements to control measures have been assessed as satisfactory.

Please do not hesitate to contact the undersigned should you have any queries regarding this report.

For and on behalf of Lancaster and Dickenson Consulting.



Kyle Lancaster

Lancaster & Dickenson Consulting Pty Ltd



APPENDIX A

CERTIFICATE OF ANALYSIS

CERTIFICATE OF ANALYSIS 333615

Client Details

Client	Lancaster & Dickenson Consulting Pty Ltd
Attention	Kyle Lancaster
Address	Unit 4, 6 Dacre St, MITCHELL, ACT, 2911

Sample Details

Your Reference	<u>LDJ01943</u>
Number of Samples	2 Soil, 2 Paint
Date samples received	21/09/2023
Date completed instructions received	21/09/2023

Analysis Details

Please refer to the following pages for results, methodology summary and quality control data.

Samples were analysed as received from the client. Results relate specifically to the samples as received.

Results are reported on a dry weight basis for solids and on an as received basis for other matrices.

Report Details

Date results requested by	28/09/2023
Date of Issue	26/09/2023
NATA Accreditation Number 2901. This document shall not be reproduced except in full.	
Accredited for compliance with ISO/IEC 17025 - Testing. Tests not covered by NATA are denoted with *	

Results Approved By

Loren Bardwell, Development Chemist

Authorised By

Nancy Zhang, Laboratory Manager

Acid Extractable metals in soil			
Our Reference		333615-1	333615-2
Your Reference	UNITS	11B-LS1	11B-LS2
Type of sample		Soil	Soil
Date Sampled		09/09/2023	09/09/2023
Date prepared	-	22/09/2023	22/09/2023
Date analysed	-	22/09/2023	22/09/2023
Lead	mg/kg	5	7

Lead in Paint			
Our Reference		333615-3	333615-4
Your Reference	UNITS	LD-NB0023	LD-NB0022
Type of sample		Paint	Paint
Date Sampled		09/09/2023	09/09/2023
Date prepared	-	25/09/2023	25/09/2023
Date analysed	-	25/09/2023	25/09/2023
Lead in paint	%w/w	0.03	<0.005

Moisture			
Our Reference		333615-1	333615-2
Your Reference	UNITS	11B-LS1	11B-LS2
Type of sample		Soil	Soil
Date Sampled		09/09/2023	09/09/2023
Date prepared	-	22/09/2023	22/09/2023
Date analysed	-	25/09/2023	25/09/2023
Moisture	%	6.1	3.0

Method ID	Methodology Summary
Inorg-008	Moisture content determined by heating at 105+/-5 °C for a minimum of 12 hours.
Metals-020	Determination of various metals by ICP-AES.
Metals-020/021/022	Digestion of Paint chips/scrapings/liquids for Metals determination by ICP-AES/MS and or CV/AAS.

QUALITY CONTROL: Acid Extractable metals in soil					Duplicate			Spike Recovery %		
Test Description	Units	PQL	Method	Blank	#	Base	Dup.	RPD	LCS-3	[NT]
Date prepared	-			22/09/2023	[NT]	[NT]	[NT]	[NT]	22/09/2023	[NT]
Date analysed	-			22/09/2023	[NT]	[NT]	[NT]	[NT]	22/09/2023	[NT]
Lead	mg/kg	1	Metals-020	<1	[NT]	[NT]	[NT]	[NT]	98	[NT]

QUALITY CONTROL: Lead in Paint					Duplicate			Spike Recovery %		
Test Description	Units	PQL	Method	Blank	#	Base	Dup.	RPD	LCS-1	[NT]
Date prepared	-			25/09/2023	4	25/09/2023	25/09/2023		25/09/2023	[NT]
Date analysed	-			25/09/2023	4	25/09/2023	25/09/2023		25/09/2023	[NT]
Lead in paint	%w/w	0.005	Metals-020/021/022	<0.005	4	<0.005	<0.005	0	108	[NT]

Result Definitions

NT	Not tested
NA	Test not required
INS	Insufficient sample for this test
PQL	Practical Quantitation Limit
<	Less than
>	Greater than
RPD	Relative Percent Difference
LCS	Laboratory Control Sample
NS	Not specified
NEPM	National Environmental Protection Measure
NR	Not Reported

Quality Control Definitions

Blank	This is the component of the analytical signal which is not derived from the sample but from reagents, glassware etc, can be determined by processing solvents and reagents in exactly the same manner as for samples.
Duplicate	This is the complete duplicate analysis of a sample from the process batch. If possible, the sample selected should be one where the analyte concentration is easily measurable.
Matrix Spike	A portion of the sample is spiked with a known concentration of target analyte. The purpose of the matrix spike is to monitor the performance of the analytical method used and to determine whether matrix interferences exist.
LCS (Laboratory Control Sample)	This comprises either a standard reference material or a control matrix (such as a blank sand or water) fortified with analytes representative of the analyte class. It is simply a check sample.
Surrogate Spike	Surrogates are known additions to each sample, blank, matrix spike and LCS in a batch, of compounds which are similar to the analyte of interest, however are not expected to be found in real samples.
Australian Drinking Water Guidelines recommend that Thermotolerant Coliform, Faecal Enterococci, & E.Coli levels are less than 1cfu/100mL. The recommended maximums are taken from "Australian Drinking Water Guidelines", published by NHMRC & ARMC 2011.	
The recommended maximums for analytes in urine are taken from "2018 TLVs and BEIs", as published by ACGIH (where available). Limit provided for Nickel is a precautionary guideline as per Position Paper prepared by AIOH Exposure Standards Committee, 2016.	
Guideline limits for Rinse Water Quality reported as per analytical requirements and specifications of AS 4187, Amdt 2 2019, Table 7.2	

Laboratory Acceptance Criteria

Duplicate sample and matrix spike recoveries may not be reported on smaller jobs, however, were analysed at a frequency to meet or exceed NEPM requirements. All samples are tested in batches of 20. The duplicate sample RPD and matrix spike recoveries for the batch were within the laboratory acceptance criteria.

Filters, swabs, wipes, tubes and badges will not have duplicate data as the whole sample is generally extracted during sample extraction.

Spikes for Physical and Aggregate Tests are not applicable.

For VOCs in water samples, three vials are required for duplicate or spike analysis.

Duplicates: >10xPQL - RPD acceptance criteria will vary depending on the analytes and the analytical techniques but is typically in the range 20%-50% – see ELN-P05 QA/QC tables for details; <10xPQL - RPD are higher as the results approach PQL and the estimated measurement uncertainty will statistically increase.

Matrix Spikes, LCS and Surrogate recoveries: Generally 70-130% for inorganics/metals (not SPOCAS); 60-140% for organics/SPOCAS (+/-50% surrogates) and 10-140% for labile SVOCs (including labile surrogates), ultra trace organics and speciated phenols is acceptable.

In circumstances where no duplicate and/or sample spike has been reported at 1 in 10 and/or 1 in 20 samples respectively, the sample volume submitted was insufficient in order to satisfy laboratory QA/QC protocols.

When samples are received where certain analytes are outside of recommended technical holding times (THTs), the analysis has proceeded. Where analytes are on the verge of breaching THTs, every effort will be made to analyse within the THT or as soon as practicable.

Where sampling dates are not provided, Envirolab are not in a position to comment on the validity of the analysis where recommended technical holding times may have been breached.

Where matrix spike recoveries fall below the lower limit of the acceptance criteria (e.g. for non-labile or standard Organics <60%), positive result(s) in the parent sample will subsequently have a higher than typical estimated uncertainty (MU estimates supplied on request) and in these circumstances the sample result is likely biased significantly low.

Measurement Uncertainty estimates are available for most tests upon request.

Analysis of aqueous samples typically involves the extraction/digestion and/or analysis of the liquid phase only (i.e. NOT any settled sediment phase but inclusive of suspended particles if present), unless stipulated on the Envirolab COC and/or by correspondence. Notable exceptions include certain Physical Tests (pH/EC/BOD/COD/Apparent Colour etc.), Solids testing, total recoverable metals and PFAS where solids are included by default.

Samples for Microbiological analysis (not Amoeba forms) received outside of the 2-8°C temperature range do not meet the ideal cooling conditions as stated in AS2031-2012.