

Division 26: Electrical

Quillbrook Public Library, Main Floor Electrical Fit-out

Section list

Section	Title
26 05 00	Common Work Results for Electrical
26 05 19	Low-Voltage Electrical Power Conductors
26 05 33	Raceways and Boxes
26 22 13	Low-Voltage Transformers
26 24 16	Panelboards
26 27 26	Wiring Devices
26 51 00	Interior Lighting
26 52 00	Emergency Lighting

26 05 00 Common Work Results for Electrical

1. Work conforms to CSA C22.1, Canadian Electrical Code, Part I, as adopted in Alberta.
2. Materials are new and CSA certified. Material descriptions on the materials schedule, drawing E-000, are the Owner's standard descriptions.
3. Feeder F1: three #3 copper conductors plus a #8 copper bond in 35 mm EMT, as shown on E-001.
4. Test every circuit for continuity and insulation resistance before energizing. Provide a typed directory in panel LP-1.

26 05 19 Low-Voltage Electrical Power Conductors

1. Copper conductors, type THHN/THWN-2, 90 °C, 600 V.
2. Branch circuits: #12 AWG minimum, three conductors per circuit (line, neutral, bond).

26 05 33 Raceways and Boxes

1. Interior raceways: electrical metallic tubing (EMT) with steel set-screw fittings, 21 mm minimum.
2. Boxes: steel, sized to code. Fittings, boxes, supports, and connectors are incidental to the raceway and devices.

26 22 13 Low-Voltage Transformers

1. Transformer T1: dry-type, 75 kVA, 600 V delta primary, 120/208 V wye secondary, 150 °C rise, floor mounted on vibration isolation pads.
2. Secondary conductors to LP-1 and the bonding connection to the building ground bus are part of the transformer installation.

26 24 16 Panelboards

1. Panelboard LP-1: 42 circuits, 225 A copper bus, 225 A main breaker, 120/208 V, 3 phase, 4 wire, surface mounted, 10 kA interrupting rating.
2. Branch breakers: 20 A, 1 pole, bolt-on, for every circuit in use and every spare shown on E-002.

26 27 26 Wiring Devices

1. Duplex receptacles: 15 A, 125 V, CSA 5-15R, specification grade, white, with box and device plate.
2. Switches: single-pole, 15 A, 120 V, specification grade, white.

26 51 00 Interior Lighting

1. 2x4 LED troffer: recessed in the T-bar ceiling, 40 W, 4000 K, minimum 4,400 lumens, on and off control.

26 52 00 Emergency Lighting

1. Exit signs: LED, green running man pictogram to the National Building Code of Canada, 5 W, universal mounting.
2. Emergency battery units: 12 V, with two heads, 30 minute runtime, self-diagnostic.