

EVANSTON SKOKIE SCHOOL DISTRICT 65

Evanston, IL
Age of Facilities & Functional Age



#	BUILDING	SQ FT	DATE BUILT	TOTAL AGE OF BLDG FROM ORIGINAL STRUCTURE	LAST MAJOR RENOVATION **	TOTAL AGE OF BLDG FROM LAST MAJOR RENOVATION	FUNCTIONAL AGE	VALUE OF FCA IMPROVEMENTS RECOMMENDED (Not Adjusted for Inflation)	FCA FCI %
A	Chute Middle School	112,898	1966	56	1966	56	56	\$17,452,418	41.22%
B	Haven Middle School	142,114	1926	96	1980	42	42	\$18,992,990	35.64%
C	Nichols Middle School	97,880	1928	94	1940	82	82	\$13,134,800	35.78%
D	King Arts Magnet School	100,022	1956	66	1956	66	66	\$15,150,830	40.39%
E	Bessie Rhodes Magnet School	50,661	1957	65	1957	65	65	\$9,476,555	49.88%
F	Park School	35,367	1959	63	1959	63	63	\$6,949,735	52.40%
G	Hill Early Childhood & Admin.	50,000	2002	20	2002	20	20	\$3,404,840	18.16%
H	Dawes Elementary	57,700	1954	68	1970	52	52	\$9,639,100	44.55%
I	Dewey Elementary	62,690	1940	82	1985	37	37	\$9,869,280	41.98%
J	Kingsley Elementary	63,427	1967	55	1967	55	55	\$10,525,063	44.25%
K	Lincoln Elementary	67,360	1953	69	1980	42	42	\$10,851,050	42.96%
L	Lincolnwood Elementary	61,039	1949	73	1970	52	52	\$9,897,125	43.24%
M	Oakton Elementary	95,470	1914	108	1920	102	102	\$13,986,170	39.07%
N	Orrington Elementary	46,933	1911	111	1920	102	102	\$7,863,130	44.68%
O	Walker Elementary	51,425	1962	60	1962	60	60	\$8,962,720	46.48%
P	Washington Elementary	76,798	1901	121	1950	72	72	\$13,530,330	46.98%
Q	Willard Elementary	56,856	1922	100	1960	62	62	\$9,008,990	42.25%
TOTALS OR AVERAGE:		1,228,640	1945	77	1961	61	61	\$188,695,126	41.76%

**	District Buildings have had miscellaneous Maintenance Work done over the years such as Life Safety, some roof replacements, some secure entry projects and technology upgrades over the years. Major Renovations have not happened at most buildings. Additions were completed at Haven, Dewey, Dawes, Lincoln, Lincolnwood, Oakton, Washington and Willard over the years. The Functional Dates for this sheet shall use the original Building date or an extrapolation date to better note the last major Addition and original building date.
----	--

INDUSTRY STANDARDS & RECOMMENDATIONS FOR PK-12 BUILDINGS:

1. Typical Anticipated Life Span of a PK-12 Building is 50 years
2. Typical Major Renovation Cycle of PK-12 Facilities is 20 to 25 years
3. Older Buildings Built Between 1900 to 1940 are Typically Built to Last Longer and more easily Renovated
4. Buildings Built Post War to the 80's were Typically Built with Cheaper Materials & have Shorter Life Spans or Need More Frequent Maint./Systems Replacement
5. Annual Preventive Maintenance for PK-12 Buildings Should be 2% to 4% of the Current Replacement Value (CRV)