

# **BAB I**

## **PENDAHULUAN**

### **1.1 Background**

A chemical plant is a systematic and rational arrangement or series of integrated processing units. The overall objective of operating a chemical plant is to convert raw materials into products with greater utility. During operation, the plant will always encounter problems such as regulations or control of various process variables and disturbances from the external environment. During operation, the plant must consider technical, economic, and social aspects so that the processes occurring within the plant are not significantly affected by these external changes and a stable process is achieved.

In order for the process to remain stable, control equipment must be installed. These control devices include controllers, sensors, actuators, alarm systems, remote controllers, and so on. These control devices are installed for the purpose of maintaining work safety and security. In addition, they can function to meet the desired product specifications, ensure that the process equipment functions as intended in the design, keep factory operations economical, and meet environmental requirements.

To meet the above requirements, continuous monitoring of chemical plant operations and external intervention are necessary to achieve operational objectives. This can be accomplished through a series of equipment (measuring instruments, controllers, and computers) and human intervention (plant managers and plant operators) that together form a control system. In plant operation, various prerequisites and specific operating conditions are required, thus necessitating efforts to monitor plant operating conditions and control processes so that operating conditions remain stable (Liu et al., 2023).

### **1.2 Problem Formulation**

In the course of a production process in industry, it is necessary to monitor the quality and quantity of that process. This monitoring is a system known as process control. Process control is implemented to minimize or reduce human error and enhance efficiency in the accuracy of an automated device's response to disturbances compared to a manually operated device. Therefore, an understanding of the operation of control systems and their variations in terms of proportional (P), proportional integral (I), and proportional integral derivative (PID) is essential.

### **1.3 Purposes**

1. Able to operate a process with a control system.
2. Able to evaluate processes with variations in feedback control systems (Proportional (P), Proportional Integral (I), and Proportional Integral Derivative (PID)).
3. Able to examine graphs showing the relationship between level and elapsed time against set points, data intervals, PID, and orifice variations.

### **1.4 Benefits**

1. Students are expected to be able to understand the operation of a process with a control system.
2. Students should be able to evaluate processes with various feedback control systems (Proportional (P), Proportional Integral (I), and Proportional Integral Derivative (PID)).
3. Students are expected to be able to examine graphs showing the relationship between level and elapsed time against set points, data intervals, PID, and orifice variations.

## **CHAPTER II**

### **LITERATURE REVIEW**

#### **2.1 Process Control**

A control system is a set of physical components designed to control a system or other systems related to a process in an open loop or closed loop (Benner, 1993). In general, process control is the control of one or more variables so that they remain at a certain value or range. For example, the fluid level in a reactor must be maintained at a certain level, so a control valve is needed to regulate the flow rate into the reactor. It is impossible to achieve precise results manually, so automatic equipment is needed to solve the problem. Almost all processes in the industrial world require automated equipment to control process parameters. Automation is not only necessary for smooth operation, safety, economy, and product quality, but is also a basic requirement. It is impossible for an industry not to involve process control, for example, control in an oil refining process.

There are many parameters that must be controlled in a process. Among the most common are pressure in a vessel or pipe and reactor, flow in a pipe, temperature in a process unit such as a heat exchanger, or the surface of a liquid (level) in a tank, and chemical concentration (Dong et al., 2024). In addition, there are several other parameters outside of the four above that are quite important and also need to be controlled due to specific process requirements, including: pH in the petrochemical industry, water cut (BS & W) in crude oil fields, product color in a gas liquefaction facility (NGL), and so on.

Understanding the process is one of the main factors in the successful control of the parameters that must be controlled. In practice, automatic control systems play an important role because they can improve dynamic system performance, improve product quality, reduce production costs, increase production speed, and reduce routine work that was previously done by humans. The role of manual operators has now been largely replaced by a device called a controller. For example, the task of opening and closing valves is no longer done manually, but is controlled by a controller. For this control to run automatically, the valve needs to be equipped with a device called an actuator, so that the valve changes function to become a control valve. All equipment used in this control process, such as controllers and control valves, are known as part of the process control instrumentation system.

A controller is a system added to a plant to obtain the overall system performance characteristics as expected. One commonly used control method is PID (Proportional-Integral-Derivative) control. PID control serves to improve system performance by increasing the response to changing conditions. With the application of PID control, the system can reduce or even eliminate steady-state errors and increase the response speed in reaching the desired set point value.

## 2.2 Proportional (P) Control

Proportional control is a controller whose output signal ( $p(t)$ ) is proportional to the error ( $e(t)$ ), which is the difference between the set point and the measurement result, which can be expressed mathematically as follows:

$$p(t) = \bar{p} + K_c \times \text{error}(t) \quad (2.1)$$

Based on this approach, where  $K_c$  is the proportional gain that indicates the responsiveness of the controller to the setup or correction process provided to achieve the set point. The proportional gain is adjusted to regulate how responsive the system is to differences between the set point and the process variable.

The proportional controller has two parameters, namely: proportional band and proportional constant. The effective working range of the controller is reflected by the proportional band, while the proportional constant indicates the amplification factor value for the error signal,  $K_C$ . The relationship between the proportional band (PB) and the proportional constant ( $K_C$ ) is shown as follows:

$$PB = \left( \frac{1}{K_C} \right) \times 100\% \quad (2.2)$$

This control system is a very simple form of process control system with a very fast response to set points and disturbances in the process, but it has a large steady state error characteristic.

Characteristics of proportional controllers:

1. When the  $K_C$  value is small, proportional controllers are only capable of making small error corrections, resulting in a slow system response (increasing rise time).
2. When the  $K_C$  value is increased, the system response will reach a steady state more quickly (reducing rise time).
3. However, if the  $K_C$  value is increased to an excessive level, it will cause the system to become unstable or the system response will oscillate/overshoot.
4. The  $K_C$  value can be adjusted to reduce steady state error, but not eliminate

it.

### 2.3 Integral (I) Control

Integral control serves to eliminate errors as a whole, especially steady-state errors. The main purpose of the integral component is to ensure that the error between the set point and the system output becomes zero. It works by continuously calculating errors over time, then summing them (integration) to produce a control signal.

$$p(t) = \bar{p} + \frac{1}{\tau_i} \int_0^t \text{error}(t_i) dt_i \quad (2.3)$$

By integrating errors, the system output value can be corrected cumulatively, especially when errors occur over a long period of time. However, integral control is rarely used alone because it has several disadvantages. One common problem that arises is reset windup, which is a condition where the accumulation of errors causes the control signal to exceed the control valve's capacity (control valve) which is already in a saturated state (fully open), so that the system no longer responds to control commands. This can cause overshoot or even cause the controller to lose its function as a controller. To overcome this, additional methods such as anti-reset windup are usually used to keep the system response stable, responsive, and controlled.

### 2.4 Derivative (D) Control

Derivative control serves to anticipate error signals that will occur by observing the rate of change and predicting changes so that the system reacts more quickly and intelligently to changes. Derivative controllers are known for their speed of action, pre-action, or anticipatory control. Their function is to anticipate error signals that will occur by observing the speed of change and predicting changes. Derivative controllers can accelerate system response, thereby reducing overshoot (signals exceeding the set point).

$$p(t) = \bar{p} + \tau_i \frac{d \text{error}(t)}{dt} \quad (2.4)$$

Derivative controllers help the system respond more quickly at the beginning and prevent signals from exceeding the desired value (set point). It works by observing how quickly the error changes. If the error increases rapidly, the controller will react immediately before the error becomes too large. Conversely, if the error decreases rapidly, the controller will reduce its reaction

so that it does not decrease excessively. This makes the system more stable, less likely to exceed limits, and quicker to reach a stable condition.

## 2.5 Proportional Integral (PI) Control

A PI controller is a combined control system consisting of a proportional and integral controller. An integral controller is used to eliminate errors by integrating the error over a certain period until the error is “zero” or there is no error at all. The output form of the controller depends on the integral of the signal error over the entire time, where:

$$\Delta Q_{\text{output}} = K_i \int i. dt \quad (2.5)$$

or

$$p(t) = \bar{p} + K_c(\text{error}(t) + \frac{1}{\tau_i} \int_0^t \text{error}(t_i) dt_i) \quad (2.6)$$

$K_i$  = integral gain or “reset rate” (repeat/minute)

$K_c$  = amount of correction given

$\tau_i$  = integral time or reset time

Integral control is also known as “reset,” which has a relatively slow response but is quite effective for controlling fast processes that contain large disturbances and are dominated by the dead time of product transport. Its effect on steady-state error is relatively small. This control is commonly used to reduce the offset between the set point and the process variable.

## 2.6 Proportional Integral Derivative (PID) Control

Proportional Integral Derivative (PID) control is a type of system control that combines three different control elements, namely proportional, integral, and derivative. PID control is used to determine the values of  $K_p$ ,  $T_i$ , and  $T_d$ . The derivative of this control is commonly known as the “rate.” The value of this parameter basically means how far into the future you want to predict the rate of change. The equation model used is:

$$\Delta Q_{\text{output}} = K_d \frac{d \text{error}(t)}{dt} \quad (2.7)$$

or

$$p(t) = \bar{p} + K_c(\text{error}(t) + \frac{1}{\tau_i} \int_0^t \text{error}(t_i) dt_i + \tau_D \frac{d \text{error}(t)}{dt}) \quad (2.8)$$

$K_d$  = time constant

$\tau_D$  = derivative time

The derivative model never stands alone but is always accompanied by proportional or proportional-integral because derivative control only changes when there is an error change, so when the error is static (fixed), this control will not react. In PID control, there are three parameters that can be set, namely  $K_c$ ,  $\tau_i$  and  $\tau_D$ . In PID control itself, it is necessary to avoid derivative kick (large disturbances) by adjusting the existing parameters.

## 2.7 Ziegler-Nichols Method

Tuning is the process of adjusting parameter values in a controller, such as PID (Proportional, Integral, Derivative), so that the system can work properly as desired. In control systems, tuning is very important because it determines how quickly, stably, and accurately the system responds to changes or disturbances. If tuning is done correctly, the system will respond quickly without excessive oscillation, will not be too slow, and will be able to reach the target or set point efficiently. The tuning process is usually done by trial and error with parameter values, using mathematical methods, or experimental approaches, depending on the type of system and the information available.

One tuning method used is the Ziegler-Nichols method. The Ziegler-Nichols method is a practical way to tune a PID controller so that the system can work quickly and stably, without needing to know the formula or mathematical model of the system. This method is done by observing how the system responds when we change the input, then from that observation we determine the appropriate PID parameter values. The goal is for the system to respond quickly but remain stable, usually with an overshoot of around 25%. Because it is easy and does not require complicated calculations, this method is very useful in various industrial fields, such as temperature, pressure, flow, or other automatic systems that require a fast and efficient response.

The Ziegler-Nichols method for tuning PID controllers begins by setting the PID controller with integral ( $K_i$ ) and differential ( $K_d$ ) values equal to zero, with only the proportional gain ( $K_p$ ) active. Then, gradually increase the  $K_p$  value until the system begins to exhibit unstable oscillatory (fluctuating) behavior. The  $K_p$  value at the point when the system oscillates is called  $K_{MAX}$  (the maximum value at which the system can still operate but has started to oscillate). During oscillation, the frequency formed is called  $f_0$ . After reaching  $K_{MAX}$ , lower the  $K_p$  value to a lower level, which is usually set at around 50-75% of  $K_{MAX}$ . Finally, use the  $f_0$  value to set the integral ( $T_i$ ) and differential ( $T_d$ ) gain



values based on the formula specified by Ziegler-Nichols. Generally, the formula for setting PID parameters is as follows:

$$K_p = 0,6 \times K_{MAX} \quad (2.9)$$

$$T_i = \frac{1}{2 \times f_0} \quad (2.10)$$

$$T_d = \frac{1}{8 \times f_0} \quad (2.11)$$

(Ellis, 2012)

## 2.8 PCT 50 Level Control



Figure 2.1 PCT50 *level control*

PCT 50 is a level control process device that uses water as the working fluid for safety and user comfort. Water stored in the lower storage tank is transferred to the upper process vessel via a submerged variable speed centrifugal pump. A quick release connector allows the pump outlet pipe to be easily removed, facilitating the pump priming process after the lower tank is filled with water. The vertical inlet arrangement in the process vessel allows the water entering the vessel to remain visible regardless of the water level, and a non-valve (check valve) integral with the vessel prevents back flow into the storage tank when the pump speed is reduced or stopped. The in-line ball valve (CV1) above the quick release connector allows the flow of water entering the process vessel to be varied, regardless of the pump speed, to suit specific demonstrations.

The water level in the process vessel is measured using an electronic pressure sensor installed on the edge of the vessel. One side of the pressure sensor is connected inside the process vessel and the other side is open to the atmosphere, allowing the pressure inside the process vessel to be measured relative to the atmosphere. Therefore, this sensor measures the water level in the process vessel. The height level is also indicated on a scale on the side of the process vessel. Water flows from the process vessel back to the lower storage



tank through two outlets at the bottom of the process vessel. The flow through the main outlet is continuous. The flow through the second outlet can be started and stopped by a solenoid valve (SOL) with remote control. Both outlets are equipped with manually operated ball valves (CV2 and CV3) that allow the water flow to be continuously varied to suit specific demonstrations. Both outlets are also equipped with changeable orifices (3 and 5) that allow the flow to be set to a predetermined size. The size of the orifice is changed by removing the plastic cap containing the orifice and replacing it with another one of the required size. Installation uses 'O' ring seals and only requires hand tightening. Alternative orifice sizes are stored in threaded holes in the front of the base plate when not in use.

Overflow in the process vessel returns water to the storage tank, preventing overfilling of the process vessel during use. The pressure sensor that measures the level, centrifugal pump, and solenoid valve are connected to an electrical interface that combines the necessary signal conditioning, allowing the process to be operated directly from a PC using a single USB port. The computer software included with the PCT 50 allows for level process control and response data logging using a PC. Alternatively, the software allows data logging only when operating the process remotely using a PID controller. When filled with water, the PCT 50 is self-contained and requires only a main power supply to the in-line DC converter and a connection to a PC via the USB port. The unit is drained using a drain located at the rear.

## CHAPTER III

### PRACTICUM METHOD

#### 3.1 Practicum Design

##### 3.1.1 Practicum Design

Figure 3.1 Practical design

##### 3.1.2 Variable Determination

#### 3.2 Materials and Tools Used

##### 3.2.1 Materials

*Aquadest 8 Liter*

##### 3.2.2 Tools

*PCT 50 Level Control*

#### 3.3 Tool Picture




Figure 3.2 PCT 50 level control tool and its parts

- |   |  |
|---|--|
| <p>(1) <i>Upper Process Vessel</i></p> <p>(2) <i>Level Sensor</i></p> <p>(3) <i>Manual Discharge Port</i></p> <p>(4) <i>Electrical interface</i></p> <p>(5) <i>Solenoid Discharge Port</i></p> <p>(6) <i>Overflow</i></p> <p>(7) <i>Inlet</i></p> <p>(8) <i>Integral non-return valve</i></p> | <p>(9) <i>Quick Release Conenector</i></p> <p>(10) <i>Centrifugal Pump</i></p> <p>(11) <i>Water Discharge</i></p> <p>(12) <i>Alternative sizes of orifice</i></p> <p>(CV1) <i>Control Valve 1</i></p> <p>(CV2) <i>Control Valve 2</i></p> <p>(CV3) <i>Control Valve 3</i></p> <p>(SOL) <i>Solenoid Drain Valve</i></p> |
|---|--|

### 3.4 Trial Procedure

#### 3.4.1 *Installing Software Armfield Level Control*

1. Install the driver first by going to this PC, right click then select properties then select device manager.
2. Insert the USB into the laptop, after which COM 5 will appear with an exclamation mark. Make sure the PCT-50 has turned on with the green light indicator on.
3. Remove the exclamation mark by updating the driver. Find the PCT-50 folder then select the second order icon from the top then select install by following the steps on the driver. The laptop will automatically restart after the installation process is complete.
4. Make sure the USB is connected perfectly so that the connection between the PCT-50 tool and the laptop is not cut off suddenly. Also make sure that when you want to use it, it is not in a scanning state.

#### 3.4.2 Practical Implementation

##### a. Find the maximum level

1. Plug the power cord of the appliance into the power source;
2. Calibrate the tool with the following procedure:
  - 1) Close the CV2 output valve at the bottom of the process vessel, then pour about 10 mm of distilled water into the process vessel.
  - 2) Open the CV2 outlet valve and allow the distilled water to drain from the process vessel into the sump until the process vessel is empty.
  - 3) Ensure that the drain valve at the rear of the sump tank is securely closed, then fill the bottom of the sump tank with clean aquadest to approximately 30 mm below the opening at the front of the tank.
  - 4) Ensure that flow control valve CV1 is fully open at the inlet of the process vessel so that distilled water can flow into the vessel while the pump is running.
  - 5) Ensure output valve CV2 is fully open at the base of the process vessel to allow the aquadest to return to the sump tank as the process vessel fills with aquadest.
  - 6) Ensure output valve CV2 is fully open at the base of the process vessel to allow aquadest to return to the sump tank when the process vessel is filled with aquadest.

- 7) Ensure valve CV3 is fully open above the SOL solenoid valve to drain the aquadest back to the sump tank when the solenoid valve is open and the process vessel is filled with aquadest.
- 8) Open the drain valve to remove any water in the sump tank.
3. Open valve CV2 and close the drain valve;
4. Fill the tank with 8 liters of distilled water;
5. Turn on the computer/laptop that has the PCT-50 software installed;
6. Set the sample interval and fixed duration on the sample configuration menu according to the predetermined variables.
7. Set the variables (pump speed, set point, proportional band, integral time, derivative time, and mode of operation) that have been determined in the PID menu.
8. Operate the tool according to the specified variables by clicking power on and go to record the data obtained;
9. Observe the graph obtained in the graph menu, take and save the practicum data according to the data listed in the PCT-50 application (excel);
10. If the time has reached the desired, decrease the pump speed to return the water to the tank.
11. Perform steps 7-9 with different variables (operating modes).

**b. Find the value of PID**

1. Ensure that the process vessel tank is empty.
2. Set the variables (set point and proportional band) that have been determined in the PID menu.
3. Operating mode is done in automatic mode.
4. Operate the tool according to the specified variables by clicking power on and go to record the data obtained.
5. Observe the graph obtained in the graph menu. If it is stable, check the data to get the PC value.
6. The PC value is entered and calculated into excel calculations.
7. Input the calculation results in excel to the PID menu.
8. Operate the device and observe the graph, take and save the practical data according to the data listed in the PCT-50 application (excel).



9. After all is done, clean the equipment by opening the drain valve so that the water in the tank drains out, make sure the water in the tank and process vessel is completely gone.
10. After cleaning and draining, the equipment can be turned off gradually.






Figure 3.3 Steps to use Armfield PCT 50 software

Process

Laboratory

## DAFTAR PUSTAKA

- Bennet, S. (1993). Development of the PID controller. *IEEE Control Systems*, 13(6), 58-62. doi: 10.1109/37.248006
- Dong, W., He, F., Wang, J., Wu, N., & Li, X. (2004). Modeling and numerical analysis of PID-controlled phase-change transpiration cooling. *International Journal of Thermal Sciences*, 196, 108729. <https://doi.org/10.1016/j.ijthermalsci.2023.108729>.
- Ellis, G. (2012). Chapter 6 - Four Types of Controllers. *Control System Design Guide (Fourth Edition)*, 97-119. <https://doi.org/10.1016/B978-0-12-385920-4.00006-0>
- Liu, H., Yu, Q., & Wu, Q. (2023). PID control model based on back propagation neural network optimized by adversarial learning-based grey wolf optimization. *Applied Sciences*, 13(8), 4767. <https://doi.org/10.3390/app13084767>.
- Seborg, D. E., Edgar, T. F., Mellichamp, D. A., & Doyle III, F. J. (2016). *Process Dynamics and Control Fourth Edition*. United States: John Wiley & Sons, Inc.
- Smith, C.A. & Armando B. Corripio. (1997). *Principles and Practice of Automatic Proses Control Second Edition*. New York: John Wiley & Sons, Inc.