

PROJECT INFORMATION

CUSTOMER NAME : Mangomist Resort
PLANT CAPACITY : 237.4kWp
:

237.4kWp (DC) PHOTOVOLTAIC SYSTEM
CONSISTING OF 654 WAAREE MODULES
EARTHING LAYOUT OF 526 PANELS ON SHEET ROOF

EARTH STRIP INSTALLATION GUIDE:-

1. EARTH STRIP SHOULD BE WELDED AND BOLTED AT EVERY EARTH STRIP JOINTS.
2. EARTH STRIP SHOULD BE WELDED AND BOLTED WITH EQUIPMENTS FOR EQUIPMENT GROUNDING. IF MANUFACTURER OF THE EQUIPMENT DO NOT ALLOW TO WELD THEN EARTH STRIP SHOULD BE TIGHTLY BOLTED WITH EQUIPMENT AT LEAST .

NOTES:

1. ALL DIMENSIONS ARE IN MM.
2. EQUIPMENT GROUNDING AND SYSTEM GROUNDING CONDUCTORS SHALL HAVE SHORTEST DISTANCE TO EARTH PIT WITH MINIMUM NUMBER OF BENDS/TURNS.
3. NON-CURRENT CARRYING METAL PARTS SHALL BE CONNECTED TO NEAR BY EARTH STRIP.
4. MODULES FRAME IS TO BE CONNECTED WITH 6 SQ.MM GROUNDING CABLE.
5. EPOXY PAINT TO BE APPLIED AT THE PLACE OF WELDING.
6. CONNECTION OF EARTH STRIP WITH EARTH ELECTRODE SHALL BE WITH SS 304 NUT,BOLT AND WASHER.
7. ALL BOLTED CONNECTION SHALL HAVE SPRING AND FLAT WASHER.
8. BASED ON THE TYPE OF AVAILABLE EARTH ELECTRODE,CONNECTION OF EARTH STRIP WITH ELECTRODE TO BE REFER EARTH PIT TYPE-1/2.
9. SPACING BETWEEN TWO EARTH ELECTRODES SHALL BE 6MTR IN CASE, IF IT IS NOT POSSIBLE TO MEET THIS CRITERIA THEN 3 MTR DISTANCE SHALL BE MAINTAINED AT LEAST.

BOLTED CONNECTION

6sq.mm cable

Alu Earth Strip 8mm

6sq.mm Cable

EARTHING STRIP CONNECTING
STRUCTURE TO COMMON
PHERIPHERAL SIDE STRIP
INSTALLATION

SHED - WEST ROOF (262 PANELS)

SHED - EAST ROOF (264 PANELS)

EP - 5 EP - 6

EP - 1 EP - 2

EP- 3 EP - 4

237.4kWp On-Grid system Mangomist Resort
Anekal Taluk,Banglore.

Itemref	Quantity	Title/Name, designation, material, dimension etc			Article No./Reference	
Designed by Lakshmi	Checked by	Approved by - date	Filename EL - 003	Date 07/01/2020	Scale N/A	
EcoSoch Solar Pvt Ltd			EARTHING LAYOUT			
DWG - EL - 003			Edition 04	Sheet 1/1		