

- Auto
- Thermal Faults
- Safety switch
- Emergency stop
- End limit switch high
- End limit switch low
- Moment fault

The fault inputs will make the object go into fault. The actual fault will be indicated on the SCADA system until the object is reset or as long as the fault is active.

Start counters is handled by the object

8.23.10 Standard regulator (Controller)

A standard regulator shall as a minimum be provided with the following functions and parameters:

- Status of the regulator : Auto, Local, Manual
- PID-regulator with adjustable parameters. The I-time shall be adjustable from 5 sec. to 5 min.
- Calculation set-point, low and high (option)
- Limitation of regulator output, low and high

Set point for regulator

- Manual adjusting by operator of set point
- Manual adjusting by operator of regulator output (regulator in manual).

Running in of all regulators shall be carried out by the Contractor.

8.23.11 Status/alarm handling 1

The status-handling object is a standard routine handling individual status/alarm inputs and command outputs. (Level switches etc.) or communication

All input can by means of the option word individually be configured to be status or alarm.

Status inputs will be indicated in the status word as long as the input is activated.

Alarm inputs will make the object go into fault. The actual fault will be indicated in the status word until the object is reset or as long as the input is active

8.23.12 System alarm

The system alarm handling object is a standard routine handling specific system alarms generated by CMS s and communication units.

The following alarms shall be generated and displayed at the CMS system.

- Cycles time limit exceeded
- Battery exhausted or missing
- I/O error with diagnostics