Hood information

Item #	Model	Length [in]	Material Exposed Unexposed	Weight of Hood	Exhaust Information: Total Exhaust [cfm]	S.P. [“H2O]	Collars [in] Length	Width	Qty	Supply Information: Total Supply [cfm]	S.P. [“H2O]	Collars [in] Length	Width	Qty	Weight of Plenum
H1	KVW-UV	84	18 GA. 304 S.S. 18 GA. 304 S.S.	922 lbs	1814	0.32	13	12	1						

Supply Devices

Item #	Type	Supply [cfm]	dpTot [“H2O]	Collar diam. [in]

Hood information

Item #	Filters: Type	Qty	Size	Lighting: Qty	Type	Fire suppression Size: 1 tanks: Type	Location	Switch panel: Type	Location
H1	KSA	8	Full KSA	6	LED				

Hood information

Item #	Ceiling closure panels: Height [in]	Qty	Backsplash panels: Qty	Type	Length [in]	Height [in]
H1						

Notes

Capture Jet® air is not Supply or Make Up Air. It is a proprietary technology to reduce Exhaust Air

KSA GREASE EXTRACTOR



MANUF: HALTON COMPANY
GREASE FILTER CLASSIFIED BY
U.L. UNDER FILE #R 13515

EFFECTIVE AREA = 1.25 SQUARE FEET PER FULL FILTER
0.75 SQUARE FEET PER HALF FILTER



(1) 1/2" ALL THREAD "BY OTHERS"
(2) 1/2" NUT "BY OTHERS"
(3) HANGER BRACKET

NOTE:
STRUCTURAL ENGINEER TO VERIFY
LOCAL REQUIREMENTS.
HANGING REQUIREMENTS ARE THE
RESPONSIBILITY OF
INSTALLING CONTRACTOR, LOCAL
CODES MUST BE FOLLOWED.



H1



H1

Preliminary drawing

All dimensions in inches

THIS DRAWING MUST BE CHECKED, SIGNED AND RETURNED TO THE APPROPRIATE FACTORY:
PLEASE VERIFY THE FOLLOWING:
1. ALL DIMENSIONS, LOCATION, MOUNTING POSITIONS AND CLEARANCES.
2. THE LOCATION AND TYPE OF COOKING EQUIPMENT.
NOTE TO APPROVER:
FOR CONTROLS & FIRE SUPPRESSION EQUIPMENT, EACH APPLIANCE REQUIRES A SEPARATE DRAWING.
FOR CONTROLS & FIRE SUPPRESSION EQUIPMENT, ONLY THE NUMBER OF SENSORS, SOLENOIDS, ETC. AS REQUIRED FOR THE SPECIFIED APPLIANCE WILL BE QUOTED.

☐ REVISE AND RESUBMIT
APPROVED FOR FABRICATION.
☐ WITH NO CHANGES
☐ WITH CHANGES AS NOTED
APPROVED BY
DATE

ASHRAE 90.1 2010 Compliant

MAIL APPROVED DRAWINGS TO APPROPRIATE FACTORY BELOW:
HALTON CO. (CANADA)
1021 BREVIK PLACE
MISSISSAUGA, ON L4W 3R7
1.905.624.0111 905.624.0301

HALTON CO. (USA)
101 INDUSTRIAL DRIVE
SCOTTSVILLE, KY 42164
1.270.237.5660

WEBSITE: WWW.HALTONCOMPANY.COM

REV.	REVISION DESCRIPTION	BY	DATE
1			
2			
3			
4			
5			
6			
7			

PROJECT: Go Grill, Central City (Rev.1)
LOCATION: Surrey, BC
DATE: 11/12/2017
DRAWN BY: N.O.
SCALE:
CONSULTANT:
DRAWING TITLE:
DRAWING No.:
REV. NO.:
SHEET NO.: of