



GLAZED OPENINGS IN EXPOSING BUILDING FACE							
ELEVATION	BUILDING FACE (GRADE TO UPPERMOST CEILING)	PROPOSED			PERMITTED (9.10.15.4.)		
		LIMITING DISTANCE	UNPROTECTED OPENINGS	PERCENTAGE OF UNPROTECTED OPENINGS	LIMITING DISTANCE	PERCENTAGE OF UNPROTECTED OPENINGS	UNPROTECTED OPENINGS
NORTH	64.65 m²	34.64 m	14.38 m²	22.24 %	MIN. 6 m	NO LIMIT	NO LIMIT
EAST	59.96 m²	7.17 m	1.61 m²	2.69 %	MIN. 1.2 m	MAX. 34 %	MAX. 20.39 m²
WEST	28.34 m²	53.84 m	1.61 m²	5.68 %	MIN. 1.2 m	NO LIMIT	NO LIMIT

Maximum Total Area of Exposing Building Face, m²	MAXIMUM AGGREGATE AREA OF GLAZED OPENINGS, % OF EXPOSING BUILDING FACE AREA													
	Limiting Distance, m													
	< 1.2	1.2	1.5	2	2.5	3	4	6	8	10	12	16	20	25
10	0	8	12	21	10	33	96	100	-	-	-	-	-	-
15	0	8	10	17	10	25	67	100	-	-	-	-	-	-
20	0	8	10	15	10	21	53	100	-	-	-	-	-	-
25	0	8	9	13	10	19	45	100	-	-	-	-	-	-
30	0	7	9	12	10	17	39	88	100	-	-	-	-	-
40	0	7	8	11	10	15	32	69	100	-	-	-	-	-
50	0	7	8	10	10	14	28	57	100	-	-	-	-	-
100	0	7	8	9	10	11	18	34	56	84	100	-	-	-
> 100	0	7	7	8	10	9	12	19	28	40	55	92	100	-

The undersigned has reviewed and takes the responsibility for this design, and has the qualifications and meets the requirements set out in the Ontario Building Code to be a designer.

QUALIFICATION INFORMATION  
Required unless design is exempt under 2.17.5.1 of the building code  
Michael MacNeill 47264  
NAME SIGNATURE BCIN

REGISTRATION INFORMATION  
Required unless design is exempt under 2.17.5.1 of the building code  
MacNeill Design Services 112901  
FIRM NAME BCIN

client  
Private Client

project  
Glen Morris Addition  
Private Address

The drawings and written material herein constitute original work of the designer, and as intellectual property and instruments of service, are subject to copyright and may not be reproduced, distributed, published or used in any way without the express written consent of the architect.

revisions  
1 Issued for Permit 2021-05-01

title  
Limiting Distances

project number 21002  
date 2021-01-07  
sheet

A0.02