

\\CRC\protocols\studies\v5motion\rslh_ep3d_vaso_4e_axial

TA: 7:46 PM: REF Voxel size: 0.8×0.8×0.8 mmPAT: 3 Rel. SNR: 1.00 : 684e6dda

Properties

Prio recon	Off
Load images to viewer	On
Inline movie	Off
Auto store images	On
Load images to stamp segments	Off
Load images to graphic segments	Off
Auto open inline display	Off
Auto close inline display	Off
Start measurement without further preparation	Off
Wait for user to start	Off
Start measurements	Single measurement

Routine

Slab group	1
Slabs	1
Position	Isocenter
Orientation	Transversal
Phase enc. dir.	A >> P
AutoAlign	---
Slab Scale	-10 %
Slices per slab	24
FoV read	186 mm
FoV phase	100.0 %
Slice thickness	0.75 mm
TR 1	71.3 ms
TR 2	4529 ms
TE 1	24.70 ms
Averages	1
Multi-echo Shots	1
Filter	Distortion Corr.(3D)
Coil elements	A32

Contrast - Common

TR 1	71.3 ms
TR 2	4529 ms
TE 1	24.70 ms
Multi-echo spacing	66.03 ms
Magn. preparation	Non-sel. HSN IR
TI 1	1515.6 ms
TI 2	3226.8 ms
Flip angle	60 deg
Fat suppr.	Fat sat.
Magn. Prep. Shots	1

Contrast - Dynamic

Averages	1
Averaging mode	Long term
Reconstruction	Magnitude
Measurements	100
Pause after meas.	0.0 s

Resolution - Common

FoV read	186 mm
FoV phase	100.0 %
Slice thickness	0.75 mm
Base resolution	248
Phase resolution	100 %
Slice resolution	100 %
Phase partial Fourier	6/8

Resolution - Common

Slice partial Fourier	Off
Interpolation	Off

Resolution - iPAT

PAT mode	CAIPIRINHA
Acc. factor PE	3
Ref. lines PE	75
Acc. factor 3D	1
Ref. lines 3D	22
CAIPI 3D Shift	0
Reference Scan Mode	GRE/separate
CAIPIRINHA mode	Free

Resolution - Filter Image

Image Filter	Off
Distortion Corr.	On
Mode	3D
Unfiltered images	Off
Prescan Normalize	Off
Normalize	Off
B1 filter	Off

Resolution - Filter Rawdata

Raw filter	Off
Elliptical filter	Off

Geometry - Common

Slab group	1
Slabs	1
Position	Isocenter
Orientation	Transversal
Phase enc. dir.	A >> P
Slab Scale	-10 %
Slices per slab	24
FoV read	186 mm
FoV phase	100.0 %
Slice thickness	0.75 mm
TR 1	71.3 ms
TR 2	4529 ms
Multi-slice mode	Interleaved
Series	Ascending
Multi-echo Shots	1

Geometry - AutoAlign

Slab group	1
Position	Isocenter
Orientation	Transversal
Phase enc. dir.	A >> P
AutoAlign	---
Initial Position	Isocenter
L	0.0 mm
P	0.0 mm
H	0.0 mm
Initial Rotation	0.00 deg
Initial Orientation	Transversal

Geometry - Saturation

Saturation mode	Standard
Fat suppr.	Fat sat.

System - Miscellaneous

Positioning mode	REF
Table position	H
Table position	0 mm
MSMA	S - C - T
Sagittal	R >> L
Coronal	A >> P
Transversal	F >> H
Coil Combine Mode	Sum of Squares
Save uncombined	Off
Matrix Optimization	Off
AutoAlign	---
Coil Select Mode	Default

System - Adjustments

B0 Shim mode	Standard
B1 Shim mode	TrueForm
Confirm freq. adjustment	Off
Assume Dominant Fat	Off
Assume Silicone	Off
Adjustment Tolerance	Auto

System - Adjust Volume

Position	Isocenter
Orientation	Transversal
Rotation	0.00 deg
A >> P	186 mm
R >> L	186 mm
F >> H	18 mm
Reset	Off

System - Tx/Rx

Frequency 1H	297.162474 MHz
Correction factor	1
Gain	Low
Img. Scale Cor.	1.000
Reset	Off
? Ref. amplitude 1H	0.000 V

Sequence - Part 1

Introduction	On
Dimension	3D
Reordering	Linear
Asymmetric echo	Off
Contrasts	1
Multi-slice mode	Interleaved
Echo spacing	1.05 ms
Bandwidth	1062 Hz/Px

Sequence - Part 2

EPI factor	62
Segmentation	1
RF pulse type	Normal
Gradient mode	Normal
Excitation	Slab-sel.
RF spoiling	On
Turbo factor	24

Sequence - Special

PATRef FA	3 deg
RF duration	3500 us
RF BWT product	15
Ernst T1	1200 ms
PATRef prep. shots	10
Volume dummy shots	0

Sequence - Special

Dummy Measurements	0
Invert PE	Off
Min. TE if PF	On
Echo Time Shift	On
Ramp Sampling	On
NORDIC	Off
Water Exc.	-none-
External PC	per Series
Saturation RF	per Shot
EPI rise time factor	1.10
Mosaic DICOMs	On
Modify IcePAT	On
HSN RF power scale	3.00
Inversion Delay	650 ms
Relaxation Delay	0 ms
Var. FA /MAGEC	4

Sequence - Assistant

Mode	Off
------	-----