

# Revised Load Interconnection System Impact Study Report

## For Queue Project Q17-0769

Otter Valley 230 kV  
January 29, 2018

### **1. Introduction**

This System Impact Study report documents the results of the analyses performed for interconnection request Q17-0769. The Interconnection Customer proposes a 184.2 MW large load (data center) facility interconnecting at the Otter Valley 230 kV substation in the Ohio area. The request was received on April 02, 2017. The study evaluated system intact and single contingency conditions using the regional planning case, including 377 higher-queued active requests and their assigned network upgrades.

### **2. Summary of Results**

The study did not identify any facilities overloaded as a result of the project. Network upgrade cost: \$0.  
Estimated network upgrade cost: \$0

### **3. Network Impacts**

#### **3.1 Load Deliverability Analysis**

No overloads identified.

#### **3.2 Multiple Facility Contingency Analysis**

No additional overloads were identified for multiple facility contingencies.

#### **3.3 Short Circuit and Stability**

Short circuit and stability analyses identified no additional network upgrades.

### **4. Required Network Upgrades and Cost Estimates**

None. Total network upgrade cost allocated to this project: \$0.

This report is a simulated study produced by the gridconstraint research prototype on a public synthetic-but-realistic PJM-footprint case; it is not a PJM document.