

# Generation Interconnection System Impact Study Report

## For Queue Project Q19-1344

Stumpy Lake 138 kV

November 21, 2021

### **1. Introduction**

This System Impact Study report documents the results of the analyses performed for interconnection request Q19-1344. The Interconnection Customer proposes a 206.0 MW natural gas combined cycle facility interconnecting at the Stumpy Lake 138 kV substation in the Virginia area. The request was received on November 29, 2019. The study evaluated system intact and single contingency conditions using the regional planning case, including 345 higher-queued active requests and their assigned network upgrades.

### **2. Summary of Results**

The study did not identify any facilities overloaded as a result of the project. Network upgrade cost: \$0.  
Estimated network upgrade cost: \$0

### **3. Network Impacts**

#### **3.1 Generator Deliverability and Single Contingency Analysis**

No overloads identified.

#### **3.2 Multiple Facility Contingency Analysis**

No additional overloads were identified for multiple facility contingencies.

#### **3.3 Short Circuit and Stability**

Short circuit and stability analyses identified no additional network upgrades.

### **4. Required Network Upgrades and Cost Estimates**

None. Total network upgrade cost allocated to this project: \$0.

This report is a simulated study produced by the gridconstraint research prototype on a public synthetic-but-realistic PJM-footprint case; it is not a PJM document.