

# Load Interconnection Request System Impact Study Report

## For Queue Project Q20-1541

J R Whiting 500 kV  
May 03, 2022

### **1. Introduction**

This System Impact Study report documents the results of the analyses performed for interconnection request Q20-1541. The Interconnection Customer proposes a 453.2 MW large load (data center) facility interconnecting at the J R Whiting 500 kV substation in the Michigan area. The request was received on August 04, 2020. The study evaluated system intact and single contingency conditions using the regional planning case, including 440 higher-queued active requests and their assigned network upgrades.

### **2. Summary of Results**

No thermal overloads attributable to this project were identified. No network upgrades are required. Estimated network upgrade cost: \$0

### **3. Network Impacts**

#### **3.1 Load Deliverability Analysis**

No overloads identified.

#### **3.2 Multiple Facility Contingency Analysis**

No additional overloads were identified for multiple facility contingencies.

#### **3.3 Short Circuit and Stability**

Short circuit and stability analyses identified no additional network upgrades.

### **4. Required Network Upgrades and Cost Estimates**

None. Total network upgrade cost allocated to this project: \$0.

This report is a simulated study produced by the gridconstraint research prototype on a public synthetic-but-realistic PJM-footprint case; it is not a PJM document.