

# Generation Interconnection Request System Impact Study Report

## For Queue Project Q21-1822

Mickens 138 kV  
June 24, 2023

### 1. Introduction

This System Impact Study report documents the results of the analyses performed for interconnection request Q21-1822. The Interconnection Customer proposes a 87.4 MW solar plus storage facility interconnecting at the Mickens 138 kV substation in the Virginia area. The request was received on July 21, 2021. The study evaluated system intact and single contingency conditions using the regional planning case, including 449 higher-queued active requests and their assigned network upgrades.

### 2. Summary of Results

The project was found to contribute (DFAX of 5% or greater) to 1 overloaded facility. The total estimated cost of the network upgrades allocated to this project is \$67,000.

### 3. Network Impacts

#### 3.1 Generator Deliverability and Single Contingency Analysis

| Monitored Facility                            | Contingency           | Loading (%) | Rating (MVA) | DFAX (%) |
|-----------------------------------------------|-----------------------|-------------|--------------|----------|
| Wheelabrator Portsmouth to Gosport 138kV Line | Mickens to Swan 138kV | 121.7       | 371          | 14.2     |

#### 3.2 Multiple Facility Contingency Analysis

No additional overloads were identified for multiple facility contingencies.

#### 3.3 Short Circuit and Stability

Short circuit and stability analyses identified no additional network upgrades.

### 4. Required Network Upgrades and Cost Estimates

| Facility                                      | Required Upgrade                            | Cost Estimate | Allocation to Project |
|-----------------------------------------------|---------------------------------------------|---------------|-----------------------|
| Gosport to Wheelabrator Portsmouth 138kV Line | Rebuild line with higher-capacity conductor | \$1,768,000   | 4% (\$67,000)         |
|                                               | Total allocated to project                  |               | \$67,000              |

This report is a simulated study produced by the gridconstraint research prototype on a public synthetic-but-realistic PJM-footprint case; it is not a PJM document.