



Software version	4.14-00
Unit under test	FULL_TEST_su_cavo_ps_pp1_V3
Filename	C:\Users\Public\Documents\CEETIS\Projects\FULL_TEST_su_cavo_ps_pp1_V3.project
Date/Time	09/05/2024 11:24:47
Serial number	Cable01

T e s t r e s u l t	
Continuity test	2 errors
LV isolation test	No commands
HV isolation test	1 error
Test of electrical components	No commands
Voltage and Current	No commands
Other tests	Pass
F A I L E D	

Ambient Temperature:°C

Ambient Rel.Humidity:%

CONTINUITY AND RESISTANCE MEASUREMENTS

-->LV channels

Parameters for continuity test

Current=500mA; Threshold=40Ohm; Trise=2ms; Twait=2s; Tmeas=1ms; Auto ranging=On; Voltage limit=48V

Parameters for continuity test

Threshold=10hm

✓ Passed	LV1	LV1 S	LV1 Sr	559,4mOhm
✓ Passed	LVreturn1	LVR1 S	LVR1 Sr	557,1mOhm
✓ Passed	LV2	LV2 S	LV2 Sr	563,8mOhm
✓ Passed	LVreturn2	LVR2 S	LVR2 Sr	556,2mOhm
✓ Passed	LV3	LV3 S	LV3 Sr	564,9mOhm
✓ Passed	LVreturn3	LVR3 S	LVR3 Sr	559mOhm
✓ Passed	LV4	LV4 S	LV4 Sr	558,5mOhm
✓ Passed	LVreturn4	LVR4 S	LVR4 Sr	552,6mOhm
✓ Passed	LV5	LV5 S	LV5 Sr	558,2mOhm
✓ Passed	LVreturn5	LVR5 S	LVR5 Sr	553,1mOhm
✓ Passed	LV6	LV6 S	LV6 Sr	548mOhm
✓ Passed	LVreturn6	LVR6 S	LVR6 Sr	551,6mOhm
✓ Passed	LV7	LV7 S	LV7 Sr	567,4mOhm
✓ Passed	LVreturn7	LVR7 S	LVR7 Sr	553,1mOhm
✓ Passed	LV8	LV8 S	LV8 Sr	544,9mOhm
✓ Passed	LVreturn8	LVR8 S	LVR8 Sr	543,6mOhm
✓ Passed	LV9	LV9 S	LV9 Sr	567,3mOhm
✓ Passed	LVreturn9	LVR9 S	LVR9 Sr	558,7mOhm
✓ Passed	LV10	LV10 S	LV10 Sr	562,6mOhm
✓ Passed	LVreturn10	LVR10 S	LVR10 Sr	558,2mOhm
✓ Passed	LV11	LV11 S	LV11 Sr	565,7mOhm
✓ Passed	LVreturn11	LVR11 S	LVR11 Sr	564,6mOhm
✓ Passed	LV12	LV12 S	LV12 Sr	562mOhm
Passed	LVreturn12	LVR12 S	LVR12 Sr	565,7mOhm

✓				
✓	Passed	PH	PH S	PH Sr
✓	Passed	PHreturn	PHR S	PHR Sr
	--> Drains			
✗	Open	Drain	Drain S	Drain r
	HV channels and Tsensor			
	Parameters for continuity test			
	Threshold=15Ohm			
✓	Passed	Tsensor1	TS1 S	TS1 Sr
✓	Passed	Tsensor2	TS2 S	TS2 Sr
✗	Open	Tsensor3	TS3 S	TS3 Sr
✓	Passed	Tsensor4	TS4 S	TS4 Sr
✓	Passed	H1	H1 S	H1 Sr
✓	Passed	H2	H2 S	H2 Sr
✓	Passed	H3	H3 S	H3 Sr
✓	Passed	H4	H4 S	H4 Sr
✓	Passed	HR1	HR1 S	HR1 Sr
✓	Passed	H5	H5 S	H5 Sr
✓	Passed	H6	H6 S	H6 Sr
✓	Passed	H7	H7 S	H7 Sr
✓	Passed	H8	H8 S	H8 Sr
✓	Passed	HR2	HR2 S	HR2 Sr
✓	Passed	H9	H9 S	H9 Sr
✓	Passed	H10	H10 S	H10 Sr
✓	Passed	H11	H11 S	H11 Sr
✓	Passed	H12	H12 S	H12 Sr
✓	Passed	HR3	HR3 S	HR3 Sr

INSULATION TEST 1 VS all

--> LV channels

Parameters for HV isolation test

Voltage=50V; Threshold=100MOhm; Trise=10s; Twait=3s; Tmeas=1s; Auto ranging=On; Current limit=1,95mA; Tmeas red.=Off; Tmeas fact.=1; Voltage ramp=120V/s

Parameters for HV isolation test

Trise=1s; Twait=8s; Tmeas=8s

Passed; LV1; 2311273771.69321; Ohm; 2,311GOhm
 Passed; LVR1; 1993541157.42706; Ohm; 1,994GOhm
 Passed; LV2; 1988244827.50544; Ohm; 1,988GOhm
 Passed; LVR2; 2301396691.46384; Ohm; 2,301GOhm
 Passed; LV3; 2309193526.26052; Ohm; 2,309GOhm
 Passed; LVR3; 1663244834.21197; Ohm; 1,663GOhm
 Passed; LV4; 1290735498.37421; Ohm; 1,291GOhm
 Passed; LVR4; 1032925156.20429; Ohm; 1,033GOhm
 Passed; LV5; 2259416624.04094; Ohm; 2,259GOhm
 Passed; LVR5; 1601703189.78743; Ohm; 1,602GOhm
 Passed; LV6; 1276406993.25255; Ohm; 1,276GOhm
 Passed; LVR6; 1144959028.19898; Ohm; 1,145GOhm
 Passed; LV7; 1625819390.97378; Ohm; 1,626GOhm
 Passed; LVR7; 1985974797.26275; Ohm; 1,986GOhm
 Passed; LV8; 1774093257.25668; Ohm; 1,774GOhm
 Passed; LVR8; 787109863.673495; Ohm; 787,1MOhm
 Passed; LV9; 2535292844.86757; Ohm; 2,535GOhm
 Passed; LVR9; 2071526908.10781; Ohm; 2,072GOhm
 Passed; LV10; 1414965425.21754; Ohm; 1,415GOhm
 Passed; LVR10; 2298480100.32004; Ohm; 2,298GOhm
 Passed; LV11; 2004374677.87577; Ohm; 2,004GOhm
 Passed; LVR11; 1787329239.47976; Ohm; 1,787GOhm
 Passed; LV12; 1906445997.15821; Ohm; 1,906GOhm
 Passed; LVR12; 1667787993.86862; Ohm; 1,668GOhm

Passed; PH; 1529818173.94454; Ohm; 1,53GOhm
Passed; PHR; 1991465713.41551; Ohm; 1,991GOhm
--> HV channels

Parameters for HV isolation test

Voltage=1,2kV; Threshold=1GOhm; Trise=10s; Tmeas=1s

✓	Passed	HV1	H1 F	34,44GOhm
✓	Passed	HV2	H2 F	>98,41GOhm
✓	Passed	HV3	H3 F	>98,41GOhm
✓	Passed	HV4	H4 F	75,2GOhm
✓	Passed	HV5	H5 F	>98,41GOhm
✓	Passed	HV6	H6 F	>98,41GOhm
✓	Passed	HV7	H7 F	>98,41GOhm
✓	Passed	HV8	H8 F	>98,41GOhm
✓	Passed	HV9	H9 F	>98,41GOhm
✓	Passed	HV10	H10 F	>98,41GOhm
✓	Passed	HV11	H11 F	>98,41GOhm
✓	Passed	HV12	H12 F	>98,41GOhm
✓	Passed	HVreturn1	HR1 F	>98,41GOhm
✓	Passed	HVreturn2	HR2 F	>98,41GOhm
✓	Passed	HVreturn3	HR3 F	>98,41GOhm

Parameters for HV isolation test

Voltage=50V; Threshold=100MOhm; Trise=1s; Tmeas=2s

✓	Passed	Tsensor1	TS1 F	>4,101GOhm
✓	Passed	Tsensor2	TS2 F	>4,101GOhm
✓	Passed	Tsensor3	TS3 F	>4,101GOhm
✗	Short	Tsensor4	TS4 F	?NotSearched? <25,51kOhm

INSULATION GROUP TEST

--> LV channels

Parameters for HV isolation test

Threshold=10MOhm

Passed; LV_group; 136443657.878759; Ohm; 136,4MOhm

--> HV channels

Parameters for HV isolation test

Voltage=1,2kV; Threshold=100MOhm; Trise=10s

✓	Passed	HV_group	HV	Low group	>4,921GOhm
---	--------	----------	----	-----------	------------









