

Real-Time Control of Electrical Distribution Grids

Jean-Yves Le Boudec^{1,2}

EPFL

Simons Institute / Societal Networks

Mar. 26 – Mar. 29, 2018

¹ <https://people.epfl.ch/105633/research>

² <http://smartgrid.epfl.ch>

Credits

Joint work

EPFL-DESL (Electrical Engineering)
and LCA2 (I&C)

Supported by



Energy Turnaround
National Research Programme NRP 70



Contributors

Jagdish Achara
Andrey Bernstein
Niek Bouman
Benoit Cathiard
Andreas Kettner
Maaz Mohiuddin
Mario Paolone
Marco Pignati
Lorenzo Reyes
Roman Rudnik
Erica Scolari
Wajeb Saab
Cong Wang

Contents

1. Real-time operation of
electrical distribution grids
(COMMELEC)
2. V-control

1. Real-Time Operation of Microgrid: Motivation


Absence of inertia (inverters)

Stochastic generation (PV)

Storage, demand response

Grid stress (charging stations,
heat pumps)

Support main grid (primary and secondary frequency support)




⇒ Agent based, real-time control of microgrid

COMMELEC Uses Explicit Power Setpoints

Every 100 msec

- Grid Agent monitors grid and sends **power setpoints** to Resource Agents
- Resource agent sends to grid agent: PQ profile, Virtual Cost and **Belief Function**



Goal: manage quality of service in grid; support main grid; use resources optimally.

[Bernstein et al 2015, Reyes et al 2015]

<https://github.com/LCA2-EPFL/commelec-api>


PQ profile = set of setpoints that this resource is willing to receive

Belief Function

Say grid agent requests setpoint $(P_{\text{set}}, Q_{\text{set}})$ from a resource; actual setpoint (P, Q) will, in general, differ.

Belief function exported by resource agent means: the resource implements $(P, Q) \in BF(P_{\text{set}}, Q_{\text{set}})$

Quantifies uncertainty due to nature +
local inverter controller
Essential for safe operation




Operation of Grid Agent

Grid agent computes a setpoint vector x that minimizes

$$J(x) = \sum_i \underbrace{w_i C_i(x_i)}_{\text{Virtual cost of the resources}} + \underbrace{W(z)}_{\text{Penalty function of grid electrical state } z \text{ (e.g., voltages close to 1 p.u., line currents below the ampacity)}} + \underbrace{J_0(x_0)}_{\text{Cost of power flow at point of common connection}}$$

subject to **admissibility**.


x is admissible $\Leftrightarrow (\forall x' \in BF(x), \quad x' \text{ satisfies security constraints})$



Implementation / EPFL Microgrid

Topology: 1:1 scale of the Cigré low-voltage microgrid benchmark TF C6.04.02 [Reyes et al, 2018]


- Phasor Measurement Units:
nodal voltage/current synchrophasors @50 fps
- Solar PVs on roof and facade
- Battery
- Thermal Load (flex house)



Dispatch and Primary-Frequency Support

Superposition of dispatch and primary frequency control (i.e., primary droop control) with a max regulating energy of 200 kW/Hz

In parallel, keep the internal state of the local grid in a feasible operating condition.



COMMELEC Uses Active Replication with Real-Time Consensus

iPRP: transparent duplication of IP multicast and redundant networks

Axo: makes sure delayed messages are not used

Quarts: grid agents perform **agreement on input**

Added latency \leq one RTT – compare to consensus's unbounded delay


[Mohiuddin et al 2017, Saab et al 2017]

<https://github.com/LCA2-EPFL/iprp>

2. Controlling the Electrical State with Uncertain Power Setpoints

Admissibility test: when issuing power setpoint s , grid agent tests whether the grid is safe during the next control interval for all power injections in the set $S = BF(s)$.

Load Flow Mapping



Electrical state $v \in \mathbb{C}^{3N}$: collection of complex phasors

Power injection $s \in \mathbb{C}^{3N}$: collection of complex powers injected (generated or consumed) at all nodes

Load flow mapping $s = F(v)$ is quadratic.

Inverse problem “find v given s ” has 0 or many solutions.

Security constraints are constraints on v bearing on voltage and currents + non-singularity of ∇F_v


Controlling the Electrical State with Uncertain Power Setpoints

Admissibility test: when issuing power setpoint s , grid agent tests whether the grid is safe during the next control interval for all power injections in the set $S = BF(s)$.

The abstract problem is:

- given an initial electrical state v of the grid
 - given that the power injections s remain in some uncertainty set \mathcal{S}
- can we be sure that the resulting state of grid satisfies security constraints and is non-singular ?

\mathcal{V} -Control




\mathcal{S} is a **domain of \mathcal{V} -control** \Leftrightarrow whenever $t \mapsto v(t)$ is continuous, knowing that $v(0) \in \mathcal{V}$ and $\forall t \geq 0, F(v(t)) \in \mathcal{S}$ ensures that $\forall t \geq 0, v(t) \in \mathcal{V}$.

[Wang et al 2017b]




3-phase grid with one slack bus and N PQ buses; v = electrical state = complex voltage at all non slack buses; s = power injection vector at all non slack buses

Existence of Load Flow Solution Does not Imply V-control





For \mathcal{S} to be a domain of \mathcal{V} -control it is necessary that every $s \in \mathcal{S}$ has a load-flow solution in \mathcal{V} .

But this is not sufficient.




Every $s \in \mathcal{S}$ has a load-flow solution in \mathcal{V} .
But starting from s^0 and $v = \diamond$ we exit \mathcal{V} .








$\mathcal{V} = \{v: |v_1|, |v_2| \in [0.9; 1.1] \text{ and } \nabla F_v \text{ non singular}\}$
 $\mathcal{S} = \{s = \kappa(s_1^0, s_2^0), \kappa \in [0.992; 1]\}$
 $v = \diamond$ is in interior of \mathcal{V} , close to boundary (in s_1)

Unique Load Flow Solution Does not Imply V-control





Assume that every $s \in \mathcal{S}$ has a **unique** load-flow solution in \mathcal{V} .

This is **not sufficient** to guarantee that \mathcal{S} is a domain of \mathcal{V} -control.



Every $s \in \mathcal{S}$ has a unique load-flow solution in \mathcal{V} .
But starting from s^0 and $v = \diamond$ we exit \mathcal{V} .




$$\mathcal{V} = \mathcal{V}^A \cup \mathcal{V}^B$$

$$\mathcal{S} = \{s = \kappa(s_1^0, s_2^0), \kappa \in [0.999; 1]\} = \mathcal{S}^A \cup \mathcal{S}^B$$

$$\mathcal{S}^A = \{s = \kappa(s_1^0, s_2^0), \kappa \in (0.999915; 1]\}$$

$$\mathcal{S}^B = \{s = \kappa(s_1^0, s_2^0), \kappa \in [0.999; 0.999915]\}$$

Sufficient Condition for V-control




Theorem 3 in [Wang et al 2017b]

If

1. \mathcal{V} is open in \mathbb{C}^{3N}
 2. \mathcal{S} is open in \mathbb{C}^{3N}
 3. $\forall s \in \mathcal{S}$ there is a unique load-flow solution in \mathcal{V}
- then \mathcal{S} is a domain of \mathcal{V} -control.

In the previous example, neither \mathcal{V} nor \mathcal{S} is open.



V-control and Non-Singularity

We call v **non-singular** if ∇F_v is non-singular.


Theorem 3 in [Wang et al 2017b]

If

1. \mathcal{V} is open in \mathbb{C}^{3N}
2. \mathcal{S} is open in \mathbb{C}^{3N}
3. $\forall s \in \mathcal{S}$ there is a unique load-flow solution in \mathcal{V}

then \mathcal{S} is a domain of \mathcal{V} -control.

Furthermore, every $v \in \mathcal{V}$ such that $F(v) \in \mathcal{S}$ is **non-singular**.




Uniqueness and Non-Singularity

We call \mathcal{V} a **domain of uniqueness** iff


$$\forall v \in \mathcal{V}, \forall v' \in \mathcal{V}, v \neq v' \Rightarrow F(v) \neq F(v')$$

Theorem 1 in [Wang et al 2017b]

If \mathcal{V} is open in \mathbb{C}^{3N} and is a domain of uniqueness then every $v \in \mathcal{V}$ is non-singular.



In this previous example, \mathcal{V} is not a domain of uniqueness



Grid Agent's Admissibility Test

Problem (P): Given a set of power injections $\mathcal{S}^{uncertain}$, find a set of electrical states \mathcal{V} such that

1. $v(0) \in \mathcal{V}$
2. \mathcal{V} is open
3. \mathcal{V} is a domain of uniqueness
4. \mathcal{V} satisfies security constraints (voltages and line currents)
5. $\mathcal{S}^{uncertain} \subseteq F(\mathcal{V})$


By Theorems 1 and 3 (applied to \mathcal{V} and $\mathcal{S} = F(\mathcal{V})$), this will imply that \mathcal{V} is non singular and $\mathcal{S}^{uncertain}$ is a domain of \mathcal{V} -control.

Solving (P)

- Sufficient conditions for uniqueness and existence of load flow:
Theorem 1 in [Wang et al 2017a]

Given is a load-flow pair (\hat{v}, \hat{s}) . If $\xi(s - \hat{s}) < \rho^\ddagger(\hat{v})^2$ then s has a unique load flow solution in a disk around \hat{v} with radius $\rho^\ddagger(\hat{v})$. The norm $\xi()$ and ρ^\ddagger are derived from the Y matrix.

- Additional conditions (Def 3. in [Wang et al 2017b]) ensure security conditions.
- Domains can be patched (Thm 6 in [Wang et al 2017b])



Notation [Wang et al 2017b]

$$\delta_j(\hat{\mathbf{v}}, \mathbf{s}) \triangleq \frac{\sum_{\ell=1}^N |\mathbf{\Gamma}_{j,\ell}| |\text{diag}(\mathbf{w}_\ell)^{-1}| \boldsymbol{\eta}_\ell(\hat{\mathbf{v}}, \mathbf{s})}{u_{\min}(\hat{\mathbf{v}})(u_{\min}(\hat{\mathbf{v}}) - \rho^\dagger(\hat{\mathbf{v}}, \mathbf{s}))}; \quad (6)$$

zero-load nodal voltage $\mathbf{w} \triangleq -\mathbf{Y}_{LL}^{-1} \mathbf{Y}_{L0} \mathbf{v}_0$

- $\mathbf{\Gamma}_{j,\ell}$, $j, \ell \in \mathcal{N}^{PQ}$ is the 3×3 submatrix formed by rows $\{3j-2, 3j-1, 3j\}$ and columns $\{3\ell-2, 3\ell-1, 3\ell\}$ of \mathbf{Y}_{LL}^{-1} ;


Notation	Definition
\mathbf{W}	$\text{diag}(\mathbf{w})$
$\xi(\mathbf{s})$	$\ \mathbf{W}^{-1} \mathbf{Y}_{LL}^{-1} \overline{\mathbf{W}}^{-1} \text{diag}(\overline{\mathbf{s}})\ _\infty$
$u_{\min}(\mathbf{v})$	$\min_{j \in \mathcal{N}^{PQ}, \gamma \in \{a,b,c\}} v_j^\gamma / w_j^\gamma $
$\rho^\dagger(\mathbf{v})$	$\frac{1}{2} (u_{\min}(\mathbf{v}) - \xi(\mathbf{F}(\mathbf{v}))/u_{\min}(\mathbf{v}))$
$\rho^\dagger(\mathbf{v}, \mathbf{s}')$	$\rho^\dagger(\mathbf{v}) - \sqrt{\rho^\dagger(\mathbf{v})^2 - \xi(\mathbf{s}' - \mathbf{F}(\mathbf{v}))}$
$\boldsymbol{\eta}_\ell(\mathbf{v}, \mathbf{s}')$	$u_{\min}(\mathbf{v}) \mathbf{s}'_\ell - \mathbf{F}_\ell(\mathbf{v}) + \rho^\dagger(\mathbf{v}, \mathbf{s}') \mathbf{F}_\ell(\mathbf{v}) $

Patching Example

The algorithm tries if a single (\hat{v}, \mathcal{S}) works, else breaks the set \mathcal{S} into pieces and patches them.

IEEE 13-bus feeder, 3-phase configuration 602.

Uncertainty set



Round #	Bus 634 Phase b	Bus 671 Phase c	Bus 652 Phase a	Strictly secured candidate pair	Consistent with elements in \mathcal{L}	Action
1				No		<ul style="list-style-type: none"> Partition bus 671 phase c; Add 4 elements to \mathcal{L}^{aux}.
2				Yes	Yes	<ul style="list-style-type: none"> Add 1 element to \mathcal{L}.
3				Yes	Yes	<ul style="list-style-type: none"> Add 1 element to \mathcal{L}.
4				Yes	Yes	<ul style="list-style-type: none"> Add 1 element to \mathcal{L}.
5				No		<ul style="list-style-type: none"> Partition bus 634 phase b; Add 4 elements to \mathcal{L}^{aux}.
6				Yes	Yes	<ul style="list-style-type: none"> Add 1 element to \mathcal{L}.
7				Yes	Yes	<ul style="list-style-type: none"> Add 1 element to \mathcal{L}.
8				Yes	Yes	<ul style="list-style-type: none"> Add 1 element to \mathcal{L}.
9				Yes	Yes	<ul style="list-style-type: none"> Add 1 element to \mathcal{L}.

$+ F(\hat{v})$
 $\circ F(\tilde{v})$
 \mathcal{S}
 $\mathcal{S}^{\text{uncertain}}$

Performance Evaluation

IEEE 37 bus feeder. $\mathcal{S}^{uncertain} = [0, \kappa] \times$ benchmark values on all loaded phases. For $0 \leq \kappa \leq 1.15$ algorithm declares $\mathcal{S}^{uncertain}$ safe in one partition and <20 msec runtime on one i7; for $\kappa > 1.15$ the algorithm needs multiple partitions but lowest voltage bound is close to limit.

IEEE 123 bus feeder. $\mathcal{S}^{uncertain} = \left[1 - \frac{\kappa}{2}, 1 + \frac{\kappa}{2}\right] \times$ benchmark values on all loaded phases. For $0 \leq \kappa \leq .31$ algorithm declares $\mathcal{S}^{uncertain}$ safe in one partition and <30 msec runtime; for $\kappa > .31$ the algorithm needs multiple partitions but highest branch current is close to limit.


Performance Evaluation

IEEE 37 bus feeder. One source added to one unloaded phase. Uncertainty set as shown. We limit the number of partitions to 8.

For $\kappa \leq 0.750$ no partition.

For $\kappa = 0.992$, 8 partitions and run-time < 200 msec. Low voltage bound is close.

Incidentally, lowest voltage is not at $(0,0)$ nor (P^{\max}, Q^{\max}) (**non-monotonicity**)



Conclusions

Controlling state of a grid by **controlling power injections** helps solve the problems posed by stochastic loads and generations.

Concrete implementations exist (COMMELEC) and use commodity hardware with solutions for **active replication**.

Accounting for uncertainty is essential. Testing admissibility of uncertain power setpoints can use the theory of **V-control**.

References

- <http://smartgrid.epfl.ch>
- [Bernstein et al 2015, Reyes et al 2015a] Andrey Bernstein, Lorenzo Reyes-Chamorro, Jean-Yves Le Boudec , Mario Paolone, “A Composable Method for Real-Time Control of Active Distribution Networks with Explicit Power Setpoints, Part I and Part II”, in Electric Power Systems Research, vol. 125, num. August, p. 254-280, 2015.
- [Bernstein et al 2015b] Bernstein, A., Le Boudec, J.Y., Reyes-Chamorro, L. and Paolone, M., 2015, June. Real-time control of microgrids with explicit power setpoints: unintentional islanding. In PowerTech, 2015 IEEE Eindhoven (pp. 1-6). IEEE.
- [Nguyen Turitsyn 2014] Nguyen, H.D. and Turitsyn, K.S., 2014, July. Appearance of multiple stable load flow solutions under power flow reversal conditions. In PES General Meeting| Conference & Exposition, 2014 IEEE (pp. 1-5). IEEE.
- [Mohiuddin et al 2017] Mohiuddin, M., Saab, W., Bliudze, S. and Le Boudec, J.Y., 2017. Axo: Detection and Recovery for Delay and Crash Faults in Real-Time Control Systems. IEEE Transactions on Industrial Informatics.
- [Pignati et al 2015] M. Pignati et al , “Real-Time State Estimation of the EPFL-Campus Medium-Voltage Grid by Using PMUs”, Innovative Smart Grid Technologies (ISGT2015)
- [Popovic et al 2016] Popovic, M., Mohiuddin, M., Tomozei, D.C. and Le Boudec, J.Y., 2016. iPRP—The parallel redundancy protocol for IP networks: Protocol design and operation. IEEE Transactions on Industrial Informatics, 12(5), pp.1842-1854.
- [Reyes et al, 2018] Reyes-Chamorro, L., Bernstein, A., Bouman, N.J., Scolari, E., Kettner, A., Cathiard, B., Le Boudec, J.Y. and Paolone, M., 2018. Experimental Validation of an Explicit Power-Flow Primary Control in Microgrids. IEEE Transactions on Industrial Informatics.
- [Saab et al 2017] W. Saab, M. M. Maaz, S. Bliudze and J.-Y. Le Boudec. Quarts: Quick Agreement for Real-Time Control Systems. 22nd IEEE International Conference on Emerging Technologies And Factory Automation (ETFA), Limassol, Cyprus, 2017.015 IEEE World Conference on (pp. 1-4). IEEE.
- [Wang et al. 2016] Wang, C., Bernstein, A., Le Boudec, J.Y. and Paolone, M., 2016. Explicit conditions on existence and uniqueness of load-flow solutions in distribution networks. IEEE Transactions on Smart Grid.
- [Wang et al. 2017b] Wang, C., Bernstein, A., Le Boudec, J.Y. and Paolone, M., 2017. Existence and uniqueness of load-flow solutions in three-phase distribution networks. IEEE Transactions on Power Systems, 32(4), pp.3319-3320.
- [Wang et al. 2017b] Wang, C., Le Boudec, J.Y. and Paolone, M., 2017. Controlling the Electrical State via Uncertain Power Injections in Three-Phase Distribution Networks. IEEE Transactions on Smart Grid.