

STEPPED DISCHARGE TEST & RECOVERY

APT
GEOTECHNICAL SOLUTIONS

BOREHOLE TEST RECORD

PROJECT NO:	MAP REFERENCE:	PROVINCE:
BOREHOLE NO: MDW06	LATITUDE:	DISTRICT:
ALT BH NO:	LONGITUDE:	SITE NAME:
ALT BH NO:	ELEVATION:	
BOREHOLE DEPTH (m):	DATUM LEVEL ABOVE BOREHOLE (m): 0.5	EXISTING PUMP:
WATER LEVEL (mbdl): 5.12	CASING HEIGHT (magl):	CONTRACTOR:
DEPTH OF PUMP (m): 180	DIAM PUMP INLET (mm): 230	PUMP TYPE:

STEPPED DISCHARGE TEST & RECOVERY

DISCHARGE RATE 1				DISCHARGE RATE 2				RECOVERY		
DATE: 04-10-2025		TIME: 11:50		DATE: 04-10-2025		TIME: 14:00		DATE: 04-10-2025		TIME: 14:45
TIME (MIN)	WATER LEVEL (M)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	WATER LEVEL (M)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	WATER LEVEL (M)	RECOVERY (M)
0	5.12			0				0		
0.5	6.80			0.5	60.12			0.5	125.86	
1	7.79			1	60.93			1	124.10	
2	10.46			2	64.54			2	114.12	
3	12.71		2.10	3	69.79		3.93	3	108.13	
5	15.91		2.03	5	73.51		3.92	5	96.83	
7	18.57		2.00	7	80.27		4.00	7	86.87	
10	21.17		1.98	10	88.12		4.00	10	76.23	
15	26.40		2.03	15	99.40		3.96	15	64.80	
20	29.94		1.97	20	108.76		3.93	20	56.61	
30	32.96		2.00	30	121.20			30	43.81	
40	34.91		2.03	40	127.78			40	35.37	
50	35.38		2.01	50				50	34.81	
60	41.70		2.01	60				60	30.05	
70	45.80		1.93	70				70	23.84	
80	50.18		2.00	80				80	18.92	
90	53.88		2.00	90				90		
100	55.79		2.00	100				100	13.59	
110	57.18		2.01	110				110	12.10	
120	57.99		2.03	120				120	11.13	
130	58.19			150				150	9.52	
180				180				180	8.75	
210				210				210	8.27	
240				240				240	7.95	
pH:				pH:				300	7.53	
TEMP:		°C		TEMP:		°C		360	7.28	
EC:		µS/cm		EC:		µS/cm		420	7.09	
DISCHARGE RATE 3				DISCHARGE RATE 4				480	6.99	
DATE		TIME		DATE		TIME		540	6.86	
TIME (MIN)	WATER LEVEL (M)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	WATER LEVEL (M)	DRAW DOWN (M)	YIELD (L/S)	600	6.75	
0.5				0.5				720	6.61	
1	6			1				840	6.53	
2				2				960	6.49	
3				3				1080	6.47	
5				5				1200	6.46	
7				7				1320	6.45	
10				10				1440	6.42	
15				15				1560		
20				20				1680		
30				30				1800		
40				40				1920		
50				50				2040		
60				60				2160		
70				70				2280		
80				80				2400		
90				90				2520		
100				100				2640		
110				110				2760		
120				120				2880		
150				150				3000		
180				180				3120		
								3240		

Available draw down = 124.88m