

STEPPED DISCHARGE TEST & RECOVERY



BOREHOLE TEST RECORD

PROJECT NO:		MAP REFERENCE:		PROVINCE:	NORTH WESTERN
BOREHOLE NO:	MDW14	LATITUDE:		DISTRICT:	
ALT BH NO:		LONGITUDE:		SITE NAME:	MALUNDWE
ALT BH NO:		ELEVATION:		EXISTING PUMP:	NEW HOLE
BOREHOLE DEPTH (m):	180	DATUM LEVEL ABOVE CASING (m):		CONTRACTOR:	
WATER LEVEL (mbdl):	58.05	CASING HEIGHT (magl):		PUMP TYPE:	WA110-2
DEPTH OF PUMP (m):	148.25	DIAM PUMP INLET (mm):	230		

STEPPED DISCHARGE TEST & RECOVERY

DISCHARGE RATE 1				DISCHARGE RATE 2				RECOVERY		
DATE:	10/10/2025	TIME:	12:00	DATE:	10/10/2025	TIME:	14:00	DATE:		TIME:
TIME (MIN)	WATER LEVEL (M)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	WATER LEVEL (M)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	WATER LEVEL (M)	RECOVERY (M)
0				0				0		
0.5	61.19	3.14		0.5	68.66	10.61		0.5		
1	62.38	4.33		1	68.83	10.78		1		
2	63.39	5.34		2	73.90	15.85		2		
3	63.46	5.41	1.60	3	75.86	17.81		3		
5	63.78	5.73	2.20	5	79.87	21.82	4.93	5		
7	65.09	7.04		7	81.76	23.71		7		
10	66.17	8.12		10	82.90	24.85	4.77	10		
15	66.93	8.88	2.06	15	82.77	24.72	3.45	15		
20	67.44	9.39	2.06	20	82.33	24.28	4.47	20		
30	67.72	9.67	2.08	30	82.59	24.54	4.26	30		
40	68.00	9.95	2.05	40	82.81	24.76	4.53	40		
50	68.07	10.02	2.07	50	83.10	25.05	4.47	50		
60	68.12	10.07	2.01	60	82.77	24.72	4.23	60		
70	68.22	10.17	2.09	70	82.80	24.75	4.19	70		
80	68.19	10.14	2.15	80	82.68	24.63	4.23	80		
90	68.11	10.06	2.11	90	82.74	24.69	3.80	90		
100	68.13	10.08	2.19	100	82.84	24.79	4.35	100		
110	68.20	10.15	2.15	110	82.81	24.76	3.98	110		
120	68.33	10.28		120	82.85	24.80		120		
150				150				150		
180				180				180		
210				210				210		
240				240				240		
pH:				pH:				300		
TEMP:				TEMP:				360		
EC:				EC:				420		
DISCHARGE RATE 3				DISCHARGE RATE 4						
DATE:	10/10/2025	TIME:	16:00	DATE:	10/10/2025	TIME:	19:00			
TIME (MIN)	WATER LEVEL (M)	DRAW DOWN (M)	YIELD (L/S)	TIME (MIN)	WATER LEVEL (M)	DRAW DOWN (M)	YIELD (L/S)			
0.5	83.48	25.43		0.5	103.52	45.47				
1	84.06	26.01		1	103.86	45.81	7.10			
2	85.03	26.98	5.50	2	104.38	46.33	8.02			
3	86.77	28.72	5.08	3	104.87	46.82	7.83			
5	87.03	28.98	5.39	5	107.20	49.15	7.95			
7	88.10	30.05	5.14	7	107.93	49.88	7.93			
10	88.73	30.68	5.39	10	109.26	51.21	7.70			
15	91.37	33.32	5.47	15	115.33	57.28	7.95			
20	95.67	37.62	6.50	20	122.24	64.19	8.01			
30	99.02	40.97	6.48	30	126.30	68.25	7.91			
40	100.03	41.98	6.30	40	127.67	69.62	7.95			
50	100.82	42.77	6.47	50	128.12	70.07	7.89			
60	101.20	43.15	6.43	60	129.72	71.67	7.85			
70	101.50	43.45	6.40	70						
80	101.70	43.65	6.28	80						
90	101.84	43.79	6.19	90						
100	102.00	43.95	6.19	100						
110	102.09	44.04	6.16	110						
120	102.23	44.18	6.34	120						
150	102.87	44.82	6.35	150						
180	103.13	45.08		180						

AVAILABLE DRAWDOWN = 90.20