

RISK ASSESSMENT & METHOD STATEMENT

Test Groundworks Ltd • New Housing Development — Drainage & Substructure • RAMS-NEW-HOUSING-DEVELOPM-001 Rev A

PROJECT

New Housing Development —
Drainage & Substructure

SITE

Plot 1—40, Greenfield Road, Coventry,
CV3 3AB

PRINCIPAL CONTRACTOR

Main Build Ltd

PREPARED BY

Dave Jones — Site Manager

START DATE

2026-08-04

SELECTED TRADES (10)

- General Excavation (open cut)
- Deep Excavation (>1.2m — confined space rules apply)
- Trench Excavation for Services
- Foul Water Drainage Installation
- Surface Water Drainage Installation
- Precast Manhole Chamber Installation
- Pipe Laying (clay, PVC, concrete, HDPE)
- Confined Space Entry — Manholes & Chambers
- Wacker Plate / Vibrating Compactor Operations
- Strip Foundations

RISK ASSESSMENT — 9 ROWS

Ref	Hazard	Who at Risk	Pre-Score	Key Controls	Post-Score
RA-01	Excavation collapse / side wall failure During excavation to the required depth, the side walls may collapse due to soil instability, ground water ingress, surc...	Operatives working in or adjacent to the excavation	15 HIGH	• Competent person to assess ground conditions and battering/shoring requirements before and throughou... • Excavate in maximum 1m stages; batter sides at minimum 1:1 in granular soils or install proprietary ... • No operatives to enter unsupported excavation exceeding 1.2m depth at any time. + 3 more controls	5 LOW
RA-02	Buried services strike (gas, electric, water, telecoms) Underground services including gas mains, high and low voltage electrical cables, water mains, and telecoms ducts may be...	Operatives, adjacent workers, members of the public	15 HIGH	• Obtain statutory undertakers' plans for all services within the works area before commencing excavat... • Carry out CAT (Cable Avoidance Tool) and Genny survey of the entire excavation footprint before any ... • Issue a 'Permit to Dig' for every excavation; no mechanical dig within 0.5m of any known or suspecte... + 3 more controls	5 LOW
RA-03	Plant and pedestrian interface / collision 360° excavator and ancillary plant operating within the site boundary creates a risk of collision with operatives on foo...		12 MEDIUM	• Establish and maintain a pedestrian exclusion zone of minimum 3m around operating plant; demarcate w... • A trained banksman/slinger to be present during all manoeuvring and lifting operations; plant operat... • All plant to be fitted with working reversing alarms and rotating beacon; operatives to wear Class 2... + 2 more controls	4 LOW

		Operatives, banksmen, members of the public, adjacent workers			
RA-04	Slips, trips and falls adjacent to or into the excavation The excavation edge, uneven spoil heaps, and site compound present a risk of operatives and others slipping, tripping, o...	Operatives, site visitors, members of the public	9 MEDIUM	• Install edge protection (minimum 950mm high barriers with toeboards) around all open excavations; tr... • Maintain good housekeeping; clear spoil, surplus materials, and tools from walkways at end of each s... • Adequate lighting to be provided for any works outside daylight hours. + 2 more controls	3 LOW
RA-05	Manual handling of materials (pipes, manhole components, aggregate bags...) Manual handling of pipes, manhole components, aggregate bags and tools presents risk of musculoskeletal injury (back, sh...	Operatives	9 MEDIUM	• Plan all manual handling tasks in advance; use mechanical aids (excavator, pipe handler, pallet truc... • Restrict individual manual lifts to maximum 25kg; team lifts for loads between 25–50kg; mechanical l... • All operatives to have received manual handling awareness training; trained in correct posture, grip... + 2 more controls	4 LOW
RA-06	Water ingress and flooding of excavation Ground water, surface water run-off, or connection to existing drainage infrastructure may cause the excavation to flood...	Operatives within or adjacent to the excavation	12 MEDIUM	• Review ground investigation data and statutory drainage records before commencing; establish expecte... • Provide dewatering pump (minimum 2-inch submersible) on site before commencing excavation; test befo... • No operative to enter a flooded or partially flooded excavation under any circumstances. + 2 more controls	8 MEDIUM
RA-07	Hand-arm vibration (HAVS) from compaction and breaking equipment Use of vibrating plate compactors exposes operatives to hand-arm vibration in excess of the EAV of 2.5 m/s². Prolonged e...	Operatives using vibratory equipment	9 MEDIUM	• Conduct HAV exposure calculation for each tool before works commence; ensure daily exposure does not... • Implement job rotation to limit individual daily HAV exposure below the EAV (2.5 m/s²) wherever prac... • Provide anti-vibration gloves to all operatives using vibratory equipment; ensure gloves are manufac... + 3 more controls	6 LOW
RA-08	Noise-induced hearing loss from plant and equipment Plant and equipment used during these works will generate noise levels exceeding the Lower Exposure Action Value (LEAV) ...	Operatives, adjacent workers, members of the public	9 MEDIUM	• Carry out noise assessment identifying noise levels from each item of plant; designate hearing prote... • Mandatory hearing protection (min SNR 28 ear defenders or Class 5 earplugs) to be worn by all operat... • Members of the public and adjacent workers to be informed of noise-generating activities in advance ... + 2 more controls	4 LOW
RA-09	Welfare and dehydration / heat stress (during summer works) Operatives carrying out physically demanding groundworks in warm conditions risk dehydration, heat exhaustion, or heat s...	Operatives	6 LOW	• Adequate welfare facilities (drying room, WC, wash facilities) to be available on or adjacent to sit... • Fresh drinking water available on site at all times; operatives encouraged to drink regularly. • Rest breaks to be taken in shade where possible during hot weather. + 1 more controls	3 LOW