

24: Beam: T10  
Span: 0.9 m. Reactions: R1: 1.48 kN R2: 1.48 kN

Use 2no 47 x 220 C24  
Bearing R1:  
Hanger to T5  
Bearing R2:  
Post to floor

25: Beam: T11  
Span: 2.0 m. Reactions: R1: 1.42 kN R2: 1.61 kN

Use 2no 47 x 220 C24  
Bearing R1:  
hanger to T11  
Bearing R2: 10 mm m.s. bearing plate, size 94 x 100 mm

26: Beam: T12  
Span: 2.0 m. Reactions: R1: 6.78 kN R2: 6.78 kN

Use 2no 47 x 220 C24  
Bearing R1:  
Hangere to T8  
Bearing R2: 10 mm m.s. bearing plate, size 175 x 100 mm

27: Beam: T13  
Span: 1.0 m. Reactions: R1: 1.64 kN R2: 1.64 kN

Use 2no 50 x 220 C24

28: Beam: B2  
Span: 6.4 m. Reactions: R1: 38.46 kN R2: 33.63 kN  
Use 203 x 203 x 71 UC S355  
Bearing R1:  
Web ofT1 via 2 No 100x100x10 thick rt angle brackets and 2 No M16 bolts per face.  
Bearing R2: 30 mm m.s. bearing plate, size 650 x 120 mm

29: Beam: B1  
Span: 6.8 m. Reactions: R1: 70.95 kN R2: 37.72 kN  
Use 254 x 254 x 73 UC S355  
Bearing R1: 1600 x 100 mm padstone  
Or shs  
Bearing R2: 40 mm m.s. bearing plate, size 850 x 100 mm

30: Beam: I1  
Span: 1.1 m. Reactions: R1: 5.02 kN R2: 5.02 kN  
Use 203 x 203 x 46 UC S355  
Bearing R1: 10 mm m.s. bearing plate, size 204 x 205 mm  
Bearing R2: As R1

31: Beam: BA  
Span: 5.2 m. Reactions: R1: 6.47 kN R2: 6.47 kN  
Use 178 x 102 x 19 UB S355  
Bearing R1:  
Web of Lower spine wall beam via 2 No 100x100x10 thick rt angle brackets and 2 No M16 bolts per face.  
Bearing R2: 10 mm m.s. bearing plate, size 150 x 100 mm

32: Beam: BB  
Span: 4.1 m. Reactions: R1: 5.10 kN R2: 5.10 kN  
Use 178 x 102 x 19 UB S355  
Bearing R1: 10 mm m.s. bearing plate, size 125 x 100 mm  
Bearing R2:  
Web of Lower spine wall beam via 2 No 100x100x10 thick rt angle brackets and 2 No M16 bolts per face.

33: Beam: Lower Ground Spine beam  
Span: 6.6 m. Reactions: R1: 56.21 kN R2: 59.80 kN  
Use 254 x 254 x 89 UC S355  
Bearing R1: 1050 x 120 mm padstone  
Or SHS  
Bearing R2: 1150 x 120 mm padstone  
Or SHS

34: Beam: SHS1( R1 of lower ground floor beam)  
Span: 1.0 m. Reactions: R1: 28.33 kN R2: 28.33 kN  
Use 120 x 120 x 12.5 HF SHS S355 (40.9kg/m)

35: Beam: SHS2(R2 Of Lower ground floor bem)  
Span: 1.0 m. Reactions: R1: 30.13 kN R2: 30.13 kN  
Use 120 x 120 x 12.5 HF SHS S355 (40.9kg/m)

36: Beam: Upper Ground floo spine beam  
Span: 6.6 m. Reactions: R1: 77.83 kN R2: 89.94 kN  
Use 254 x 254 x 89 UC S355  
Bearing R1: 1750 x 100 x 75h mm padstone  
Or SHS  
Bearing R2: 2000 x 100 mm padstone  
Or SHS

37: Beam: SHS3 (R1 of B1)  
Span: 1.0 m. Reactions: R1: 35.70 kN R2: 35.70 kN  
Use 120 x 120 x 12.5 HF SHS S355 (40.9kg/m)

38: Beam: SHS4 (R2 of Upper ground floor beam)  
Span: 1.0 m. Reactions: R1: 45.19 kN R2: 45.19 kN  
Use 120 x 120 x 12.5 HF SHS S355 (40.9kg/m)

39: Beam: BC  
Span: 6.5 m. Reactions: R1: 8.09 kN R2: 8.09 kN  
Use 203 x 102 x 23 UB S355  
Bearing R1:  
Web of upper spine wall beam via 2 No 100x100x10 thick rt angle brackets and 2 No M16 bolts per face.  
Bearing R2: 10 mm m.s. bearing plate, size 200 x 100 mm

40: Beam: BD  
Span: 4.1 m. Reactions: R1: 5.10 kN R2: 5.10 kN  
Use 127 x 76 x 13 UB S355  
Bearing R1: 10 mm m.s. bearing plate, size 125 x 100 mm  
Bearing R2:  
Web of Upper spine wall beam via 2 No 100x100x10 thick rt angle brackets and 2 No M16 bolts per face.

TITLE

PROPOSED DRAWINGS

ADDRESS

95 MALVERN ROAD  
LONDON. NW6

CLIENT

Mr. C. NORMAN

SCALE

1:50 @ A3

DATE

MARCH 2019

DRAWING NO.

190328/31

REV.