



LEGHA KRISHI FARM
Aadarsh Visu Nagar, Post/GSS : Bhunia,
Teh : Dhanaui, District: Barmer (Raj) - 344704
LOA: 313557 GSTIN: 08AAECL1234F1ZR PAN: AAECL1234F

JOINT METER READING (JMR) REPORT

Plant Name: Legha Krishi Farm Month: June Year: 2025 Reading Date: 2025-07-07

MAIN METER

Parameter	Last Reading	Reading on End of Month	Diff	MF	Total
kWh Import	10000.00	40000.00	30000.00	1	30000.00
kWh Export	1000.00	4000.00	3000.00	1	3000.00
kVAh Import	8000.00	15000.00	7000.00	1	7000.00
kVAh Export	1500.00	2500.00	1000.00	1	1000.00
kVArh Q1 (Lag Import)	2.00	3.00	1.00	1	1.00
kVArh Q2 (Lead Import)	2000.00	4000.00	2000.00	1	2000.00
kVArh Q3 (Lag Export)	2.00	5.00	3.00	1	3.00
kVArh Q4 (Lead Export)	800.00	1200.00	400.00	1	400.00
Import Power Factor					-1.00
Export Power Factor					0.58
Import Billing MD (kVA)					12.00
Export Billing MD (kVA)					17.00

Meter No.: RAJ14183 Old Seal: M26760043 New Seal: M2676330

Meter Body: ok | Terminal: ok | Test Terminal Block: ok | Panel: ok

CHECK METER

Parameter	Last Reading	Reading on End of Month	Diff	MF	Total
kWh Import	0.00	0.00	0.00	1	0.00
kWh Export	0.00	0.00	0.00	1	0.00
kVAh Import	0.00	0.00	0.00	1	0.00
kVAh Export	0.00	0.00	0.00	1	0.00
kVArh Q1 (Lag Import)	0.00	0.00	0.00	1	0.00
kVArh Q2 (Lead Import)	0.00	0.00	0.00	1	0.00
kVArh Q3 (Lag Export)	0.00	0.00	0.00	1	0.00
kVArh Q4 (Lead Export)	0.00	0.00	0.00	1	0.00
Import Power Factor					0.00
Export Power Factor					0.00
Import Billing MD (kVA)					0.00
Export Billing MD (kVA)					0.00

Meter No.: RAJ14184 Old Seal: M26760044 New Seal: M2676331

Meter Body: ok | Terminal: ok | Test Terminal Block: ok | Panel: ok

Remarks:

Owner/Signatory
Legha Krishi Farm, Bhunia

Executive Engineer (M & P)
JDVVNL, BARMER