



**LEGHA KRISHI FARM**  
Aadarsh Visu Nagar, Post/GSS : Bhunia,  
Teh : Dhanau, District: Barmer (Raj) - 344704  
LOA: 313557 GSTIN: 08AAIFL9284F1ZV PAN: AAIFL9284F

### JOINT METER READING (JMR) REPORT

Plant Name: Legha Krishi Farm    Month: July    Year: 2025    Reading Date: 2025-08-05

#### MAIN METER

Parameter	Last Reading	Reading on End of Month	Diff	MF	Total
Energy Import (kWh)	1396189.95	1594439.94	198249.99	1	198249.99
Energy Export (kWh)	7330.00	8290.00	960.00	1	960.00
kVAh Import	1401479.94	1600179.97	198700.03	1	198700.03
kVAh Export	12110.00	13800.00	1690.00	1	1690.00
kVArh Q1 (Lag Import)	2150.00	2150.00	0.00	1	0.00
kVArh Q2 (Lead Import)	91330.00	102580.00	11250.00	1	11250.00
kVArh Q3 (Lag Export)	710.00	710.00	0.00	1	0.00
kVArh Q4 (Lead Export)	8010.00	9390.00	1380.00	1	1380.00
Import Power Factor					-1.00
Export Power Factor					0.57
Import Billing MD (kVA)					1655.51
Export Billing MD (kVA)					11.60

Meter No.: RAJ14183    Old Seal: M2676330    New Seal: M2676541  
Meter Body: OK | Terminal: OK | Test Terminal Block: OK | Panel: OK


#### CHECK METER

Parameter	Last Reading	Reading on End of Month	Diff	MF	Total
Energy Import (kWh)	1395920.00	1594200.06	198280.06	1	198280.06
Energy Export (kWh)	7330.00	8290.00	960.00	1	960.00
kVAh Import	1401030.02	1599769.98	198739.96	1	198739.96
kVAh Export	12140.00	13820.00	1680.00	1	1680.00
kVArh Q1 (Lag Import)	1780.00	1780.00	0.00	1	0.00
kVArh Q2 (Lead Import)	91180.00	102410.00	11230.00	1	11230.00
kVArh Q3 (Lag Export)	780.00	780.00	0.00	1	0.00
kVArh Q4 (Lead Export)	7970.00	9340.00	1370.00	1	1370.00
Import Power Factor					-1.00
Export Power Factor					0.57
Import Billing MD (kVA)					1659.00
Export Billing MD (kVA)					11.59

Meter No.: RAJ14184    Old Seal: M2676331    New Seal: M2676542  
Meter Body: OK | Terminal: OK | Test Terminal Block: OK | Panel: OK

**Remarks:** All Import Parameters Means Energy Import by Discom (Energy Export by SPD) and All Export parameters means energy export by Discom (Energy Import by SPD). MRI taken and replaced comport seal on 05.08.2025 by Executive Engineer (M & P Bamer). This metering point newly commissioned on dated 01/02/2025.

Owner/Signatory  
Legha Krishi Farm, Bhunia

  
Executive Engineer (M & P)  
JDVVNL, BARMER  
Jodhpur Discom, Barmer