



LEGHA KRISHI FARM  
Aadarsh Visu Nagar, Post/GSS : Bhunia,  
Teh : Dhanau, District: Barmer (Raj) - 344704  
LOA: 313557 GSTIN: 08AAECL1234F1ZR PAN: AAECL1234F

### JOINT METER READING (JMR) REPORT

Plant Name: Legha Krishi Farm Month: June Year: 2025 Reading Date: 2025-07-07

#### MAIN METER

Parameter	Last Reading	Reading on End of Month	Diff	MF	Total
kWh Import	1001.00	3001.00	2000.00	1	2000.00
kWh Export	101.00	201.00	100.00	1	100.00
kVAh Import	501.00	1501.00	1000.00	1	1000.00
kVAh Export	101.00	251.00	150.00	1	150.00
kVArh Q1 (Lag Import)	0.00	1.00	1.00	1	1.00
kVArh Q2 (Lead Import)	200.00	500.00	300.00	1	300.00
kVArh Q3 (Lag Export)	1.00	2.00	1.00	1	1.00
kVArh Q4 (Lead Export)	100.00	250.00	150.00	1	150.00
Import Power Factor					-1.00
Export Power Factor					0.58
Import Billing MD (kVA)					15.00
Export Billing MD (kVA)					20.00

Meter No.: RAJ14183 Old Seal: M26760043 New Seal: M2676330

Meter Body: ok | Terminal: ok | Test Terminal Block: ok | Panel: ok

#### CHECK METER

Parameter	Last Reading	Reading on End of Month	Diff	MF	Total
kWh Import	0.00	0.00	0.00	1	0.00
kWh Export	0.00	0.00	0.00	1	0.00
kVAh Import	0.00	0.00	0.00	1	0.00
kVAh Export	0.00	0.00	0.00	1	0.00
kVArh Q1 (Lag Import)	0.00	0.00	0.00	1	0.00
kVArh Q2 (Lead Import)	0.00	0.00	0.00	1	0.00
kVArh Q3 (Lag Export)	0.00	0.00	0.00	1	0.00
kVArh Q4 (Lead Export)	0.00	0.00	0.00	1	0.00
Import Power Factor					0.00
Export Power Factor					0.00
Import Billing MD (kVA)					0.00
Export Billing MD (kVA)					0.00

Meter No.: RAJ14184 Old Seal: M26760044 New Seal: M2676331

Meter Body: ok | Terminal: ok | Test Terminal Block: ok | Panel: ok

Remarks: ok

Owner/Signatory  
Legha Krishi Farm, Bhunia

Executive Engineer (M & P)  
JDVVNL, BARMER