

CO₂ Impact Electric Vehicle Charging on a Local Microgrid: a case study in Southern California

Luis Fernando Enriquez-Contreras^{*†}, Matthew Barth^{*†}, Sadrul Ula[†]

^{*}*Department of Electrical and Computer Engineering*

University of California, Riverside

Riverside, United States of America

lenri001@ucr.edu, barth@ece.ucr.edu

[†]*College of Engineering, Center for Environmental Research & Technology*

University of California, Riverside

Riverside, United States of America

lenri001@ucr.edu, barth@ece.ucr.edu, sula@cert.ucr.edu

Abstract—In this paper, we evaluate a case study at the University of California, Riverside (UCR) that simulates different EV charging setups with their associated electric costs and CO₂. The CO₂ are calculated with high resolution CAISO CO₂ emissions data in order to review the different emission levels from the different setups. Electric costs are also compared in order to see the different savings the consumer will have with the different setups. It was found that Level 2 charging has a minimal impact on electric costs and CO₂ emissions, which can be offsetted with EV pricing, and by replacing trips from internal combustion engine (ICE) vehicles. Level 3 charging does cause a higher output of emissions, it can double the demand costs by itself. While the CO₂ can be offset from the prevented ICE trips, a prevention of Level 3 charging during peak times must be implemented to prevent high demand costs.

Index Terms—microrgrids, demand response, CO₂ emissions, modelica, EV charging

I. INTRODUCTION

A. Background

California is committed to reducing greenhouse gas emissions through various approaches. However, the two largest contributors to greenhouse gas emissions in California are transportation and electricity generation. In California, 18.84 % percent of 2022 vehicle sales were electric, [1] and the state plans on banning internal combustion engine vehicles by 2035 [2]. At the same time, California is increasing the number of charging stations in the state, having over 13,737 stations [3]. Electric vehicle technology has improved, and new vehicles can charge in 20-60 minutes [4]. This is due to Level 3 charging, which can be as high as 350 kilowatts (kW), as opposed to Level 2 charging, which is capped at 19 kW [4]. While this innovation has led to a higher practicality for electric vehicles, it also leads to more difficulty for the owners of these chargers since they can create a tremendous amount of loads very quickly. Most Level 2 chargers consumers use are similar in load to an air conditioner. While California tries to increase clean energy penetration, it also needs to reduce the amount of GHG emissions produced by transportation through electrification. This leads to two conundrums: how will California add

enough capacity for electrified transport, and how clean is the grid to minimize the amount of emissions associated with battery electric vehicles? One proposal to mitigate the strain on the grid is to keep electricity production and EV charging local by using microgrids. A microgrid is defined as: “a group of interconnected loads and distributed energy resources within clearly defined electrical boundaries that acts as a single controllable entity with respect to the grid. A microgrid can connect and disconnect from the grid to enable it to operate in both grid-connected or island-mode” As microgrids and EV chargers become ubiquitous, it is crucial to study the economic and environmental impacts EV charging, in particular fast charging, will have on microgrids.

B. Literature Review

In [5], Electric Vehicle Charging Stations (EVCS) are analyzed under different solar irradiation conditions. The study develops a demand and stochastic model, then performs a techno-economic assessment and analyzes the environmental impact of EVCS. The authors conclude that EVCS with solar’s optimal configuration and investment costs are highly dependent on feed-in tariffs and the solar irradiation of the area. The CO₂ emissions were calculated on a per year basis, and do not deal with the variations of CO₂ emissions within a single day. Also, only energy charges were calculated with no demand costs calculations. 6, proposes a control algorithm is proposed that in different scenarios can minimize charging time or costs or maximize renewable energy use. The authors used a uniform distribution during peak times to model the charging loads, with only Level 2 charging at 3.3 kW and no Level 3 charging. An EV charging model is proposed in [7], that load shifts charging events from high peak times to low peak times. The authors found their current method does little to reduce peak load shaving, and solar production surplus may not be necessarily shifted to EVs due to their low availability at the time. The dataset was limited to one week], with four EVs in a system with 10 buildings. In [8], the authors run multiple

scenarios with different self consumption rates, first comparing scenarios and then calculating emissions for each scenario.. The CO₂ emissions are calculated from whole life-cycle CO₂ emissions without a high time resolution. [9] uses the Non-dominated Sorting Genetic Algorithm- II (NSGA-II) to analyze 4 different responses with 0 % 10 % 20 % 30% EV penetration and a Monte Carlo load profile. Results were remarkable, however CO₂ calculations were not explained. and the specific impacts of Level 2 vs Level 3 charging were not shown. [10] analyzes IEEE 9 and 14 nodes that forecast the EV loads one day ahead. The author use multiple microgrids to balance out EV charging within the system. Multi-objective energy management of multiple microgrids is used to orchestrate the operation.

This paper's analyzes the impacts different Level 2 and Level 3 charging have on the behavior of microgrids and the associated electric costs and CO₂ emissions in southern California. The simulation is run in open Modelica rather than being a purely calculated model. This paper also uses a higher time resolution data than most to calculate the CO₂ emissions every 15 minutes.

C. Peak Shaving Strategy

Peak shaving is a standard method for reducing high-demand charges. Since demand charges are based on only the maximum value over the entire month, we assume the consumer wants to minimize the demand charges as much as possible. Our algorithm is based solely on cost savings for a typical microgrid. During peak-shaving, the algorithm looks at the amount of power being imported, if there is enough energy, and if the batteries can mitigate a fraction of that or the total amount.

D. CO₂ Emissions

Our microgrid's solar production greatly overlaps with the local solar energy production within the larger grid. With a BESS, we can utilize renewable energy during peak times and at night. In this scenario, the control algorithm is economically based since we want to see how EV charging aligns with actual CO₂ emission outputs. The simulation uses emission output calculations from CAISO for each time interval as a sum of all the powerplant CO₂ emissions (imports, natural gas, biogas, biomass, geothermal, coal) $\frac{\text{mTON}_{\text{CO}_2}}{\text{hour}}$. The CO₂ emissions output is divided by the amount of power produced (solar, wind, geothermal, biomass, biogas, small hydro, grid batteries, large hydro, imports, nuclear, coal) in MW, which gives us an emissions rate of $\frac{\text{mTON}_{\text{CO}_2}}{\text{W}}$. This is multiplied with our 15-minute data kW, and a multiplier. The multiplier of $\frac{1}{4000}$ converts kW into W and to address for the four 15 minute periods in an hour multiples by four. This gives us an estimate of the amount of CO₂ emissions in mTON_{CO₂} for every 15 minutes that is summed together to give us the total for the entire period. This method is similar to the one used in [11]. When the grid does not pull power from the grid

or is sending power, the CO₂ emissions are assumed to be zero since we are using our solar energy.

II. SIMULATION IN OPENMODELICA

OpenModelica is an open-source implementation of the Modelica programming language [12]. Modelica is a programming language that is designed for dynamic systems simulation [13]. OMEdit is the GUI interface for OpenModelica, allowing the user to draw a system for simulation [14]. The microgrid scenarios are simulated in OpenModelica using the Modelica buildings library. Lawrence Berkeley National Laboratory created the Modelica buildings library for building and district energy and control systems [15]. However, its capability for energy storage systems, bi-directional inverter, solar, and HVAC modeling make it ideal for a microgrid simulation setup. This allows us to create scenarios that do not currently exist in our microgrid, like running a month with solar with the same load, or running the BESS control algorithm for different electric rates. The power circuits are three-phase balanced circuits. The simulation of our case study microgrid is the grid-connected to the building netload. The model's net load is broken down into solar power, HVAC loads, regular building loads, electric vehicle chargers, and the BESS as shown in Figure 1.




Fig. 1: Microgrid Layout

A. Validation

To ensure that our model accurately portrays our real world system, a year of real world data was used to validate the P_G output. P_G is defined as the power the microgrid sends or consumes from the grid. The actual data was compared to the simulated with a correlation coefficient of ≈ 0.965087 as shown in Figure 2.




Fig. 2: Whole Year Validation

B. Solar Generation and Building Loads

The solar power in our model is based on the historical solar data from our PV array. The HVAC loads and the regular building loads are represented separately in this model but utilize the same method; they both use historical real world power data to represent their load in the system.

C. EV Charger Loads

Our model also considers transportation loads in the form of EV chargers. The EV chargers are represented as two models: Level 2 EV chargers, and Level 3 EV chargers. While other loads follow a typical daily and yearly pattern, EV loads are different since they switch on and off. Our case study microgrid has four Level 2 chargers, so it can have four “steps” of 7.2 kW each, while there is only one “step” of 50 kW with the Level 3 chargers. To generate EV loads, we use a Poisson random generator to generate the number of charge sessions in a day, the arrival times, and charging durations based on real world data.




Fig. 3: Probability Density Function of the Level 2 EV Charger Validation

Historical data was collected from the Level-2 charger to determine the parameters for the Poisson random generator, following a typical daily charge pdf shown in Figure 3, and the power output of the Level 2 chargers in Figure 4.




Fig. 4: Level 2 Chargers Simulated Power Output

D. BESS and Peak Shaving

The BESS is modeled as a battery connected to a bidirectional inverter. The BESS output is controlled by generated data from the control algorithm. The BESS output is computed in real-time by using a peak shaving algorithm utilizing BESS SOC and the grid meter output. The algorithm charges the battery when excess solar power is exported to the grid, and the battery needs to be charged. Python code reads the net load from the grid model and determines the amount of CO₂ being produced during that interval. Algorithm 1 shows the peak shaving algorithm sufficient for flat rate demand response.

Algorithm 1: Peak Shaving

```

1 net_load, SOC ← Modelica Data Output if
  condition then
2   | net_load ≤ -15 kW and SOC > 20 % and net_load
   | ≥ -100 kW BESS_inverter = -net_load - 15 kW
3 else if net_load ≤ -100 kW and SOC > 20 % then
4   | BESS_inverter = -100 kW
5 else if net_load ≥ 0 kW and SOC < 90 % and
   | net_load ≤ 100 kW then
6   | BESS_inverter = -net_load
7 else if net_load ≥ 0 kW and SOC < 90 % then
8   | BESS_inverter = 100 kW
9 else
10  | BESS_inverter = 0

```

III. RESULTS

The charging setup is modified in OpenModelica for different layouts and scenarios. The scenarios are described

in Table I. Scenarios 1 through 4 best represent a more typical setup at most EV charging stations. Scenarios 5 through 8 utilize the peak shaving abilities of a large BESS to mitigate the impacts on demand and emissions of EV charging, especially Level 3 charging. Scenarios 1 and 5 show a base case where only solar or solar and ABS are installed at a building. This is to control the experience and compare it with the other scenarios to show the impact of EV charging. Scenarios 2 and 6 would be considered the more typical EV charging setup. Most commercial centers mostly use Level 2 charging, which is relatively cheap and simple to install and does not have too much of a major impact. Scenarios 3,4,7,8 add one 50 kW charger to the setup. This represents the rapid adoption of fast charging and its impacts on commercial buildings. Each scenario is run independently of one other, and the power outputs of the different components in the simulation are shown in Figure 5. Each scenario's power pulled from the grid is juxtaposed in Figures ?? 8. The different amounts of loads produced by each charging is shown in Figure ??. The BESS output is shown in Figure ??. The average of daily CO₂ emissions from each scenario is shown in Figure 11. The emissions and electric price amounts of each scenario are shown in Table II.

TABLE I: Simulated Scenarios of the UCR Microgrid using Different Layouts and Electric Pricing Structures

Scenario	
1	Standard Building with no EV Chargers
2	Standard Building with Level 2 and Level 3 Charging
3	Microgrid Building with Solar, 500 kWh BESS, Level 2, and Level 3 Charging
4	Microgrid Building with Solar, 1 MWh BESS, Level 2, and Level 3 Charging




Fig. 5: Power measured from the meter




Fig. 6




Fig. 7




Fig. 8: Summer Net Load Scenario Comparison




Fig. 9




Fig. 10




Fig. 11: Microgrid CO₂ Emissions Outputs Averages During Times of Day

TABLE II: Microgrid Utility Prices and CO₂ Emissions Output under Different Pricing Scenarios and Pricing Structures

Scenario	Demand Charges (\$)	Energy Charges (\$)	Total Cost (\$)	Emissions CO ₂	Emissions (mTons)
1	7695	22736	30431		41
2	17343	32289	49632		52
3	12909	9239	22148		17
4	10835	9418	20253		17

IV. CONCLUSION

Electric vehicle charging will have a significant impact on the electric costs and emission levels of a microgrid. Level 2 charging had a relatively minimal effect on costs, with a 60 to 90% increase in electricity costs, which is not much considering that four Level 2 chargers were used. However, just one Level 3 EV charger can cause double to quadruple electric costs. Level 2 chargers have a very small impact on demand charges even when all four chargers are running since the 7.2 kilowatts of each EV charger is much less, and each has a max peak relative to the system. However, the 50 kW peaks created by the Level 3 charger nearly eclipse the demand for the HVAC units, and both used in unison can double the maximum peak and the demand costs. This happens mostly at noon when HVACs and EVs run simultaneously. Energy charges both with and without the BESS are similar, albeit slightly higher with BESS. This was expected since BESS does not reduce energy costs, only demand charges with the flat rate used by the university's utility company. The costs of Level 2 charging is significantly easier to recover compared to Level 3 charging. The difficulty is that just one charging event that aligns with the other loads can easily double the price of that month's electrical bill. Implementing a Level 3 charging control system must prohibit users from utilizing fast charging at peak hours when charging one vehicle can cause major costs to the provider. Aside from the major cost differences, locally produced solar power combined with EV charging has a huge potential to reduce CO₂ emissions from transportation. Even when utilizing both Level 2 and 3 chargers and no BESS, there's only a 42% increase of carbon dioxide emissions compared to no EV charging at all, increasing volume from 21 tons of CO₂ to 30 tons of CO₂. The X amount of vehicle trips mitigates this slight increase in CO₂ if combustion engine vehicles were used instead.

V. FUTURE WORKS

Future papers will investigate different more advanced control strategies to further decrease electric costs and CO₂ by preventing users from charging during high peak times, utilize the clean energy produced by the solar panels, and only pull power from the grid during low CO₂ times.

REFERENCES

- [1] C. E. Commission, "New zev sales in california." [Online]. Available: <https://www.energy.ca.gov/data-reports/energy-almanac/zero-emission-vehicle-and-infrastructure-statistics/new-zev-sales>

- [2] S. o. California, "Governor newsom announces california will phase out gasoline-powered cars & drastically reduce demand for fossil fuel in california's fight against climate change," Apr 2021. [Online]. Available: <https://www.gov.ca.gov/2020/09/23/governor-newsom-announces-california-will-phase-out-gasoline-powered-cars-dramatically-reduce-demand-for-fossil-fuel-in-californias-fight-against-climate-ch>
- [3] [Online]. Available: https://afdc.energy.gov/stations/#/analyze?country=US&fuel=ELEC&ev_levels=2®ion=US-CA
- [4] C. E. Commission, "New zev sales in california." [Online]. Available: <https://www.energy.ca.gov/data-reports/energy-almanac/zero-emission-vehicle-and-infrastructure-statistics/new-zev-sales>
- [5] N. Himabindu, S. Hampannavar, B. Deepa, and M. Swapna, "Analysis of microgrid integrated photovoltaic (pv) powered electric vehicle charging stations (evcs) under different solar irradiation conditions in india: A way towards sustainable development and growth," *Energy reports*, vol. 7, pp. 8534–8547, 2021.
- [6] S.-G. Yoon and S.-G. Kang, "Economic microgrid planning algorithm with electric vehicle charging demands," *Energies*, vol. 10, no. 10, p. 1487, 2017.
- [7] A. Purvins, C.-F. Covrig, and G. Lempidis, "Electric vehicle charging system model for accurate electricity system planning," *IET Generation, Transmission & Distribution*, vol. 12, no. 17, pp. 4053–4059, 2018.
- [8] M. Khemir, M. Rojas, R. Popova, T. Feizi, J. F. Heinekamp, and K. Strunz, "Real-world application of sustainable mobility in urban microgrids," *IEEE Transactions on Industry Applications*, vol. 58, no. 2, pp. 1396–1405, 2022.
- [9] Y. Huang, H. Masrur, M. S. H. Lipu, H. O. R. Howlader, M. M. Gamil, A. Nakadomari, P. Mandal, and T. Senjyu, "Multi-objective optimization of campus microgrid system considering electric vehicle charging load integrated to power grid," *Sustainable Cities and Society*, vol. 98, p. 104778, 2023.
- [10] B. Tan and H. Chen, "Multi-objective energy management of multiple microgrids under random electric vehicle charging," *Energy*, vol. 208, p. 118360, 2020.
- [11] J. Garrido, M. J. Barth, L. Enriquez-Contreras, A. J. Hasan, M. Todd, S. Ula, and J. Yusuf, "Dynamic data-driven carbon-based electric vehicle charging pricing strategy using machine learning," in *2021 IEEE International Intelligent Transportation Systems Conference (ITSC)*. IEEE, 2021, pp. 1670–1675.
- [12] [Online]. Available: <https://openmodelica.org/>
- [13] [Online]. Available: <https://modelica.org/modelicalanguage.html>
- [14] [Online]. Available: <https://openmodelica.org/doc/OpenModelicaUsersGuide/latest/omedit.html>
- [15] [Online]. Available: <https://simulationresearch.lbl.gov/modelica/>