

Luis Fernando Enriquez-Contreras, Matthew Barth, Sadrul Ula

College of Engineering, Center for Environmental Research & Technology  
University of California, Riverside

## Abstract

As an important part of Intelligent Transportation Systems (ITS), this paper presents a case study at the University of California, Riverside (UCR) that evaluates the effectiveness of different transportation-based microgrid configurations in reducing both carbon dioxide (CO<sub>2</sub>) emissions and electricity costs. CO<sub>2</sub> emissions are calculated using high-resolution California Independent System Operator (CAISO) CO<sub>2</sub> emissions data to accurately assess the environmental impact of each setup. Electric costs were also compared to determine the financial savings potential for the consumer. The results demonstrate that a peak-shaving transportation-microgrid strategy can effectively reduce CO<sub>2</sub> emissions in the range of 24% to 38% and costs from \$27,000 to \$29,000 per year, even when considering the additional demand from 12 vehicles charging daily at the building. However, careful consideration should be given to battery sizing, as peak-shaving has diminishing returns. Doubling the battery size may only provide an additional savings of \$2,000 per year with a negligible reduction in emissions. This highlights the importance of optimizing battery capacity to maximize cost-effectiveness and environmental impact.

## Microgrid Architecture




Figure 3: Microgrid Architecture of our Case Study Example BESS: Battery Energy Storage System

## Scenario Comparison Emissions Output Average Day




Figure 4: Microgrid CO<sub>2</sub> Emissions Outputs Averages During Times of Day: Adding a microgrid significantly reduces CO<sub>2</sub> Emissions compared to the non-microgrid scenarios (1 and 2).

## Level 2 Chargers Number of Sessions in One Year




Figure 1: Validation of the Level 2 EV Charger Stochastic Process that Compares the Probability Density Function of Actual Charging Data to the Poisson Process

## Simulated Scenarios of the UCR Microgrid using Different Layouts

Table 1

Scenario	
1	Standard Building with no EV Chargers
2	Standard Building with Level 2 and Level 3 Charging
3	Microgrid Building with 100 kW Solar, 500 kWh BESS, No EV Charging
4	Microgrid Building with 100 kW Solar, 100 kWh BESS, Level 2, and Level 3 Charging
5	Microgrid Building with 100 kW Solar, 250 kWh BESS, Level 2, and Level 3 Charging
6	Microgrid Building with 100 kW Solar, 500 kWh BESS, Level 2, and Level 3 Charging
7	Microgrid Building with 100 kW Solar, 1 MWh BESS, Level 2, and Level 3 Charging
8	Microgrid Building with 100 kW Solar, 1 MWh BESS, Level 2, and Level 3 Charging

## Microgrid Utility Electricity Prices and Associated CO<sub>2</sub> Emissions Output under Different Scenarios

Table 2

Scenario	Demand Charges (\$)	Energy Charges (\$)	Total Cost (\$)	CO <sub>2</sub> Emissions (mTons)
1	7695	22736	30431	34
2	17343	32289	49632	47
3	3904	0	3904	18
4	14341	8209	22550	26
5	13193	8937	22130	23
6	12909	9239	22148	22
7	10835	9418	20253	22
8	9811	9577	19388	21

## BESS Capacity Comparison




Figure 2: Cost and CO<sub>2</sub> Emissions for Different Battery Capacities: A BESS capacity of 250 -500 kWh is ideal for lowering costs and CO<sub>2</sub> emissions with less diminishing returns in savings.

## Conclusions and Future Work

- Transportation-microgrids offer significant economic and environmental benefits
  - Estimated annual savings of \$8,000-\$10,000 compared to conventional systems
  - Annual savings of \$27,000-\$29,000 compared to buildings with EV chargers but no microgrid
  - 24% - 38% reduction in CO<sub>2</sub> emissions compared to conventional buildings
  - 45% - 55% reduction in CO<sub>2</sub> emissions compared to buildings with EV chargers and no microgrid
- Increased battery capacity does not guarantee improved performance
  - Increased capacity improves performance but not proportionally to the cost
  - Large capacity needed for challenging situations may not be cost-effective
- 15 kW demand price floor discourages zero net load
  - Discourages zero net load in peak shaving setups, increasing CO<sub>2</sub> emissions
- Future Work
  - Optimizing electric costs and CO<sub>2</sub> emissions through throttling charging, maximizing solar energy use, and minimizing grid draw during peak CO<sub>2</sub> emissions times
  - Assessing the impact of California's new net energy metering policy

## Acknowledgements

I would like to give a special thanks to the CE-CERT staff, the Dwight David Eisenhower Transportation Fellowship Program, and my family who have supported me throughout my research and without them this contribution would not be possible.

## Contact Information

- Researcher: Luis Fernando Enriquez-Contreras
- Web: <https://www.cert.ucr.edu/transportation-systems-vehicle-infrastructure-interaction>
- Email: [lenri001@ucr.edu](mailto:lenri001@ucr.edu)
- Phone: +1 (909) 763 1899