

DAILY LOG SHEET

Senza Health Club Ice Baths · 60 Collins Road, Dromana VIC 3936 · three baths, 390 L each, manual dosing

DATE		DAY		OPERATOR	
CALIBRATION DISC	Pass ☐ Fail ☐	TIME RUN		INITIALS	

Run the calibration check disc before the pre-open round. On a fail, do not use the meter and do not open the baths. Call Ace on 0422 470 214.

TEST AND DOSE RECORD											Test every bath, every round. Dose if outside target, circulate 15 minutes, retest.
ROUND	TIME	BATH	FREE CL MG/L	TOTAL CL MG/L	COMB. CL MG/L	PH	TEMP °C	CLEAR Y/N	BATHERS SINCE	DOSE GIVEN (ML / G)	INITIALS
PRE-OPEN 08:45 · full panel, all three baths. Baths do not open until every one is in range.											
Pre-open		1									
		2									
		3									
retest											
ROUND 2 12:45											
Round 2		1									
		2									
		3									
retest											
ROUND 3 16:45 · busiest period sits behind this one. Expect the largest chlorine demand.											
Round 3		1									
		2									
		3									
retest											
CLOSE 20:00 · final readings and bather count recorded before draining.											
Close		1									
		2									
		3									

Combined chlorine = total chlorine minus free chlorine. Record all three. Every dose needs a retest entry beneath it.

CLOSE OF BUSINESS — DRAIN, CLEAN AND REFILL											Every trading day, all three baths
#	STEP		BATH 1	BATH 2	BATH 3						
1	Baths closed to bathers, signage placed. Bath drained completely										
2	Cartridge filter removed, cleaned, refitted										
3	All wetted surfaces and waterline scrubbed, non-abrasive pad only										
4	Rinsed thoroughly with mains water. Surround, steps and handrails wiped										
5	Refilled to operating level (390 L), pump running										
6	Sodium bicarbonate added — 39 g then circulate 15 min		g	g	g						
7	Sodium hypochlorite 12.5% added — 9.4 mL then circulate 15 min, test full panel		mL	mL	mL						
8	pH adjusted to 7.3–7.6 with dry acid, 5 mL steps (record grams used)		g	g	g						
9	Post-refill panel recorded below. Circulation pump left running overnight										

POST-REFILL PANEL	FREE CL	TOTAL CL	COMB. CL	PH	ALKALINITY	TEMP °C	CLEAR Y/N
Bath 1							
Bath 2							
Bath 3							

ROUNDS MISSED, AND WHY			
ANY BATH CLOSED TODAY?	Y ☐ N ☐	IF YES, COMPLETE FORM F4	
WEEKLY DEEP CLEAN DONE?	Y ☐ N ☐	TOTAL BATHERS, ALL BATHS	
OPERATOR SIGNATURE		TIME COMPLETED	

HOLD THESE NUMBERS	DOSE CHART — ONE BATH, 390 L	CLOSE THE BATH IF
Free chlorine Target 3.0, trade 2.0–5.0 legal min 1.0	Raise free Cl 1.0 3.1 mL hypochlorite 12.5%	Free Cl below 1.0 · total above 10 · pH below 7.0 or above 8.0 · combined above 1.0 or above free · floor not visible · pump not running
pH 7.3 to 7.6 legal 7.2–7.8	Raise free Cl 2.0 6.2 mL	Any staff member may close a bath. No permission needed. Tell the duty manager and complete Form F4. Shannon decides when it reopens.
Combined Cl Below 0.5, always below the free	Raise free Cl 3.0 9.4 mL refill dose and target	TEST → DOSE → CIRCULATE 15 MIN → RETEST → RECORD. Never dose twice without a test in between, never with a bather in the bath, never mix acid and chlorine, never pour from the drum. Full PPE every dose.
Alkalinity 80 to 120 legal above 60	Raise alkalinity 60 39 g bicarbonate refill dose	Write it down as you do it. A missed round is written in as missed, with the reason.
Clarity Floor of the bath clearly visible	Lower pH 7 g dry acid. Two doses max, then call Ace	Emergency 000 · Poisons 13 11 26 · Ace 0422 470 214
	Raise pH 4 g soda ash per 10 mg/L. pH = soda ash, alkalinity = bicarbonate	