

- The last line shall include the accumulated value for the period of the report for the data collections.

*Daily Reports:*

- The periods shall be of 1 hour each. The hour-mean value shall be included for each hour.
- The daily mean shall be included in the second last line.
- All measurements and parameters shall be included in the report.
- The accumulated value for sum up values (water quantities etc.) at the time the report ends shall be included in the last line.
- The daily report shall automatically be printed.

*Monthly Reports:*

- The periods shall be of 24 hours each. The daily mean value shall be included.
- The monthly mean value shall be included in the second last line.
- All measurements and parameters shall be included in the report.
- The accumulated values for measurements at the time the report ends shall be included in the last line.

*Yearly Reports:*

- The periods shall be of 1 month each. The monthly mean value shall be included.
- The yearly mean value shall be included in the second last line.
- All measurements and parameters shall be included in the report.
- The accumulated values for measurements and parameters at the time the report ends shall be included in the report.
- The report shall automatically be printed the 1st of January.

*Alarm Report:*

- The alarm report shall be printed at the operator's request. It shall be possible to select start and stop time for the period of report.
- Automatic printing of the report shall at a defined time be possible.

The report shall as a minimum include the following information:

- Component no.
- Alarm text (min. 25 characters)
- Time for start of the alarm
- Time for acknowledge of the alarm
- Time for stop of the alarm
- Alarm priority
- Name of person that acknowledged the alarm
- The actual alarm value