

In the event there are anomalous MISO market results related to the PARs controlling the Michigan-Ontario Interface ("Interface") such that Interface flow equals Interface schedules ("normal operation"), the Transmission Provider will consult with MISO's Independent Market Monitor and the IESO and other Reliability Coordinators (such as PJM and NYISO) as may be appropriate and will determine if the Transmission Provider should temporarily suspend normal operation of the PARs. The Transmission Provider will coordinate the change in Interface control status with the IESO, post information about the control status of the Interface on its OASIS website, and file a report with FERC describing the circumstances and changes required to resume normal operations of the PARs. MISO will not implement a change in the normal operation of the PARs if to do so would threaten the reliability of the Transmission System.