

APPENDIX 7 TO GIP

INTERCONNECTION PROCEDURES FOR A WIND GENERATING PLANT

Appendix 7 sets forth procedures specific to a wind generating plant. All other requirements of this GIP continue to apply to wind generating plant interconnections.

A. Special Procedures Applicable to Wind Generators

Interconnection Customer, in completing the Interconnection Request required by Section 3.3 of this GIP, may provide to Transmission Provider a set of preliminary electrical design specifications depicting the wind plant as a single equivalent generator. Upon satisfying these and other applicable Interconnection Request conditions, the wind plant may enter the queue and receive the base case data as provided for in this GIP.

No later than six (6) months after submitting an Interconnection Request completed in this manner, Interconnection Customer must submit completed detailed electrical design specifications and other data (including collector system layout data) needed to allow Transmission Provider to complete the System Impact Study.