



**ADDENDUM
to
INSTALLATION INSTRUCTIONS
for
Grant Spira 6-26kW and 9-36kW
Wood Pellet Boilers**

DOC.42-01/01 Rev.00 February 2014

ATTENTION INSTALLERS - UPDATED INFORMATION!

The Grant Spira condensing wood pellet boilers have a recent change that differs from the Installation & Servicing Instructions supplied with the unit. This change is due to both our continued product improvement process and compliance with new European Standards.

Please read this Addendum and use the information in conjunction with the corresponding sections of the Installation & servicing Instructions (as indicated below).

After installation and commissioning the boiler(s), please ensure that both the Installation & Servicing Instructions and this Addendum are left with the user for future reference.

Deflector Baffle

The Grant Spira 6-26 and 9-36 boilers are no longer fitted with a deflector baffle in the combustion chamber.

As a result ALL references to the baffle in the following sections of the Installation and Servicing Instructions should now be ignored:

10 Commissioning Section 10.3.2 Combustion Chamber (including Figure 10-3)

11 Boiler Servicing Section 11.6.3 Combustion Chamber (including Figure 11-9)