



FABRICATION MATERIALS				
PT NO	COMPONENT DESCRIPTION	N.S. (MM)	ITEM CODE	QTY
1	PIPE (GREP) 4.1MM WT API 15LR	50	MC000007249-(1G03)	2.5M
2	ELBOW 90 (GREP) GLASS REINFORCED PLASTIC (GRP)	50	MC000006148-(1G03)	2
3	ELBOW 45 (GREP) GLASS REINFORCED PLASTIC (GRP)	50	MC000006146-(1G03)	1

CUT PIPE LENGTH						
PIECE NO	CUT LENGTH	N.S. (MM)	REMARKS	PIECE NO	CUT LENGTH	N.S. (MM)
<1>	811	50		<2>	629	50
<3>	383	50		<4>	675	50



GRP

HOLDS 1 Cleared 2 Cleared			Notes 1. NO MODIFICATIONS TO CRITICAL LINES WITHOUT PRIOR APPROVAL FROM STRESS DEPARTMENT.			MATL CODE	COMM. PACK	TEST LOOP NO.	PRIORITY																				
									6																				
Reference Drawings FOR ISOMETRIC LEGEND SHEET SEE DRAWING :- WNB-3000-DX-1000.01							ISO DATA : bbrzz05 30-DEC-96	G.A. REFERENCE : 2602.01	P&ID REFERENCE : 3090.02	DESTINATION CODE : A	AREA : CD6	STRESS RELIEF : N	CRITICAL LINE : N	INSULATION CLASS :	SPECIFICATION : 1G3	DRAWING NUMBER WNB-PUCD6-DH-1356	RFV C1												
TEST PRESSURE KPa g	1800	LAST ITEM NUMBER																											
TEST MEDIUM	POT. WATER																												
INSULATION THICKNESS	NONE																												
COLOUR CODE	BLACK.W.Y11	LAST WELD NUMBER	C1	03/01/97	APPROVED FOR CONSTRUCTION													AN											
PAINT SYSTEM	-		REV	DATE	REVISIONS													BY											
N.D.T. CLASS	2																												