




FABRICATION MATERIALS				
PT NO	COMPONENT DESCRIPTION	N.S. (MM)	ITEM CODE	QTY
1	PIPE (GREP) 4.1MM WT API 15LR	50	MC000007249--(1G03)	1.6M
ERECTION MATERIALS				
PT NO	COMPONENT DESCRIPTION	N.S. (MM)	ITEM CODE	QTY
2	REDUCER CONC (GREP)	100 x 50	MC000005995--(1G03)	1
3	GLASS REINFORCED PLASTIC (GRP) ELBOW 45 (GREP) GLASS REINFORCED PLASTIC (GRP)	50	MC000006146--(1G03)	1

CUT PIPE LENGTH							
PIECE NO	CUT LENGTH	N.S. (MM)	REMARKS	PIECE NO	CUT LENGTH	N.S. (MM)	REMARKS
<1>	1304	50	FF WELD	<2>	281	50	



GRP

HOLDS			Notes 1. NO MODIFICATIONS TO CRITICAL LINES WITHOUT PRIOR APPROVAL FROM STRESS DEPARTMENT.			MATL CODE	COMM. PACK	TEST LOOP NO.	PRIORITY
Reference Drawings FOR ISOMETRIC LEGEND SHEET SEE DRAWING :- WNB-3000-DX-1000.01									6
TEST PRESSURE KPa g	1800	LAST ITEM NUMBER					ISO DATA : bbrzz05 30-DEC-96		
TEST MEDIUM	POT. WATER						G.A. REFERENCE : 2603.01		
INSULATION THICKNESS	NONE						P&ID REFERENCE : 3024.01		
COLOUR CODE	BLACK.W.Y11	LAST WELD NUMBER	C1	03/01/97	APPROVED FOR CONSTRUCTION	AN	DESTINATION CODE : A		
PAINT SYSTEM	-		REV	DATE	REVISIONS	BY	AREA : CD6		
N.D.T. CLASS	2						STRESS RELIEF : N		
							CRITICAL LINE : N		
							INSULATION CLASS :		
							SPECIFICATION : 1G3		
							DRAWING NUMBER		
							WNB-PUCD6-DH-1366		
							RFV C1		