[Total No. of Printed Pages :2

www.rgpvonline.com

Roll No

EE/EX-227

B.E. IV Semester

Examination, June 2017

Choice Based Credit System (CBCS) **Power System-I**

Time: Three Hours

Maximum Marks: 60

Note: i) Attempt any five questions.

ii) All questions carry equal marks.

- Explain the effect of high transmission voltage on power 1. a) system economy.
 - b) Explain the difference between feeder, distributor and service mains? www.rgpvonline.com
- 2. a) Explain the problems associated with large interconnected systems.
 - Define demand factor and load factor explain the values of demand factor and load factor are always less than one.
- Derive the expression for calculating the internal and external flux linkages of conductor carrying current. Hence deduce an expression for the total inductance of a single phase line.
- a) Explain the necessity of grading of cables. Explain different type of grading the cables.
 - A single core, lead covered cable is to be designed for 66kV to earth. Its conductor radius is 10mm and its insulating materials A, B and C have relative permittivities of 5.4 and 3 respectively and corresponding permissible stresses of 3.8, 2.6 and 2.0 kV/mm (rms) respectively. Find the minimum diameter of the lead sheath.

www.rgpvonline.com www.rgpvonline.com

www.rgpvonline.com www.rgpvonline.com

www.rgpvonline.com

[2]

- Derive A, B, C and D constants for medium transmission line.
 - b) A three phase, 50Hz transmission line, 40km long delivers 36MW at 0.8 power factor lagging at 60kV per phase. The line constants per conductor are $R=2.5\Omega$, L=0.1H, C= 0.25µF, shunt leakage may be neglected. Calculate efficiency, voltage regulation, voltage, Current, Power factor and active power.

www.rgpvonline.com

- a) Explain different methods for achieving uniform distribution of voltage along the insulators.
 - b) A string of suspension insulators consists of four units. The capacitance between each link pin and earth is one-tenth of the self capacitance of a unit. The voltage between the line conductor and earth is 100kV. Calculate string efficiency.
- Explain modified Kelvin's law for most economical size of the conductor.
 - b) A three phase 4-wire system is used for lightening compare the amount of conductor material required with that needed for a 2 wire d.c. system with same lamp voltage. Assume the same losses and balanced load the neutral wire has half the cross section of the other.
- 8. Write short notes on any two
 - Sag template
 - Method of voltage control
 - Bundle conductors
 - Ferranti effect

www.rgpvonline.com

EE/EX-227

www.rgpvonline.com