http://www.rgpvonline.com

Examination, May 2019

Choice Based Grading System (CBGS) Refrigeration and air conditioning

Time: Three Hours

Maximum Marks: 70

Attempt any five questions. Note: i)

- ii) All questions carry equal marks.
- iii) Use of refrigeration property table and psychometric chart is permitted.
- Sketch the schematics of refrigeration system operating on Bell-coleman cycle and explain its working. Represent the process on P-V and T-S plots
 - Define the following term:
 - Refrigeration
 - Refrigeration effect
 - iii) Ton of refrigeration
- 2. A simple saturation cycle using F-12 as refrigerant has been designed to produce 10 tons of ice per day from water at 35°C to ice at -5°C. For effective heat transfer at evaporator and condenser units, a temperature difference of atleast 10°C is required to be maintained. Using P-h chart determine:
 - Mass flow of refrigerant

AU/ME-8002 (CBGS)

ii) Power required to run the plant

PTO

http://www.rgpvonline.com

iii) Cylinder dimension assuming length/diameter ratio of 1.0 for a single cylinder, single acting compressor if its runs 1200 revolution per minute and has a volumetric efficiency of 90%.

How COP of this system compares with that of Carnot cycle?

Given: latent heat of ice = 335kJ/kg and specific heat of ice = 1.92kJ/kg K.

- Explain the desirable properties of refrigerants.
 - What is simple vapour absorption system? State how its performance can be improved.
- An air water mixture at 20°C and 760mm mercury has a relative humidity is 70%. Determine
 - Partial pressure of vapour and air
 - Humidity ratio
 - iii) Saturation ratio
 - iv) Dew point

http://www.rgpvonline.com

http://www.rgpvonline.com

- v) Density of mixture
- Define and explain the dry bulb, wet bulb and dew point temperatures. http://www.rgpvonline.com
- 5. Determine the sensible heat factor and capacity of a refrigeration system to be installed for a bank building to be designed for 100 persons. The pertinent data is stated as Outside ambient condition = 40°C DBT and 26°C WBT

Inside conditions = 22°C DBT and 55%RH

Building size = $20m \times 15m \times 5m$ high

Number of changes for infiltration load = 2.8 per 24 hour

http://www.rgpvonline.com

Ventilation air = 4.7×10^{-3} m³/s per person

Electrical load = 11500 kJ/hr

AU/ME-8002 (CBGS)

Contd...

http://www.rgpvonline.com

Latent and sensible heat release per person = 625 kJ/hr and 420 kJ/hr

Overall heat transfer coefficient for wall and ceiling = $18kJ/m^2$ hr and $10.5 kJ/m^2$ hr K

- 6. a) An air refrigeration open system operating between 1 MPa and 100 kPa is required to produce a cooling effect of 2000kJ/min. The temperature of air leaving the cold chamber is -5°C and at leaving the cooler is 30°C. Neglecting losses and clearance in the compressor and expander, determine:
 -) Mass of air circulated per hour
 - ii) Compressor work, expander work and cycle work,
 - iii) Coefficient of performance and the power required to run the machine.
 - b) For a vapour compression machine, explain the effect of under cooling and superheating on coefficient of performance.
- 7. a) Discuss with neat sketch the Electrolux refrigerator.
 - b) Enumerate and explain the component of internal heat gain during air conditioning.
- 8. Write a short notes on the following:
 - a) Throttling
 - b) Effect of condenser and evaporator pressure in VCRs
 - c) Human comfort



http://www.rgpvonline.com