JCM Project Design Document Form

A. Project description

A.1. Title of the JCM project

Introduction of High Efficiency Once-through Boiler in Golf Ball Factory

A.2. General description of project and applied technologies and/or measures

The proposed JCM project aims to improve energy saving for steam supply by introducing a high-efficiency once-through boiler at a golf factory in Indonesia. The golf ball factory needs considerable energy, and boilers consume significant amount of energy at the golf ball factory. The proposed project covers golf ball production process of No. 2 Golf Ball Factory, PT Sumi Rubber Indonesia in Karawang Regency, West Java Province of Republic of Indonesia.

The golf ball factory introduced high efficiency once-through boiler and Reverse Osmosis (RO) water treatment system to achieve the increase in the boiler efficiency and stable steam supply. For this, existing 3 ton/h once-through boiler (fuel: oil and gas) was replaced with 3 ton/h higher-efficiency once-through boiler (fuel: gas only).

A.3. Location of project, including coordinates

Country	Republic of Indonesia	
Region/State/Province etc.:	West Java Province	
City/Town/Community etc:	Karawang Regency	
Latitude, longitude	S 6°24'54", E 107°24'51"	

A.4. Name of project participants

The Republic of Indonesia	PTSumi Rubber Indonesia
Japan	Sumitomo Rubber Industries, Ltd.
	Nippon Koei Co., Ltd.

A.5. Duration

Starting date of project operation	01/07/2016
Expected operational lifetime of project	9 years

A.6. Contribution from Japan

The proposed project was partially supported by the Ministry of Environment, Japan (MOEJ) through the financing programme for JCM model projects, which provided financial support of less than half of the initial investment for the projects in order to acquire JCM credits. As for technology transfer, Kawasaki Thermal Engineering Co., Ltd. (KTE) has provided the following supports to PT Sumi Rubber Indonesia during commissioning test in the factory in Karawang Regency (16/06/16).

- Direct instruction on proper operation of once-through boiler to boiler operators
- Effective periodical checks to maintain efficiency of the boiler (explanation by the staff of boiler manufacturer using maintenance manual)

B. Application of an approved methodology(ies)

B.1. Selection of methodology(ies)

Selected approved methodology No.	ID_AM015
Version number	1.0

B.2. Explanation of how the project meets eligibility criteria of the approved methodology


Eligibility	Descriptions specified in the	Project information
criteria	methodology	
Criterion 1	The project boiler is a once-through	The project boiler is a once-through
	boiler with a rated capacity of 7	boiler with a rated capacity of 3 ton/hour
	ton/hour per unit or less (equivalent	(equivalent evaporation).
	evaporation)	
Criterion 2	Periodical check and maintenance	PT Sumi Rubber Indonesia arranges
	by the manufacturer of boiler or	necessary periodical check and
	authorized agent is implemented in	maintenance by authorized agent (PT
	accordance with the manufacturer's	Gikoko Kogyo Indonesia) and/or KTE in
	requirement.	accordance with the requirement of
		KTE. It is carried out yearly.
Criterion 3	Appropriate water	PT Sumi Rubber Indonesia installed RO
	purification/demineralization	water treatment system for boiler water.
	system such as Reverse Osmosis	
	(RO) membrane treatment is	
	installed.	

C. Calculation of emission reductions

C.1. All emission sources and their associated greenhouse gases relevant to the JCM project

Reference emissions	
Emission sources	GHG type
Fuel consumption by reference boiler	CO_2
Project emissions	
Emission sources	GHG type
Fuel consumption by project boiler	CO ₂

C.2. Figure of all emission sources and monitoring points relevant to the JCM project



C.3. Estimated emissions reductions in each year

Year	Estimated Reference	Estimated Project	Estimated Emission
	emissions (tCO ₂ e)	Emissions (tCO ₂ e)	Reductions (tCO ₂ e)
2013	-	-	•
2014	-	-	-
2015	-	-	-
2016	706.7	621.7	85
2017	1,631.4	1,435.2	196
2018	1,634.5	1,437.9	196

1,634.5	4 42= 0	
1,034.3	1,437.9	196
1,634.5	1,437.9	196
1,634.5	1,437.9	196
1,634.5	1,437.9	196
1,634.5	1,437.9	196
1,634.5	1,437.9	196
817.3	718.9	98
-	-	ı
-	-	ı
-	-	1
-	-	ı
-	-	1
Total (tCO ₂ e)		1,751
	1,634.5 1,634.5 1,634.5 1,634.5 1,634.5 817.3	1,634.5 1,437.9 1,634.5 1,437.9 1,634.5 1,437.9 1,634.5 1,437.9 817.3 718.9 - -

Note:

The estimated emission reductions in each year are rounded down after the decimal point.

D. Environmental impact assessment		
Legal requirement of environmental impact assessment for	No	
the proposed project		

E. Local stakeholder consultation

E.1. Solicitation of comments from local stakeholders

The local stakeholder meeting was held in a meeting room of the government office of West Java Province on 03 March 2017.

The list of participants:

National and regional government staff

- Coordinating Ministry of Economy Affairs
- Cooperation Division of West Java Province
- Division of the Environment of West Java Province
- Department of Industry and Trade of West Java Province
- Department of the Environment of West Java Province
- Regional Development Planning of Karawang Regency
- Department of the environment of Karawang Regency
- Indonesia JCM Secretariat

A meeting with the staff of PTSumi Rubber Indonesia was also conducted at the boiler room in their factory on 3 March 2017.

E.2. Summary of comments received and their consideration

Stakeholders Comments received		Consideration of comments received
PTSumi Rubber	It is good for the factory and it should	No action is needed.
Indonesia be noted that monitoring is obliged.		
PT. Sumi Rubber	JCM was the good support for	No action is needed.
Indonesia	introducing technologies into the	
	factory. The boiler is running without	
	serious troubles.	
PTSumi Rubber	It is easy to operate the project boiler.	No action is needed.
Indonesia		
Department of	It is a good chance to introduce good	No action is needed.
the Environment	technology. We would like to extend	
of Karawang	this information to the industries in	
Regency	Karawang Regency.	
Division of the	In Sumedang, Bandung and Cimahi,	No action is needed.
Environment of	there are many industries using coal	
West Java	for their factory. It is expected that	
Province	JCM can help the fuel switch from	
	coal to oil and gas.	
	We should consider awarding the	
	effort for mitigation by private	
	entities.	
Coordinating	Coordinating Ministry of Economic	No action is needed.
Ministry of	Affairs is ready to collaborate with	
Economic Affairs	local governments to implement	
	public information activities related	
	to JCM and emission reduction.	

F. References

Reference lists to support descriptions in the PDD, if any.

Annex		

Revision history of PDD			
Version	Date	Contents revised	
1.0	30/10/2018	First Version	