Kyma Analysis Report

Date: 8. maj 2020 Name: 1991d Temperature: 23.0

Filename: 1991d-TPF-UFCM 20200508

Waves analysed : Bz387,Bx387,Izmes27,Ixmes27 Gap [mm] : 200

Phase [mm]: 1 Hall Z [mm]: 0 Peak Field Bx: 0.02322 T RMS Phase Error: 3.80 deg

Taper [mm]: 0 Hall X [mm]: -12 Delta Bx/Bx: 9.8 % Fund. En. (B2E) : 2131.2 eV = 0.6 nmPeak Field Bz: 0.61821 T Radiation wavelength (lin. fit): 0.6 nm

Peaks used: 102 Bz Taper: -1.457 G/m

Undulator Period: 22.00+-0.02 mm Delta Bz/Bz: 1.3 %

e-beam energy: 3 GeV Bx Taper: -16.856 G/m


Krms: 0.899

V Dipole: -17.9 G cm Iz(coil): -17.5 G cm Pred. C.C. currents V Quadrupole: -47.5 G Iz(BzC): -17.5 Gcm Iz(Bz): 36.5 G cm I1: 1.2285 A V Sextupole: 38.9 G/cm Ix(coil): -3.6 G cm I2: -2.6537 A

Ix(BxC): -3.6 Gcm Ix(Bx): 153.8 G cm

H Dipole: 0.5 G cm $IIx(sBx) : 0.2838 \text{ G m}^2$ I3: 0.4003 A H Quadrupole: -87.6 G IIz(sBz): -0.3105 G m^2 I4: 1.4510 A

H Sextupole: 236.0 G/cm BzTrj RMS dev.: 0.5 um BxTrj RMS dev.: 1.2 um



Kyma Srl S.S. 14 km 163,5 in Area Science Park – IT-34149 Trieste, Italy - VAT no.: IT-01131640326 Voice: +39.040.375.8796 - Fax: +39.040.375.8029 - E-mail: info@kyma-undulators.eu - web: www.kyma-undulators.eu