Kyma Analysis Report

Date: 8. maj 2020 Name: 1991d Temperature: 23.0

Filename: 1991d-TPF-UFCM 20200508

Waves analysed : Bz163,Bx163,Izmes43,Ixmes43 Gap [mm] : 200

Phase [mm] : 9 Hall Z [mm]: 0 Peak Field Bx: 0.02018 T RMS Phase Error: 1.93 deg

Taper [mm]: 0 Hall X [mm]: 5 Delta Bx/Bx: 5.8 % Fund. En. (B2E) : 3371.0 eV = 0.4 nmPeak Field Bz: 0.26815 T Radiation wavelength (lin. fit): 0.4 nm

Peaks used: 101 Bz Taper: -0.171 G/m

Undulator Period: 22.00+-0.06 mm Delta Bz/Bz: 2.4 %

e-beam energy: 3 GeV Bx Taper: -6.414 G/m

Krms: 0.391


V Dipole: -8.1 G cm Iz(coil): -8.5 G cm Pred. C.C. currents V Quadrupole: -17.6 G Iz(BzC): -8.5 Gcm Iz(Bz): 29.3 G cm I1: -0.3259 A V Sextupole: 0.0 G/cm Ix(coil): -12.0 G cm I2: -1.4497 A

Ix(BxC): -12.0 Gcm Ix(Bx): 515.1 G cm

H Dipole: -11.8 G cm $IIx(sBx) : 0.4298 \text{ G m}^2$ I3: 1.7183 A H Quadrupole: 77.2 G IIz(sBz): -0.0549 G m^2 I4: 1.4673 A

H Sextupole: 37.4 G/cm BzTrj RMS dev.: 0.6 um

BxTrj RMS dev.: 0.3 um



Kyma Srl S.S. 14 km 163,5 in Area Science Park – IT-34149 Trieste, Italy - VAT no.: IT-01131640326 Voice: +39.040.375.8796 - Fax: +39.040.375.8029 - E-mail: info@kyma-undulators.eu - web: www.kyma-undulators.eu