Kyma Analysis Report

Date: 8. maj 2020 Name: 1991d Temperature: 23.0

Filename: 1991d-TPF-UFCM 20200508

Waves analysed : Bz385,Bx385,Izmes25,Ixmes25 Gap [mm] : 200

Phase [mm]: 0 Hall Z [mm]: 0 Peak Field Bx: 0.02317 T RMS Phase Error: 3.65 deg

Taper [mm]: 0 Hall X [mm]: -12 Delta Bx/Bx: 9.9 % Fund. En. (B2E) : 2116.1 eV = 0.6 nmRadiation wavelength (lin. fit): 0.6 nm

Peak Field Bz: 0.62889 T Peaks used: 101 Bz Taper: 7.815 G/m

Undulator Period: 22.00+-0.02 mm Delta Bz/Bz: 0.9 %

e-beam energy: 3 GeV Bx Taper: -18.985 G/m


Krms: 0.914

V Dipole: -15.4 G cm Pred. C.C. currents Iz(coil): -15.1 G cm Iz(BzC): -15.1 Gcm Iz(Bz): 33.9 G cm V Quadrupole: -48.5 G I1: 0.9805 A V Sextupole: 37.2 G/cm Ix(coil): -4.0 G cm I2: -2.4029 A

Ix(BxC): -4.0 Gcm Ix(Bx): -38.4 G cm

H Dipole: -0.1 G cm $IIx(sBx) : 0.2872 \text{ G m}^2$ I3: 0.4796 A H Quadrupole: -89.5 G IIz(sBz): -0.2718 G m^2 I4: 1.4136 A

H Sextupole: 237.3 G/cm BzTrj RMS dev.: 0.5 um BxTrj RMS dev.: 1.2 um



 $\label{eq:KymaSrl} Kyma~Srl~S.S.~14~km~163,5~in~Area~Science~Park~-~IT-34149~Trieste,~Italy~-~VAT~no.:~IT-01131640326$ Voice: +39.040.375.8796 - Fax: +39.040.375.8029 - E-mail: info@kyma-undulators.eu - web: www.kyma-undulators.eu