Kyma Analysis Report

Date: 8. maj 2020 Name: 1991d Temperature: 23.0

Filename: 1991d-TPF-UFCM 20200508

Waves analysed : Bz181,Bx181,Izmes37,Ixmes37 Gap [mm] : 200

Phase [mm]: 6 Hall Z [mm]: 0 Peak Field Bx: 0.01366 T RMS Phase Error: 2.50 deg

Taper [mm]: 0 Hall X [mm]: 0 Delta Bx/Bx: 6.3 % Fund. En. (B2E) : 2523.0 eV = 0.5 nmPeak Field Bz: 0.50477 T Radiation wavelength (lin. fit): 0.5 nm

Peaks used: 102 Bz Taper: -3.892 G/m

Undulator Period: 22.00+-0.02 mm Delta Bz/Bz: 1.1 %

e-beam energy: 3 GeV Bx Taper: -4.493 G/m


Krms: 0.734

V Dipole: -11.4 G cm Pred. C.C. currents Iz(coil): -12.0 G cm V Quadrupole: 18.9 G Iz(BzC): -12.0 Gcm Iz(Bz): 58.9 G cm I1: 0.2749 A V Sextupole: 20.1 G/cm Ix(coil): 3.7 G cm I2:-1.0882 A

Ix(BxC) : 3.7 Gcm Ix(Bx) : 909.5 G cm

H Dipole: 3.8 G cm $IIx(sBx) : 0.1032 \text{ G m}^2$ I3: 0.4787 A H Quadrupole: -79.8 G IIz(sBz): -0.0493 G m^2 I4: -0.1012 A

H Sextupole: -185.8 G/cm BzTrj RMS dev.: 0.1 um BxTrj RMS dev.: 0.2 um



Kyma Srl S.S. 14 km 163,5 in Area Science Park – IT-34149 Trieste, Italy - VAT no.: IT-01131640326 Voice: +39.040.375.8796 - Fax: +39.040.375.8029 - E-mail: info@kyma-undulators.eu - web: www.kyma-undulators.eu