Kyma Analysis Report

Date: 24. feb 2020 Name: 1991b Temperature: 23.0

Filename: 1991b-TPF-UFCM 20200224

 $Waves\ analysed: Bz181, Bx181, Izmes26, Ixmes26\\ Gap\ [mm]: 200$

Phase [mm]: 6 Hall Z [mm]: 0 Peak Field Bx: 0.00873 T RMS Phase Error: 2.40 deg

Taper [mm]: 0 Hall X [mm]: -5 Delta Bx/Bx: 8.5 % Fund. En. (B2E) : 2764.1 eV = 0.4 nmPeak Field Bz: 0.43999 T Radiation wavelength (lin. fit): 0.4 nm

Peaks used: 102 Bz Taper: 4.374 G/m

Undulator Period: 22.00+-0.03 mm Delta Bz/Bz: 1.2 %

e-beam energy: 3 GeV Bx Taper: 3.754 G/m

Krms: 0.639


V Dipole: -0.8 G cm Iz(coil): -0.9 G cm Pred. C.C. currents V Quadrupole: 20.1 G Iz(BzC): -0.9 Gcm Iz(Bz): 25.7 G cm I1: 0.7131 A V Sextupole: -40.3 G/cm Ix(coil): 3.7 G cm I2: -1.4783 A

Ix(BxC): 3.8 Gcm Ix(Bx): 867.8 G cm

H Dipole: 6.2 G cm $IIx(sBx) : 0.0943 \text{ G m}^2$ I3: -0.8602 A H Quadrupole: 6.8 G IIz(sBz): -0.2666 G m^2 I4: 1.1837 A

H Sextupole: 66.0 G/cm BzTrj RMS dev.: 0.1 um

BxTrj RMS dev.: 0.1 um



Kyma Srl S.S. 14 km 163,5 in Area Science Park – IT-34149 Trieste, Italy - VAT no.: IT-01131640326 Voice: +39.040.375.8796 - Fax: +39.040.375.8029 - E-mail: info@kyma-undulators.eu - web: www.kyma-undulators.eu