Kyma Analysis Report

Date: 24. feb 2020 Name: 1991b Temperature: 23.0

Filename: 1991b-TPF-UFCM 20200224

Waves analysed : Bz229,Bx229,Izmes27,Ixmes27 Gap [mm] : 200

Phase [mm]: 6 Hall Z [mm]: 1 Peak Field Bx: 0.00762 T RMS Phase Error: 5.45 deg

Taper [mm]: 0 Hall X [mm]: 0 Delta Bx/Bx : 10.4 % Fund. En. (B2E) : 2622.3 eV = 0.5 nmPeak Field Bz: 0.48222 T Radiation wavelength (lin. fit): 0.5 nm

Peaks used: 102 Bz Taper: -17.900 G/m

Undulator Period: 22.00+-0.03 mm Delta Bz/Bz: 1.6 %

e-beam energy: 3 GeV Bx Taper : 4.046 G/m


Krms: 0.701

V Dipole: -3.2 G cm Iz(coil): -3.4 G cm Pred. C.C. currents V Quadrupole: -10.3 G Iz(BzC): -3.4 Gcm Iz(Bz): 37.8 G cm I1: 0.7831 A V Sextupole: 30.1 G/cm Ix(coil): 4.1 G cm I2: -0.8324 A

Ix(BxC): 4.1 Gcm Ix(Bx): 895.5 G cm

H Dipole: 8.0 G cm $IIx(sBx) : -0.0337 \text{ G m}^2$ I3: -0.7486 A H Quadrupole: 11.1 G IIz(sBz): -0.1683 G m^2 I4: 0.3105 A

H Sextupole: 96.2 G/cm BzTrj RMS dev.: 0.1 um BxTrj RMS dev.: 0.1 um



Kyma Srl S.S. 14 km 163,5 in Area Science Park – IT-34149 Trieste, Italy - VAT no.: IT-01131640326 Voice: +39.040.375.8796 - Fax: +39.040.375.8029 - E-mail: info@kyma-undulators.eu - web: www.kyma-undulators.eu