

**Thermodynamics: An Engineering Approach**

**8th Edition**

**Yunus A. Çengel, Michael A. Boles**

**McGraw-Hill, 2015**

**Topic 18**

**The Rankine Cycle**

# Objectives

- Evaluate the performance of gas power cycles for which the working fluid remains a gas throughout the entire cycle.
- Analyze vapor power cycles in which the working fluid is alternately vaporized and condensed.
- Investigate ways to modify the basic Rankine vapor power cycle to increase the cycle thermal efficiency.

# THE CARNOT VAPOR CYCLE

The Carnot cycle is the most efficient cycle operating between two specified temperature limits but it is not a suitable model for power cycles. Because:

**Process 1-2** Limiting the heat transfer processes to two-phase systems severely limits the maximum temperature that can be used in the cycle ( $374^{\circ}\text{C}$  for water)

**Process 2-3** The turbine cannot handle steam with a high moisture content because of the impingement of liquid droplets on the turbine blades causing erosion and wear.


**Process 4-1** It is not practical to design a compressor that handles two phases.

The cycle in (b) is not suitable since it requires isentropic compression to extremely high pressures and isothermal heat transfer at variable pressures.


- 1-2 isothermal heat addition in a boiler
- 2-3 isentropic expansion in a turbine
- 3-4 isothermal heat rejection in a condenser
- 4-1 isentropic compression in a compressor

FIGURE 10-1

$T$ - $s$  diagram of two Carnot vapor cycles.



(a)




(b)

# RANKINE CYCLE: THE IDEAL CYCLE FOR VAPOR POWER CYCLES

Many of the impracticalities associated with the Carnot cycle can be eliminated by superheating the steam in the boiler and condensing it completely in the condenser.

The cycle that results is the Rankine cycle, which is the ideal cycle for vapor power plants. The ideal Rankine cycle does not involve any internal irreversibilities.


- 1-2 Isentropic compression in a pump
- 2-3 Constant pressure heat addition in a boiler
- 3-4 Isentropic expansion in a turbine
- 4-1 Constant pressure heat rejection in a condenser



**FIGURE 10-2**

The simple ideal Rankine cycle.

# Energy Analysis of the Ideal Rankine Cycle



## Steady-flow energy equation

$$(q_{\text{in}} - q_{\text{out}}) + (w_{\text{in}} - w_{\text{out}}) = h_e - h_i \quad (\text{kJ/kg})$$

*Pump* ( $q = 0$ ):

$$w_{\text{pump,in}} = h_2 - h_1$$

$$w_{\text{pump,in}} = v(P_2 - P_1)$$

$$h_1 = h_f @ P_1 \quad \text{and} \quad v \cong v_1 = v_f @ P_1$$

*Boiler* ( $w = 0$ ):

$$q_{\text{in}} = h_3 - h_2$$

*Turbine* ( $q = 0$ ):

$$w_{\text{turb,out}} = h_3 - h_4$$

*Condenser* ( $w = 0$ ):

$$q_{\text{out}} = h_4 - h_1$$

$$w_{\text{net}} = q_{\text{in}} - q_{\text{out}} = w_{\text{turb,out}} - w_{\text{pump,in}}$$

$$\eta_{\text{th}} = \frac{w_{\text{net}}}{q_{\text{in}}} = 1 - \frac{q_{\text{out}}}{q_{\text{in}}}$$

The efficiency of power plants in the U.S. is often expressed in terms of **heat rate**, which is the amount of heat supplied, in Btu's, to generate 1 kWh of electricity.



$$\eta_{\text{th}} = \frac{3412 \text{ (Btu/kWh)}}{\text{Heat rate (Btu/kWh)}}$$

The thermal efficiency can be interpreted as the ratio of the area enclosed by the cycle on a  $T$ - $s$  diagram to the area under the heat-addition process.

# The Simple Ideal Rankine Cycle

Consider a steam power plant operating on the simple ideal Rankine cycle. Steam enters the turbine at 3 MPa and 350°C and is condensed in the condenser at a pressure of 75 kPa. Determine the thermal efficiency.


## Example 1




# DEVIATION OF ACTUAL VAPOR POWER CYCLES FROM IDEALIZED ONES

The actual vapor power cycle differs from the ideal Rankine cycle as a result of irreversibilities in various components.

Fluid friction and heat loss to the surroundings are the two common sources of irreversibilities.



(a)



(b)

**Isentropic efficiencies**

$$\eta_P = \frac{w_s}{w_a} = \frac{h_{2s} - h_1}{h_{2a} - h_1}$$


$$\eta_T = \frac{w_a}{w_s} = \frac{h_3 - h_{4a}}{h_3 - h_{4s}}$$

(a) Deviation of actual vapor power cycle from the ideal Rankine cycle.


(b) The effect of pump and turbine irreversibilities on the ideal Rankine cycle.

# An Actual Steam Power Cycle

A steam power plant operates on the cycle shown below. If the isentropic efficiency of the turbine is 87% and the isentropic efficiency of the pump is 85%, determine the thermal efficiency of the cycle and the net power output for a mass flow rate of 15 kg/s.




## Example 2





# HOW CAN WE INCREASE THE EFFICIENCY OF THE RANKINE CYCLE?

The basic idea behind all the modifications to increase the thermal efficiency of a power cycle is the same: Increase the average temperature at which heat is transferred to the working fluid in the boiler, or decrease the average temperature at which heat is rejected from the working fluid in the condenser.



**FIGURE 10–6**


The effect of lowering the condenser pressure on the ideal Rankine cycle.

## **Lowering the Condenser Pressure (Lowers $T_{low,avg}$ )**

To take advantage of the increased efficiencies at low pressures, the condensers of steam power plants usually operate well below the atmospheric pressure. There is a lower limit to this pressure depending on the temperature of the cooling medium

**Side effect:** Lowering the condenser pressure increases the moisture content of the steam at the final stages of the turbine.

## Superheating the Steam to High Temperatures (Increases $T_{\text{high,avg}}$ )



**FIGURE 10–7**

The effect of superheating the steam to higher temperatures on the ideal Rankine cycle.

Both the net work and heat input increase as a result of superheating the steam to a higher temperature. The overall effect is an increase in thermal efficiency since the average temperature at which heat is added increases.


Superheating to higher temperatures decreases the moisture content of the steam at the turbine exit, which is desirable.

The temperature is limited by metallurgical considerations.

Presently the highest steam temperature allowed at the turbine inlet is about 620°C.

## Increasing the Boiler Pressure (Increases $T_{\text{high,avg}}$ )


For a fixed turbine inlet temperature, the cycle shifts to the left and the moisture content of steam at the turbine exit increases. This side effect can be corrected by reheating the steam.



**FIGURE 10-8**

The effect of increasing the boiler pressure on the ideal Rankine cycle.

Today many modern steam power plants operate at supercritical pressures ( $P > 22.06$  MPa) and have thermal efficiencies of about 40% for fossil-fuel plants and 34% for nuclear plants.




**FIGURE 10-9**

A supercritical Rankine cycle.


# Effect of Boiler Pressure and Temperature on Efficiency

Consider a steam power plant operating on the ideal Rankine cycle. Steam enters the turbine at 3 MPa and 350°C and is condensed in the condenser at a pressure of 10 kPa. Determine the thermal efficiency of the power plant (a) under these operation parameters, (b) if the steam is superheated to 600°C instead of 300°C, and (c) if the boiler pressure is raised to 15 MPa while the steam is superheated to 600°C.


## Example 3



(a)










(b)



(c)

# Solution

	Part A	Part B	Part C
Boiler Pressure	3 MPa	3 MPa	15 MPa 
Boiler Temperature (exit)	350°C	600°C 	600°C 
Steam Quality (turbine exit)	81.3%	91.5% 	80.4% 
Thermal Efficiency	33.4%	37.3% 	43.0% 

# Summary

- The Carnot vapor cycle
- Rankine cycle: The ideal cycle for vapor power cycles
  - ✓ Energy analysis of the ideal Rankine cycle
- Deviation of actual vapor power cycles from idealized ones
- How can we increase the efficiency of the Rankine cycle?
  - ✓ Lowering the condenser pressure (*Lowers*  $T_{\text{low,avg}}$ )
  - ✓ Superheating the steam to high temperatures (*Increases*  $T_{\text{high,avg}}$ )
  - ✓ Increasing the boiler pressure (*Increases*  $T_{\text{high,avg}}$ )