Public Health
Environmental Health Division

June 20, 2017

TO: Staff Planner, Land Use Department

FROM: Jessica Epstein, Environmental Health Specialist

SUBJECT: LU-17-0011: St. Vrain Creek Reach 3 Restoration project

OWNER: Boulder County

PROPERTY ADDRESS: Parcel #s 120320100008, 120320100009, 120321000002, 120321000003, 120321000036, 120321000038, 120321000041, 120321000044, 120321000046, 120322000020, 120326000023, 120326000026, 120326000029, 120326000046, 120326000060, 120327000011, 120328000001, and 120335000011

SEC-TOWN-RANGE: 20 3N 70

The Boulder County Public Health – Environmental Health division has reviewed the submittals for the above referenced docket and has the following comments.

Avoid Damage to OWTS:

1. Before beginning construction, the contractor must determine the location of all the existing approved OWTS components in the project area. The documents are scanned into septicmart.org. If there are unapproved OWTS, there may not be any information online. In this case, the owner should help with the general location of the system.
2. Heavy equipment should be restricted from the surface of the absorption field during stream restoration to avoid soil compaction, which could cause premature absorption field malfunction. Caution should be used in conducting trenching and excavation activities so that sewer lines and other OWTS components are not damaged.

This concludes comments from the Boulder County Public Health – Environmental Health division at this time. For additional information on the OWTS application process and regulations, refer to the following website: **www.SepticSmart.org**. If you have additional questions about OWTS, please do not hesitate to contact Jessica Epstein at (303) 441-1138.

Cc: OWTS file, owner, Land Use Department